



Snowy Monaro Regional Council

Options Assessment Report - Bombala Water Supply

June 2020

Executive summary

The scope of this report was to assess the condition and performance of the existing Bombala Drinking water supply covering the Raw water Pump station and Bombala Water Treatment Plant (WTP) and

Develop options for upgrade to achieve reliable treatment for the next 25 years compliant with current and likely future Australian Drinking Water Guidelines (ADWG) plus “good water industry practice” for the raw water quality conditions.

Conclusions

The main conclusions from condition assessment of the existing Water Treatment facilities were;

- The existing raw water pump station requires a new building and E, I and C works due to very old asset in poor condition and not fit for purpose.
- The existing WTP is now 39 years old and the process (especially alkali, polymer and chlorine) and most electrical systems are older than normal asset life.
- Existing sludge ponds are too small to achieve the requirements of (1) containment of filter wash water and clarifier sludge plus (2) sludge drying

The main conclusions from the assessment of demand, groundwater alternative, existing surface water quality and treatment were;

- The alternative of a future water supply from groundwater was found to be not viable
- The proposed weir on the Bombala River in the centre of Bombala township does not provide an opportunity for a secure alternative water source
- The required future (in 25 years) peak day demand for the new WTP is 1.5 ML/d
- The raw water catchment for this system is unprotected with substantial areas of grazing land for cattle/sheep/deer and septic tanks at rural properties. Based on the Health based Targets (HBT) concept, understood to be soon added to (ADWG), the Source Water Category Classification would be 4. Also, raw water quality conditions are challenging. This is mainly because this water supply from Coolumbooka Dam is from an unprotected catchment with high microbiological risk plus after chlorine is added, it produces levels of disinfection byproducts (eg THMs) that exceed ADWG health limit in the treated water. Also, the water has a continuous level of poor odour, events of very high manganese and iron and is relatively soft with very low water temperatures in winter which requires special features to be added for effective treatment.
- The existing treatment processes at the WTP are not suitable or sufficient for treatment of this combination of raw water risk and water quality conditions. Treatment essentially failed for several days soon after the recent wet weather event in February 2020. The existing process is not suitable for these rapidly deteriorating conditions.
- The existing raw water pump station structures are well beyond asset life and the pumps have no variable flow control and minimal telemetry back to the Water Treatment Plant (WTP). A reliable pump station with ability to modulate flowrate and monitor performance is essential, particularly given the relatively old AC water main connecting it to the WTP.

- The recent special water quality sampling program has highlighted the water quality challenges and inadequate existing WTP performance.

A summary of the options and comparison of options is set out below. All the Options 2 to 5 would be located at the site of the old house on the existing WTP site.

Option 3 is preferred overall on cost and non-cost advantages basis.

| Item | OPTION 1 upgrade existing WTP clarifier/filters GAC Disinfection/UV THM stripping | OPTION 2 New site Clarifier/MF GAC Disinfection/UV THM stripping | OPTION 3 New site DAF/MF GAC Disinfection/UV THM stripping | OPTION 4 New site DAF/MF Ozone/GAC Disinfection/UV THM stripping | OPTION 5 New site DAF/MF NF Disinfection |
|-------------------------|---|---|---|---|--|
| CAPEX | \$8.6m | \$9.3m | \$9.1m | \$9.8m | \$9.6m |
| NPC | \$12m | \$13.5m | \$13.3m | \$14.2m | \$17m |
| Performance | √√ (clarifier uncertain) | √√√ (small nitrification risk) | √√√ (small nitrification risk) | √√√√ | √√√√√ |
| Operability | √√ (too compact) | √√√√ | √√√√ | √√√√ | √√√ (|
| Env&WHS | √√ (ongoing poor access to filter valves) | √√√ | √√√ | √√√ | √(high volume of salty NF waste) |
| Construction complexity | √ (existing structure and uncertain time offline needing carting in water risks) | √√√√ (small building easily fits) | √√√√ (small building easily fits) | √√√ (bigger building) | √√√ (bigger building) |
| Easy procurement | √√√√ | √√√√ | √√√√ | √√√ | √√ (NF equipment) |

The above costs do not include Fluoridation. Based on a separate contract for a new building and sodium fluoride dosing system compliant with the NSW code the extra cost is estimated at \$0.65m. This cost is based on recent tenders and independent cost estimates.

Recommendations

The following is recommended based on this assessment of requirements and the options to achieve them;

- Based on projected demand in 25 years' time, the required new treated water output capacity is 1.5ML/d
- The features of the preferred WTP Option 3 to go to concept design are;
 - Process: Pre-oxidation + Dissolved Air Floatation (DAF) + Membrane filtration + GAC + UV + chlorination then chloramination. + THM stripping
 - Location; at existing old house site suited to bushfire rating with construction occurring while keeping the existing plant operating to avoid need to cart in water

- Impact on existing WTP : during concept design stage investigate reuse opportunities (eg existing coagulant bulk storage) to reduce total cost
- New wash water/sludge system; wash water +sludge holding tank and pumping to thickener and then concentrated sludge to existing sludge ponds and supernatant return to WTP inlet
- Construct a separate purpose built new chlorination building to house a duty + standby 920kg drums of chlorine plus duty/standby gas chlorinators and separate service water system
- Because Fluoridation is best located in a separate purpose built building , requires specialist contractors and often completed under a separate funding process it is recommended it be a separate contract
- Continue, at say every 2 weeks frequency, the special water sampling program over autumn /winter focusing on the main issues relevant to optimising the new treatment process design;
 - Raw water at dam; E,coli, pH, alkalinity, colour, turbidity, MIB/Geosmin and DOC
 - Filtered water; turbidity prior to addition of soda ash and chlorine
 - Treated water; DOC, pH, alkalinity and THMs (CWS, Res1 and retic sites)

Table of contents

| | | |
|-----|--|----|
| 1. | Introduction..... | 7 |
| 1.1 | Project need..... | 7 |
| 1.2 | Project scope..... | 7 |
| 1.3 | Purpose of report..... | 7 |
| 1.4 | Scope and limitations..... | 7 |
| 1.5 | Assumptions..... | 8 |
| 2. | Performance Objectives..... | 10 |
| 2.1 | Introduction..... | 10 |
| 2.2 | Water Demand and WTP design capacity..... | 10 |
| 2.3 | Treated Water Quality Requirements..... | 10 |
| 2.4 | Asset condition, environmental/OH&S requirements and reliable operation..... | 12 |
| 3. | Review of Existing Bombala System..... | 14 |
| 3.1 | Overview of Existing System..... | 14 |
| 3.2 | Water Demand and WTP design capacity..... | 16 |
| 3.3 | Water Quality Requirements..... | 18 |
| 3.1 | Asset condition, environmental/OH&S requirements and reliable operation..... | 25 |
| 4. | Investigation of Alternative Water Sources..... | 29 |
| 4.1 | Groundwater Investigation..... | 29 |
| 4.2 | Weir across Bombala River..... | 29 |
| 5. | Options for future Water Treatment..... | 32 |
| 5.1 | Development of suitable Water treatment process trains..... | 32 |
| 5.2 | Option 1: Upgrade and Retain exiting treatment plant buildings/structures..... | 35 |
| 5.3 | New WTP Options..... | 41 |
| 6. | Comparison of Options..... | 50 |
| 6.1 | Introduction..... | 50 |
| 6.2 | Comparison of New WTP site layout to upgrade of Existing..... | 50 |
| 7. | Conclusions & Recommendations..... | 53 |
| 7.1 | Conclusions..... | 53 |
| 7.2 | Recommendations..... | 55 |

Table index

| | | |
|---------|--|----|
| Table 1 | Treated water quality targets..... | 11 |
| Table 2 | Current and projected demand and WTP flows..... | 18 |
| Table 3 | Results for coliforms in raw water (MPN/100mL, as assessed by NSW Health)..... | 20 |
| Table 4 | Results for E. Coli in raw water (MPN/100mL, as assessed by ALS)..... | 21 |
| Table 5 | Bombala WTP Log Removal Values (LRVs) under HBT guidelines..... | 22 |

| | | |
|-----------|--|----|
| Table 6 | Log Removal Values (LRVs) for future treatment options | 23 |
| Table 7 | Design raw water quality envelope | 24 |
| Table 8 | Asset condition/capacity summary for existing WTP | 25 |
| Table 9 | Treated water quality performance | 26 |
| Table 10 | Comparative costs, advantages, disadvantages and MCA Scoring for each option | 52 |
| Table 11: | Asset register (visual assessment as per site visit 16/4/19) | 58 |
| Table 12 | OHS issues, as noted during site visit 16/4/19 | 60 |
| Table 13: | Comparison of treatment processes based on treatment of contaminants | 69 |

Figure index

| | | |
|-----------|--|----|
| Figure 1 | Process flow diagram showing existing process at Bombala WTP | 15 |
| Figure 2 | Daily raw water flow to Bombala WTP, Nov-2017 to April-2019..... | 16 |
| Figure 3 | Explanation in daily raw water demand outliers, January 2013 to April 2019 | 17 |
| Figure 4 | Vulnerability versus Microbial indicator concentration category in HBT document (2018)..... | 18 |
| Figure 5 | Photo of Coolumbooka Dam from GHD site visit (16 April 2019) showing sheep grazing at edge of dam (circled) | 19 |
| Figure 6 | Approximate catchment area of Coolumbooka Dam (estimated from contour lines and location of other rivers in the region)..... | 20 |
| Figure 7 | DOC removal and THM control future WTP options | 34 |
| Figure 8 | Process flow diagram for Option 1..... | 39 |
| Figure 9 | Concept design layout for Option 1 | 40 |
| Figure 10 | 2.5 ML/d Lancefield DAFF water treatment plant main building..... | 41 |
| Figure 11 | Preferred location of new WTP for Options 2 and 3 | 41 |
| Figure 12 | Process flow diagram for Option 2: New WTP | 44 |
| Figure 13 | Concept design layout for Option 2 & 3: New WTP..... | 45 |
| Figure 14 | Process flow diagram for Option 3: New WTP | 46 |
| Figure 15 | Process flow diagram for Option 4: New WTP | 47 |
| Figure 16 | Concept design layout for Option 4 & 5: New WTP..... | 48 |
| Figure 17 | Process flow diagram for Option 5: New WTP | 49 |
| Figure 18 | Bombala Control Building Layout for Option 1 (Upgrade existing plant)..... | 67 |

Appendices

Appendix A – Existing plant asset register

Appendix B – OHS issues as noted during site visit 16/04/19

Appendix C – Water Quality Testing: Memorandum

Appendix D – Bombala Operational Monitoring Data for recent 2020 wet weather event

Appendix E - Reservoir Aeration/Mixing Systems

Appendix F – Alternative siting location considered for new WTP

Appendix G – Proposed WTP building layouts

Appendix H – Comparison of treatment processes

Appendix I – Cost comparison of PAC vs GAC

Appendix J – Comparison of DAF and Settling

Appendix K – THM Stripping System

Appendix L – THM vs DOC relationship

Appendix M — CAPEX and OPEX Estimates

Appendix N — Weir proposal correspondence

1. Introduction

1.1 Project need

GHD has been engaged by Snowy Monaro Regional Council (SMRC) to carry out an Options Assessment and Concept Design for upgrades to the water supply systems for the towns of Bombala and Delegate in southeast New South Wales. This report covers the town of Bombala.

Bombala is supplied with treated water from a conventional water treatment plant. The plant is located on Cathcart Road to the north east of the Bombala Township. The raw water is sourced from Coolumbooka Dam along Coolumbooka River, upstream of the confluence with Bombala River.

The existing Bombala and Delegate water supply systems face a number of challenges related to the reliable provision of safe, high quality drinking water to their communities. Residents of Bombala and Delegate have expressed severe dissatisfaction about water quality and in response, the NSW Government has allocated substantial funding for upgrades to the water systems servicing these towns.

To date only minor changes have occurred (e.g. new actuated valves at filters and new PLC). The plant remains a challenge to operate due to ageing assets, failed equipment and treatment processes that do not handle high raw water iron & manganese colour events or taste & odour issues adequately. Improvements are needed to achieve performance, operability and health and safety requirements.

1.2 Project scope

This report outlines the results of audit of existing assets and an Options Assessment for the future Bombala Water Treatment Plant (WTP). Specifically, the aims of this report were to:

- Review information supplied by Council, including the analysis of raw water quality data
- Assess the existing WTP, including assessment of its process performance, OH&S compliance and asset condition
- Develop upgrade options, including advantages, disadvantages and cost estimates
- Recommend a preferred upgrade option.

1.3 Purpose of report

The purpose of this report is to develop upgrade options for Bombala WTP and recommend a preferred upgrade option to SMRC.

1.4 Scope and limitations

As part of this Options Assessment, GHD advised Council to undertake a water quality sampling and analysis program. Results from this testing program have been used in this report in order to assess the raw water quality and treatment capability of the existing water treatment plant process train.

The sampling program was of limited duration and did not cover the recent large storm event for several water quality characteristics (results are summarised in Appendix C). In order to determine an accurate raw water quality envelope to inform upgrade options for Bombala WTP, it is recommended that the water sampling program continue to better inform future design stages of this project.

Report based on sampling program and other intermittent results since 2014. Concern was raised that the recent program showed that in some respects the daily operational water quality data is of limited value as the results do not appear to match results done by ALS (NATA credited lab). Refer to Appendix C.

This report: has been prepared by GHD for Snowy Monaro Regional Council and may only be used and relied on by Snowy Monaro Regional Council for the purpose agreed between GHD and the Snowy Monaro Regional Council as set out in section 1.3 of this report.

GHD otherwise disclaims responsibility to any person other than Snowy Monaro Regional Council arising in connection with this report. GHD also excludes implied warranties and conditions, to the extent legally permissible.

The services undertaken by GHD in connection with preparing this report were limited to those specifically detailed in the report and are subject to the scope limitations set out in the report.

The opinions, conclusions and any recommendations in this report are based on conditions encountered and information reviewed at the date of preparation of the report. GHD has no responsibility or obligation to update this report to account for events or changes occurring subsequent to the date that the report was prepared...

GHD has prepared this report on the basis of information provided by Snowy Monaro Regional Council and others who provided information to GHD (including Government authorities)], which GHD has not independently verified or checked beyond the agreed scope of work. GHD does not accept liability in connection with such unverified information, including errors and omissions in the report which were caused by errors or omissions in that information.

GHD has prepared the preliminary cost estimate set out in section 6 of this report using information reasonably available to the GHD employee(s) who prepared this report; and based on assumptions and judgments made by GHD.

The Cost Estimate has been prepared for the purpose of comparison of options and must not be used for any other purpose.

The Cost Estimate is a preliminary estimate only. Actual prices, costs and other variables may be different to those used to prepare the Cost Estimate and may change. Unless as otherwise specified in this report, no detailed quotation has been obtained for actions identified in this report. GHD does not represent, warrant or guarantee that the works can or will be undertaken at a cost which is the same or less than the Cost Estimate.

Where estimates of potential costs are provided with an indicated level of confidence, notwithstanding the conservatism of the level of confidence selected as the planning level, there remains a chance that the cost will be greater than the planning estimate, and any funding would not be adequate. The confidence level considered to be most appropriate for planning purposes will vary depending on the conservatism of the user and the nature of the project. The user should therefore select appropriate confidence levels to suit their particular risk profile.

1.5 Assumptions

The opinions, conclusions and any recommendations in this report are based on assumptions made by GHD described in this section of this report). GHD disclaims liability arising from any of the assumptions being incorrect.

The assumptions for this report are

- Plant drawings, provided by Council represent as constructed details
- Demand data and future growth rate projections and water quality data provided by Council are reasonable representation of history and the future for this site

- Observed movement of the filter block (i.e. widening crack in brickwork between clarifier and filter) is not to the extent that the existing plant is unsafe and cannot be fixed. No detailed structural analysis to confirm the extent of damage and required repairs and cost has been provided by Council. GHD has assumed a cost up to \$100,000 in comparison of options
- The option of upgrade of the existing WTP (Option 1) is assumed to require this WTP to be offline for extended periods. Extended shutdown is needed for works including at the existing clarifier (eg cleaning, repairs/recoating/modification for sludge blanket/tube-settler), new filter inlet works and control building (eg electrics and new chemical dosing system). That is, the combination of unprotected catchment Cat 4 rating for microbiological health risk combined with evidence of periods of difficult to coagulate source water especially during wet weather events means bypassing the clarifier for direct flow of coagulated water to the filters is considered too high a risk. Allowance has been made for trucking in drinking water at 0.5 ML/day to the Clear Water Storage for a total of at least 30 days (note that it could easily be longer), spread through a low demand months. This trucking in of drinking water requirement is not required for the new WTP options 2, 3 or 4. They can be constructed while the existing plant continues to operate and then cut-over into operation within a day or so.

Cost of water cartage for the Brogo WTP upgrade amounted to \$33,000/ML. Similar pricing was advised by a supplier in Cooma for water cartage between Cooma to Bombala (approx. 90km). This translates to about \$0.5 million for 30 days of cartage of water to Bombala WTP for this Option 1.

2. Performance Objectives

2.1 Introduction

This section outlines water supply performance objectives, used to assess the existing Bombala WTP and develop upgrade options.

The overall water supply performance objectives for the Bombala WTP are (in general terms):

- Meet current and future water demand
- Meet treated water quality requirements
- Achieve asset life, environmental and OH&S requirements and reliable operation targets
- Minimise whole-of-life cost

These are further developed below.

2.2 Water Demand and WTP design capacity

The water quantity performance objective is to provide adequate WTP capacity to meet current and future peak day demands for all raw water quality scenarios. The water demand projection needs to cover both Peak Day and Annual Demand for the planning horizon of 25 years.

2.3 Treated Water Quality Requirements

The key guidance documents for drinking water quality are:

- Australian Drinking Water Quality Guidelines (ADWG)
- Health Based Targets (HBT) framework for Raw Water Quality conditions

The ADWG provides water quality limits measured at customer taps.

Table 1 sets out the normal treated water quality requirements that the upstream Water Treatment Plant (WTP) needs to be designed for to achieve the requirements of ADWG and HBT.

Table 1 Treated water quality targets

| Parameter | Units | ADWG or “Good Practise” Target | Monitoring Location |
|-----------------------------|--------------|--|--|
| E. Coli | org / 100 mL | Not detected | Clear Water Storage (CWS) |
| pH | | Set point* \pm 0.2 | CWS |
| Filtered turbidity | NTU | <0.2 @95%, max \leq 0.5 | Combined Filter outlet |
| True Colour | Hazen | <5 @95%, max \leq 10 | CWS |
| Dissolved Organic Carbon | mg/L | <6 mg/L | CWT to achieve THM requirement |
| Aluminium | mg/L | <0.1 @ 95%, max \leq 0.2 | CWS |
| Iron, total | mg/L | <0.1 @ 95%. max \leq 0.3 | CWS |
| Manganese, total | mg/L | <0.02 @ 95%. max \leq 0.05 | CWS |
| THMs | mg/L | Max <0.25 | Reticulation Network |
| Taste & Odour | | | For good T&O at customer taps |
| - Geosmin | ng/ L | <5 | |
| - MIB | ng/L | <5 | |
| Chlorine Residual (FCR) | mg/L | Set point* \pm 0.2 | CT>15mg/L-min for free chlorine leaving Res1 |
| Fluoride | mg/L | Set point \pm 0.1 | At CWS |
| Treated Water Stabilisation | | | At CWS |
| CCPP | mg/L | -4 to 0 | |
| LSI | | -1 to 0 | |
| Health Based Targets (HBT) | | LRVs for category 4 unprotected catchment | |

* Set point for pH normally =7.5 to 7.8. Set point for FCR = 1 to 2 mg/L.

2.3.1 Health Based Targets (HBTs)

The National Health and Medical Research Council (NHMRC) current draft of the Health Based Targets (HBT) document (2018), sets out required Log Reduction Value (LRV) for pathogens based on various Source Water Categories. The HBT document defines what LRVs can be achieved by various treatment processes. Refer *Manual for Application of Health-Based Treated Targets, WSAA (2005)*.

2.4 Asset condition, environmental/OH&S requirements and reliable operation

2.4.1 Asset Life

Asset life decisions need to include consideration of:

- Future development; for example impact of increased peak day and annual demand
- Innovation; for example SCADA hardware and control software continue to reduce in cost; increase in capacity/capability and to have limited support life.
- Design and maintenance/planned replacement; for example correct materials of construction, cathodic protection systems, timely replacement of old assets and allowance/prevention of settlement of structures are essential for achieving design asset life.

2.4.2 Reliable Operation

It is required that each treatment system is “fit for purpose” in terms of minimum dependence on proprietary equipment, easy to operate and perform well under design raw water conditions and have adequate asset life.

Reliability in operation needs to be in accordance with good industry practice, for example:

- Automation: Adequate online monitoring equipment, alarms and telemetry to allow automatic response to process or equipment failure and efficient operation.
- Reliability: Duty/standby with automatic standby unit start-up upon fault of the duty unit, for process critical equipment.
- OH&S: Minimisation of manual handling, automation of processes.
- Storage: Sufficient balancing storages to minimise start/stop operation and pressure surge risks, and sufficient bulk storage of treatment chemicals.

2.4.3 Contingency Management

Contingency management is required to ensure continuous treated water supply to customers by considering risks and actions to minimise to “acceptable” including:

- Unexpected equipment failure and associated redundancy
- Local or regional power failure
- Poor raw water quality events

2.4.4 Legislative compliance

Regulations

The WTP must comply with statutory requirements including:

- Chemical storage and handling – Dangerous Goods regulations including the Dangerous Goods Act (DGA)
- Occupational health and safety (OH&S) requirements

Environmental management

Environmental considerations for operation of the WTP include:

- Compliance with waste disposal and noise requirements (EPA)

- Minimisation of energy consumption
- Sludge disposal including backwash supernatant recovery – EPA requirements

2.4.5 Whole of Life Cost

The capital cost together with operating and maintenance costs, needs to be minimised over the adopted planning horizon.

3. Review of Existing Bombala System

3.1 Overview of Existing System

3.1.1 General System Description

Bombala's water is supplied from a dam on the Coolumbooka River. The resulting reservoir has a capacity of 300 ML, which is estimated to be reduced to approximately 250 ML due to siltation (Bombala Urban Water Plan, 2000). After the dam, Coolumbooka River merges with Bombala River just upstream of where it flows through Bombala Township.

The treatment process currently uses a conventional reactivator type clarifier then gravity filtration process to treat raw water, with soda ash, ACH, polymer and chlorine dosing.

The majority of Bombala township is either gravity-fed from Reservoir 1 (450 kL), located at a high point on site at the WTP, or Reservoir 2 (1,900 kL), located on the other side of the valley within which Bombala township is located.

A schematic of the existing treatment process at Bombala WTP is shown in Figure 1.

3.1.2 Raw Water System

Raw water is sourced from the Coolumbooka Dam and it is pumped to the WTP via a DN200 AC pipeline. If the parallel DN150 AC pipe is also in use the inflow rate to the WTP can be increased to about 40 to 45 L/s. A separate emergency pump and pipeline can also be used to deliver raw water to the WTP from Bombala River approximately 5 km downstream of the dam. This source has a licence limit of 20 ML/yr (TBC) and is typically only used in periods of very low levels in the Coolumbooka Dam.

3.1.3 Treatment Process

The raw water is pumped from the raw water pump station and dosed with chlorine (for manganese/iron oxidation) and pre-soda ash (only if ACH dose is very high) before entering a 'flash mixer' tank. In this flash mix tank ACH and LT20 polymer are added. The flash mixing occurs only due to the higher velocities in this small tank. The flocculated water then flows into a reactivator clarifier.

The draft tube mixer in the reactivator clarifier is currently turned off. Settled sludge is periodically discharged to 2 No sludge lagoons through a motorised valve, which is automatically opened for 1 minute every hour. A manual valve is also opened by operators to remove excess sludge on a daily basis.

The settled water from the clarifiers is split between 2 no. rising level multi-media gravity filters. Filter media consists of gravel overlaid by sand and then anthracite filter media. The filters currently require manual backwashing however electric actuated valves have recently been installed to permit automatic backwash in the future.

The filtered water is dosed with chlorine and post-soda ash prior to gravity flow to the Clear Water Storage tank. Treated water is pumped to Reservoir 1 at the top of the hill at the WTP site, where it is gravity fed to the town's reticulation system including the main storage, Reservoir 2.

EXISTING SYSTEM




Figure 1 Process flow diagram showing existing process at Bombala WTP

3.2 Water Demand and WTP design capacity

The existing Bombala WTP currently supplies treated water at approximately 180 ML/year. The plant typically operates between 4 to 11 hours per day (at an instantaneous rate of 25 to 30L/s), depending on demand and raw water quality conditions. Figure 2 shows a time series for daily raw water inflow to the WTP for November 2017 to March 2019. This record is considered the more reliable period of measurement compared to earlier data.




Figure 2 Daily raw water flow to Bombala WTP, Nov-2017 to April-2019

Figure 3 highlights outliers in the daily raw water flow to Bombala WTP from January 2013 to April 2019. All days where 2ML to 2.5ML of raw water was used could be explained by either:

- Lack of raw water demand data immediately before/after “peak” day (suggesting that flow was actually split between the days, but was not captured as data. The comment from Council is that readings are not taken consistently, and hence delays in readings explain these ‘peak’ days). These points are highlighted by red circles in Figure 3.
- WTP operating at well below capacity on previous days (suggesting that WTP operated for a significant number of hours on “peak” day to fill demand from previous days). These points are highlighted by green circles in Figure 3.

However, there were a number of other days when demand was up around 1.5 ML/d, which may be relatively reliable values.




Figure 3 Explanation in daily raw water demand outliers, January 2013 to April 2019

The population of Bombala township is approximately 1,400 (Australian Bureau of Statistics, 2016 Census). Population growth is minimal, and for the purposes of this option assessment a growth rate of 0.1%¹ is assumed to apply to the next 25 years. Table 2 summarises the current raw and treated water flows (based on 2017/19 data) and the projected design annual and peak day flows for this plant in 2045. These WTP design values are based on expected growth over the next 25 years of a total of 2.5% plus an uncertainty allowance (10%) to allow for dry year unrestricted demand plus some uncertainty (given that earlier less reliable data shows higher demands and that demand record available was relatively short).

Based on this design demand the upgraded or new WTP needs to have a peak day output capacity of 1.5ML/d. To allow for the fact that this is the only supply to town, power and equipment failure risk and that there is limited treated water storage design also assumes this 1.5ML output is delivered over a 22 hour period. Assuming the new plant options all have supernatant return then the only loss is only sludge at up to 0.06ML/d. Consequently, the raw water pumps need to be able to deliver up to 1.56ML/d. Adding allowance for supernatant return for daily filter backwashes plus filter to waste and reduced plant production rate during filter backwashing, means an instantaneous flow rate through the plant of 25 L/s is required. This rate has been adopted as the basis for options assessment. Options with additional treatment processes (eg more than a clarification then filtration process step) may require a higher instantaneous rate.

¹ Own in the brief water quality testing program ¹ As per SMRC estimates.

Table 2 Current and projected demand and WTP flows

| | 2017/19 Raw water | 2017/19 Treated Water | WTP Design treated water - 2045 |
|-----------------|----------------------|--------------------------|------------------------------------|
| Population | 1400 | | 1435 |
| Annual Demand | 212 ML/yr (1) | 180 ML/yr (2) | 240 ML/yr |
| Peak Day Demand | 1350 kL/d (1) | 1100 kL/d (2) | 1500 kL/d |

(1) Data for Raw Water daily flow, Nov-2017 – April 2019.

(2) Data for Clear Water daily flow, Nov-2017 – April 2019.

3.3 Water Quality Requirements

3.3.1 Health Based Targets & Log Removal Values (LRVs)

The HBTs set out required Log Reduction Value (LRV) for pathogens based on various Source Water Categories. As per the HBT guidelines (2018), “the source water category should be determined by combining the vulnerability assessment with the *E. coli* band allocated according to results of the microbial indicator assessment”.

The matrix in Figure 4 below defines how this works.

Table 5.4. Confirmed source water category based on comparison of *E. coli* concentration with vulnerability assessment

| Preliminary source water category based on vulnerability assessment | Microbial indicator concentration category Maximum <i>E. coli</i> result per 100 mL | | |
|---|--|--|--|
| | <20 (<i>E. coli</i> band 1) | 20 to 2000 (<i>E. coli</i> band 2) | 2001 to 20,000 (<i>E. coli</i> band 3) |
| Vulnerability category 1 | Category 1 (/) | Category 2 (*) | Anomalous (x) |
| Vulnerability category 2 | Category 2 (*) | Category 2 (/) | Anomalous (x) |
| Vulnerability category 3 | Anomalous (x) | Category 3 (/) | Category 4 (*) |
| Vulnerability category 4 | Anomalous (x) | Category 4 (*) | Category 4 (/) |

Combining the results of the *E. coli* data and vulnerability assessment will result in one of the following outcomes:

- / The two assessments are consistent and support each other
- * The result is feasible, but has a lower degree of confidence. Both the *E. coli* data and vulnerability assessment should be re-examined to better understand the reasons for the misalignment. For example, if the *E. coli* results indicates a higher level of microbial risk than inferred by the vulnerability assessment, then the vulnerability assessment of the catchment should be repeated to determine if there are sources of microbial risk that were not previously identified.
- X- This result should not be accepted. The results should be critically reviewed to understand the discrepancy. In the interim, the most conservative source water category option under consideration should be adopted. These results should be discussed with the relevant party (e.g. a health authority or other regulator).

Figure 4 Vulnerability versus Microbial indicator concentration category in HBT document (2018)

Vulnerability assessment

A vulnerability assessment consists of identifying sources of, and barriers to, pathogen contamination within the water supply catchment. The results from the vulnerability assessment are used to allocate the source water into one of four preliminary source water vulnerability

categories. The vulnerability assessment category is a judgement made on the basis of the outcomes of a risk assessment on the catchment part of the water supply system.

Figure 5 shows a photo of storage behind Coolumbooka Dam, which is the supply source to Bombala WTP. It has an unprotected catchment.

At the time of GHD visit to site, sheep were seen grazing near the dam (yellow circle in figure 5). This is consistent with observations of operators from Bombala WTP indicated that there are often cattle and sheep grazing along the banks of the storage.

It is noted that there is over 26 km of raw water reservoir/river frontage accessible by sheep and cattle within this catchment.



Figure 5 Photo of Coolumbooka Dam from GHD site visit (16 April 2019) showing sheep grazing at edge of dam (circled)

The approximate catchment boundary for Coolumbooka Dam is shown in Figure 6. The figure shows that the catchment area is mainly farmland, with some state or national park and small groups of residential properties.

On this basis the source water is defined as Vulnerability Category 4.




Figure 6 Approximate catchment area of Coolumbooka Dam (estimated from contour lines and location of other rivers in the region)

E.coli testing

The Health Based Targets (HBTs) concept also require that measurements to be made of E.coli concentration in the untreated water going to the WTP. E.coli results for collected data over 2019/20 are shown in:

- Table 3 results as measured each month by NSW Health in 2019.
- Table 4 results as measured by ALS laboratories during the 2019/20 water quality sampling program.

E. Coli results >20 cfu/100mL means the source water to the WTP falls into E.coli band 2 to band 3 under the HBT (refer Figure 4).

Table 3 Results for coliforms in raw water (MPN/100mL, as assessed by NSW Health)

| Date | E.coli (MPN/100mL) |
|------------|--------------------|
| 30/01/2019 | 36 |
| 19/02/2019 | 50 |
| 18/03/2019 | 66 |
| 15/04/2019 | 18 |
| 21/05/2019 | 3 |

Table 4 Results for E. Coli in raw water (MPN/100mL, as assessed by ALS)

| Date | Raw Water | Date | Raw Water |
|------------|-----------|------------|-----------|
| 28/05/2019 | 19 | 11/11/2019 | 10 |
| 27/06/2019 | 1 | 25/11/2019 | 12 |
| 24/07/2019 | 8 | 5/12/2019 | 12 |
| 30/09/2019 | 4 | 16/12/2019 | 24 |
| 8/10/2019 | 2 | 23/12/2019 | 41 |
| 14/10/2019 | 4 | 30/12/2019 | 55 |
| 21/10/2019 | 1 | 9/01/2020 | 24 |
| 31/10/2019 | 0.5 | 16/01/2020 | 13 |
| 4/11/2019 | 1 | 23/01/2020 | 36 |

In the early weeks of the ALS sampling program, the majority of E.Coli results in the raw water inlet pipe to the WTP were lower than the limit of detection in the ALS sampling program. These results suggested that there was residual chlorine in the water and therefore these were not a representative sample of the raw water. GHD notified Council of the issues with sampling from the raw water inlet pipe at the WTP, and hence results shown in the table above are E.Coli results from Coolumbooka Dam, which would not be affected by residual chlorine in this raw water pipeline.

Source Water category

The source water category is therefore determined using the table provided in Figure 4 as follows:

- Vulnerability category 4 + E.Coli band 2 to 3 = **Source water category 4.**

Bombala WTP LRVs

Table 5 shows the required Log Removal Values (LRVs) that need to be achieved to comply with the Source Category 4 under HBT. Also shown is what the existing Bombala WTP is estimated to currently achieve, when operating correctly. That is, to achieve the LRV for coagulation/clarification/filtration requires the filtered water from each filter to be <0.3NTU for 95% of the time and always <0.5NTU. However, operational testing where a sample is taken every day of the combined filtered water shows that this performance is not achieved, especially when raw water quality is poor after stormwater inflow events. This is important as it is during such stormwater events when the protozoan and other microbiological hazards will tend to be highest in the raw water. It is noted that the recent water quality testing program comparing operational data for filtered water turbidity with results from ALS (a NATA registered lab) were about the same (refer Appendix C), which validates the accuracy of the long-term operational data set for filtered water turbidity. Based on Table 5, the existing treatment process does not achieve the required Log Removal Value (LRV) for protozoa (e.g. Cryptosporidium) and is unlikely to achieve it for virus and bacteria.

Table 5 Bombala WTP Log Removal Values (LRVs) under HBT guidelines

| Process | Bacteria | Virus | Protozoa | Comment |
|--|---------------|---------------|-------------------|--|
| LRV Required | 6 | 6 | 5 to 5.5 | based on unprotected surface water source water at Category=4 |
| EXISTING PROCESS | | | | |
| Coagulation/flocculation in clarifier, followed by media filtration | <2.5 | < 1 | <2.5 | Water quality data from the WTP (refer Appendix C) shows that combined turbidity out of the filters is still high, with average 0.6 NTU so low LRV credits possible at present |
| Chlorination | 4 | 4 | 0 | Assumes CT>15mg/l-min |
| Total LRV (Existing process) | >4 | >4 | < 2.5 | Given filter performance to date it is likely the LRV = 0.5 (P) to 1(B&V) or less for existing clarifier/filters |
| Additional LRVs required to meet HBT for Category=4 catchment | 0 to 2 | 0 to 2 | 4.5 to 5.5 | |

Table 6 below summarises the performance that is achieved for each of the future treatment options discussed in section 5. For each treatment option, Protozoa controls the number of treatment barriers required.

Table 6 Log Removal Values (LRVs) for future treatment options

| Future Treatment Option | Description | Bacteria | Virus | Protozoa |
|--|--------------|------------|----------------|------------|
| 1 | Clarifier + | 1 | 1 | 0.5 |
| | Filters + | 1 | 1 | 3 |
| | UV + | 2 | 0 | 2 |
| | Chlorination | 4 | 4 | 0 |
| | Total | 8 | 6 | 5.5 |
| 2 | Clarifier + | 1 | 1 | 0.5 |
| | MF/UF + | 3 | 1-2.5 | 3 |
| | UV+ | 2 | 0 | 2 |
| | chlorination | 4 | 4 | 0 |
| | Total | 10 | 6 - 7.5 | 5.5 |
| 3 | DAF + | 1 | 1 | 1 |
| | MF/UF + | 3 | 1-2.5 | 3 |
| | UV + | 2 | 0 | 2 |
| | chlorination | 4 | 4 | 0 |
| | Total | 10 | 6 - 7.5 | 6 |
| 4 | DAF + | 1 | 1 | 1 |
| | MF/UF + | 3 | 1-2.5 | 3 |
| | Ozone + | 2 | 2 | 0 |
| | UV+ | 2 | 0 | 2 |
| | Chlorination | 4 | 4 | 0 |
| | Total | 12 | 8 - 9.5 | 6 |
| 5 | DAF + | 1 | 1 | 1 |
| | MF/UF + | 3 | 1-2.5 | 3 |
| | NF + | 1.5 | 1.5 | 1.5 |
| | Chlorination | 4 | 4 | 0 |
| | Total | 9.5 | 7.5 - 9 | 5.5 |
| Notes: | | | | |
| 1. LRV for filters assumes turbidity at 95% <0.3NTU | | | | |
| 2. LRV=4 @UV dose=22 mJ/cm ² . LRV=2 @ UV dose=5.8 mJ/cm ² | | | | |

3.3.2 Design raw water quality envelope

GHD advised Council to undertake a detailed sampling and analysis program over a number of months to determine the raw water quality envelope. A summary of all results from both the ALS laboratory data including a comparison with operational on-site water quality testing is included as Appendix C (Water Quality memo).

In addition there have been measurements taken by NSW Health. In addition the report “Bombala WTP site audit and Optimisation Report (City Water 2015)” included some very high raw water colour results for its successful jar coagulation tests with alum.

Based on this data the following design raw water quality envelop has been developed (Table 1). The main contaminants that have a bearing on “fit for purpose” treatment process selection are highlighted.

Table 7 Design raw water quality envelope

| WQ Characteristic | Estimated range | Estimated Lower(LL) and upper (UL) limits | Comment |
|--------------------------------------|-----------------|---|--|
| Turbidity (NTU) | 1 to 10 | 33 | UL in City Water report |
| True Colour (Hu) | 30 to 80 | 120 | UL in City Water report |
| Dissolved Organic Carbon (mg/L) | 5 to 25 | 35 | UL in 2019/20 data, at DOC>6 mg/L can generate THMs>0.25 mg/L. |
| pH | 7.4 to 8.1 | 6.6 and 8.9 | |
| Alkalinity (mg CaCO ₃ /L) | 90 to 110 | 35 and 150 | LL from ops 2/20 |
| Total Manganese (mg/L) | < 0.02 to 1 | 1.9 | UL in 22/1/14 |
| Total Iron (mg/L) | 0.15 to 1.2 | 1.5 | Highest 26/6/14 |
| Calcium (mgCa/L) | 12 to 15 | 10 and 20 | |
| Total Algae (cells/ml) | 300 to 3000 | 5,000 | 3220 in 25/3/14 |
| Blue Green Algae (cells/ml) | <10 to 1500 | 2000 | 1260 in 22/1/14 |
| MIB (ng/L) | 2 to 10 | <2 and 25 | UL in 2019/20 data |
| Geosmin (ng/L) | 10 to 35 | <2 and 65 | UL in 2019/20 data |
| E.Coli (CFU/100mL) | <1 to 110 | ? | highest 26/6/14 |
| Water Temp (°C) | 6 to 23 | 4 and 25 | Operations data and can vary 2°C in a day |
| TDS (mg/l) | 90 to 130 | 50 to 200 | |

3.1 Asset condition, environmental/OH&S requirements and reliable operation

3.1.1 Asset condition

Since engaging GHD, it is understood Council has arranged for a structural engineer to undertake a condition assessment on some of the ageing building infrastructure. Results are yet to be sent to GHD.

The condition of the assets was assessed at a site visit attended by GHD staff on 16/4/19. It included a brief structural assessment (visual only). Details of findings of this assessment of structures and equipment is included in the asset register, including asset age, in Appendix A. Generally this plant, constructed in 1981, has mechanical, instrumentation and control systems that are at end of life or in need of upgrade to a modern “good water Industry” standard.

Table 8 summarises key findings of the audit.

Table 8 Asset condition/capacity summary for existing WTP

| WTP area | Comment |
|---|---|
| Raw Water Pump Station | Pumps need replacements and VSD control. Minimal telemetry back to WTP. Most electrical cabling requires replacement. |
| Inlet Works | Jet mixer does not function as intended as ACH and polymer are added at the same location rather than separated by at least 20 to 30 second |
| Coagulation | Dosing system recently replaced and auto duty/standby |
| Clarifier | Clarifier roof low, not sufficient headroom. Clarifier internals require replacement and repainting. |
| Filters | Brick wall connecting filter block to clarifier has large vertical cracks indicating the filters may be moving down the hillside. |
| Media valves and pipework | Recent replacement of filter media and valves with motorised valves but very confined space for O&M. |
| Chemical storage, dosing systems and dosing lines | Dosing lines in trays not accessible, Soda and polymer systems very old and manual and poor OHS setup. No duty/standby automatic operation. Old poor WH&S fluoridation system that does not operate |
| OHS and Environmental | Not enough and poor arrangement for safety showers, access to valves and chemical system, leaking Coag bund, no chem delivery bund |
| Air scour and water backwash systems | Old air scour, only 1 or 2 units available. Backwash water system needs new controls for more reliable gravity backwash |
| SCADA, PLC, Telemetry & Controls | Operator Interface Screens are basic and have minimal remote operation or data collection from existing online analysers. Plant has no: <ul style="list-style-type: none"> - duty/standby with auto changeover and flow pace plus trim for coagulation pH and chlorination, - automation of filter backwash - constant level filtration, ability to run 1 filter when other is backwashing and filter to waste - auto batching and duty/standby dosing with auto changeover for soda ash and poly |
| Instrumentation | No online settled water turbidity, individual filter turbidity, coagulation pH analysers |
| Sludge | May need sludge pond re-lining and works to prevent wash water overflow to environment |
| Other | Roof over clarifier/filter area too low for good OHS |

3.1.1 Treatment process capability, performance & reliability

Flow performance and capacity

The operating rate of the WTP is currently set at 25 to 30 L/s. The plant therefore operates for approximately 6 to 12 hours per day during large periods of the year.

However, there is no ability to automatically adjust flow rate of the raw water pumps. Also the plant has to stop for filter backwash as there is no valving to allow one filter at a time to be backwashed.

There is no online monitoring of the following flows; service water, filtered water flow to the CWS, sludge output or treated water flow to Res 1.

Treatment performance

To better understand treatment performance and to assess the accuracy of operational data collected daily at the WTP, a detailed sampling program measuring raw, settled, filtered water and treated water was implemented over late 2019/early 2020. Data analysis and comparison with Plant Operational data is set out in Appendix C.

In addition a review was completed of

- 2014/19 water quality data collected by Council,
- DPI-Water and NSW Health
- Jar test work by City Water
- Plant Operational records 2018/20 for water quality and chemical dosing
- Observations at GHD site visit.

The main findings from this assessment are;

Table 9 Treated water quality performance

| Parameter | Benchmark for assessment: ADWG and "Good Practise" Targets | Existing plant historical performance |
|---|--|--|
| E. Coli | Not detected | Council documents indicate some E.coli detections in treated water |
| Treated water pH | Set point* ± 0.2 | No history of online monitoring at SCADA available. Only post pH correction occurred and observed a wide range in final pH =7.4 to 8.2 |
| Combined Filtered turbidity | <0.2NTU @95%, max ≤ 0.5 NTU | No history of online monitoring at SCADA available. Not achieved in most results, mainly due to poor performance of both coagulation using ACH after storm events with high colour/variable alkalinity and clarifier |
| True Colour and Dissolved Organic Carbon(DOC) | Colour <5 @95%, max ≤ 10 DOC <6 mg/L | Targets not achieved especially during high raw water colour /DOC storm related period, probably mainly due to use of Alchor (ie. ACH) instead of alum coagulant as ACH not great for high colour conditions as very |

| Parameter | Benchmark for assessment: ADWG and "Good Practise" Targets | Existing plant historical performance |
|--|--|---|
| | | high doses needed to get to optimum coagulation pH of <6.5 |
| Aluminium | < 0.1mg/L @ 95%, max ≤0.2mg/L | Levels up to 1.9mg/L have been measured by ALS in treated water , consistent with poor coagulation performance |
| Iron, total | <0.1mg/L @ 95%. max ≤0.15mg/L | Generally achieves targets |
| Manganese, total | <0.02 @ 95%. max ≤0.05 | Levels in raw water up to 1.9mg/L and treated water levels up to |
| THMs (ADWG Health limit) | Max <0.25mg/L | Very high prechlorine (5 to 6mg/l) and post chlorine (4 to 5 mg/L) doses plus high DOC result in several exceedances of ADWG health limit at Res 1& 2 and in retic, especially over summer |
| Taste & Odour - Geosmin - MIB | <5ng/L <5ng/L | Exceeded in most samples. Noted that MIB/Geosmin often increased through the plant |
| Chlorine Residual (FCR) | Set point* ± 0.2mg/L CT>15mg/L-min | Chlorine has poor control and residual at CWS outlet varies 0.1 to 2 mg/L |
| Fluoride (F) | Set point ± 0.1 mg/L | Existing fluoride system is not operational, well beyond asset life and a significant WH&S risk if restarted in current arrangement |
| Treated Water Stabilisation CCPP LSI | -4 to 0 -1 to 0 | Data shows generally achieved provided treated water pH >7.5 |
| Health Based Targets (HBT) | LRVs for category 4 unprotected catchment | Does not always achieve nominal targets - settled water turbidity < 2NTU and/or - filtered water turbidity <0.2NTU Needed to achieve LRV credit for clarification/filtration process |

* Set point for pH normally =7.5 to 7.8. Set point for FCR = 1 to 2 mg/L.

It is noted that it is unlikely the operation of the existing clarifier/gravity filter process is adequate to achieve the LRV credit value assigned to this process. That is, the existing process;

- Operates a reactivator clarifier (at rise rate of 1.6m/hr) and if the mixer is running it can break up fragile colour based flocc. It is not a normal treatment technology for high colour and DOC water with low alkalinity (reference: Water Quality and Treatment AWWA 5th Ed, page 7.41). If a clarification process is used under these conditions AWWA recommends flocc –blanket clarification operating at as low as 1 m/hr rise rate
- lacks normal on-line turbidity analyser for each filter,

- has no differential pressure sensor at each filter or automated filter to waste system,
- Has minimal automatic control/SCADA to respond to failure/poor performance.

Performance during the recent storm event over February 2020 highlights the relatively poor performance (refer Appendix D). During this “storm event” period the following occurred;

Raw water

- Apparent colour increased from around 1-2 Hu to 120-140 Hu
- Turbidity rose from a range 2-3 NTU to a range 3.5- 7 NTU with short peak to 19 NTU
- Alkalinity dropped from 130-150 mg/L down to 42 to 80 mg/L

Treated Water in the Clear Water Res 1

- Apparent colour increased from around <1 Hu to as high as 43 Hu
- Turbidity rose from a range <0.1-0.99 NTU to a range 0.4-2.2 NTU
- Chlorine residual drop from range 1 to 2 mg/l down to range 0.1 to 1.5 mg/L

High aluminium level in the treated water also indicates failure of either the filters or the coagulation/sedimentation process to achieve LRV.

Data analysis by ALS has been infrequent but was as follows;

- 1.74mg/L (6 June 2016) and 0.9mg/L (2 Nov 2016).
- DPI-Water noted in correspondence (18 Nov 2016) that “aluminium residuals were again above ADWG”.

3.1.2 Legislative compliance

Compliance with EPA, OHS and WHS regulations

Current chemicals and fluoridation area would not comply with modern OHS requirements due mainly to inadequate space and manual handling (soda ash) and poor location of safety equipment.

Chemical storage and handling

The main issue is:

- Chlorguard systems are not installed in the chlorination room; risk of Chlorine gas leak
- Coagulant Bund is understood to leak
- It is considered good practice to have a chemical delivery bund for liquid chemicals such as Alum and Alchlor
- Potential for overflow and leakage to groundwater from the old sludge ponds

Occupational health and safety (OH&S) requirements

The Condition assessment sets out details, and the main issues include:

- Manual handling of chemical deliveries and dosing is no longer standard practise;
- Trip hazards and constrained spaces throughout plant, particularly under the clarifier/filter block, do not comply with OHS regulations
- Safety shower not standard design (only bathroom-style showerhead) and not enough of them, e.g. should have one at the chlorine room

4. Investigation of Alternative Water Sources

As an extension of the original scope of the project, Council requested GHD to review possible alternative water sources for providing a reliable supply to Bombala.

4.1 Groundwater Investigation

GHD advised Council to undertake a field drilling investigation program to investigate the quality and bore yield potential of the groundwater resources in the vicinity of the townships of Delegate and Bombala.

A groundwater investigation drilling program was therefore undertaken at the townships of Bombala and Delegate. The objective of this drilling program was to investigate potential groundwater resources in close proximity to the current water reticulation infrastructure at both townships.

Two pilot investigation bores were drilled in each town. At Bombala, drilling initially focussed on the shallow alluvial aquifer, followed by the deeper fractured basement rock aquifer. At Delegate, the drilling focussed on the fractured basement rock aquifer.

Based on the work completed the alluvial sediments adjacent to the Bombala River were found to be thin (i.e. <7 m) and clay rich, with no significant inflows recorded. Subsequently, bore BBH2 was continued into the basement rock aquifer system to a depth of 109 m. Although salinity was suitable for potable use, at around 150 mg/L TDS, the pilot bore yield was only in the order of 0.7 L/sec.

Based on these results, there was insufficient yield for ground water to be a reliable future source of supply or to warrant the construction of any test bores or any further groundwater investigations.

The Groundwater Investigation Report has been issued to SMRC separately to this report.

4.2 Weir across Bombala River

Council has previously given some consideration to a scheme to erect a weir across the Bombala River located between the extensions of Caveat Street and Young Street. This progressed to a formal planning proposal in 2017 and was discussed at Council's meeting in February 2020.

The weir proposal intends to raise the standing water level in the Bombala River through the town by up to approximately 1.5 metres, (as described in Envirokey 2016 Terrestrial and Aquatic Biodiversity Assessment) backing up the water level when full as far as the Coolumbooka Weir.

The planning proposal requires rezoning the land to make the construction of the weir permissible under planning controls. It was referred to various State Government agencies in 2017. Responses received are provided in Appendix N to this report. The responses raise various concerns and specific requirements for the proposal.

The response from DPI Fisheries advises that "The Department would require a high quality fishway to be included in the design of the weir in accordance with section 218 of the FM Act." The provision of a fishway across the weir would significantly reduce the capacity of the weir to retain high water levels in periods of low inflows along the river.

Council is shortly to commence an Integrated Water Cycle Management Strategy for Bombala which can review this weir proposal in the context of managing stormwater from the town and river water quality implications.

Whatever other benefits may accrue from the proposed weir, it is not considered to provide a reliable alternative water supply for the Bombala potable water system.

4.2.1 Water quality concerns

- Most of the stormwater runoff from the town will flow into the proposed weir. This stormwater carries with it various pollutant loads including sediment, nutrients, grass clippings, animal wastes, resulting in variable quality in the water flowing into the weir. This will cause some contamination of the water in the weir in every rainfall event. There is also the risk of fuel and chemical contamination from traffic accidents and spills into the stormwater system.
- The sewerage system in Bombala comprises mostly old vitrified clay pipes. There are sewage pump stations in the immediate catchment of the weir. Stormwater and groundwater inflows and infiltration into sewerage systems in periods of wet weather generate peak flows in sewerage systems. Any overflows of sewage from this system due to blockages or extended power outages have potential to spill into the weir. While overflows should be infrequent, there is a direct risk of contaminating the water in the weir, making the water unsuitable for treatment as the potable water supply. Potential sewage contamination of town water supplies is not acceptable.
- GHD understands that there has been no long-term monitoring of water quality in Bombala River at the site of the proposed weir to allow any assessment of the suitability of this water as a raw water source for the proposed Water Treatment Plant.

The water quality data informs the choice of treatment process adopted in the Water Treatment Plant.

4.2.2 Reliability of supply concerns

- GHD is not aware of water balance calculations of inflows relative to water extraction, evaporation and seepage losses. In extended drought periods, it would be expected that the storage would be drawn down and not provide a reliable source of raw water to the treatment plant.
- The concept design drawings prepared in 2016 for the weir propose a maximum depth of water of approximately 4 metres, only in the narrow channel immediately adjacent to the dam, before allowing for any accumulation of sediment. The bulk of the impounded water would be much shallower than this. Shallow water storages lose significant amounts through evaporation losses.
- The fishway requirement as advised by DPI Fisheries would require a continuous release of water into the river downstream, contributing to an ongoing drawdown of the weir in dry periods.
- The potential size of the weir is too small to replace the existing main supply source at Coolumbooka Weir. At best, the proposed weir could only provide supplementary quantities of raw water at times of higher flows in the river, when inflows into Coolumbooka Weir would make this supplementary supply unnecessary. At times of low flow into Coolumbooka Weir, the flows in Bombala River will also be low, reducing both the quantity and quality of water that could be sourced from the proposed weir.

4.2.3 Approvals

- In view of the significant risk of contamination of the weir from stormwater and sewage overflows, it is unlikely that the NSW Government would give approval for sourcing water from the proposed weir, when the existing Coolumbooka Weir would provide an established source of raw water for the proposed Water Treatment Plant.
- The proposed weir cannot proceed without the prior rezoning of the site to permit this land-use. The communications provided in Appendix N indicate that the NSW Government requires further justification before considering the weir proposal.

4.2.4 Other concerns

- The proposed weir would exacerbate flooding of central Bombala. The current modelling of flood impacts without the weir shows flooding extending beyond Maybe Street and Mahratta Street. The weir would raise flood levels. The flood impact of the proposed weir would have to be modelled as part of the approval processes.
- The Bombala River is recognised as platypus habitat. Changes to this habitat would face detailed scrutiny by NSW Government before any approval could be granted.
- The cost of constructing the proposed weir, fishway and raw water intake pump station and rising main to the treatment plant site would add significant cost to the Water treatment Plant project.

In summary, the proposed weir in Bombala River in the town cannot provide a viable secure water source to the Water Treatment Plant.

The weir proposal could be considered by Council under the separate Integrated Water Cycle Management Strategy, if the various concerns can be addressed and if necessary approvals can be obtained. The weir proposal is not required or viable for supplying town water to Bombala.

5. Options for future Water Treatment

5.1 Development of suitable Water treatment process trains

5.1.1 Treatment challenges

The key treatment challenges associated with the raw water source for Bombala WTP are;

- Achieve Log Removal Values (LRVs) for bacteria, virus and protozoans based on Source Water Category=4 under Health Based Targets
- High levels of soluble iron, manganese and DOC
- Continuous medium level of Geosmin and occasional events of MIB related taste and odour
- Relatively soft and variable pH/alkalinity water during higher microorganism risk periods of storm events
- Single WTP for Bombala township which has a limited usable treated water storage capacity (ie. one peak day demand)
- Cold (down to 4°C) and variable water temperature conditions
- High levels of THM forming organics

The WTP also needs to achieve the following design requirements;

- “Fit for Purpose” treatment barriers to achieve treated water targets based on the raw water quality envelope and HBT for the unprotected catchment conditions
- Sized for net treated water production of 1.5 ML/d
- Achieve asset life, environmental and OH&S requirements and reliable operation objectives (e.g. adequate automatic, duty/standby for critical equipment)

5.1.2 Treatment process options

A brief survey of available treatment technologies was completed and is summarised in Appendix H.

The preferred processes, based on the design raw water quality envelope and the treated water targets are highlighted in Appendix H. The discussion regarding the alternatives of a Dissolved Air Flootation (DAF) or suitable settling process are outlined in Appendix J.

Due to site constraints, and the need to remove mainly colour/organics in low turbidity and variable pH/alkalinity/water temperature conditions, the preferred settling process is lamella plate clarifier as an option to DAF. The CAPEX for these processes is much the same for small plants such as Bombala WTP.

Other important decisions on process are discussed below for MIB/Geosmin removal and for organics removal to keep THM levels acceptable.

5.1.3 MIB and Geosmin removal

The main processes for removal of odour from MIB and Geosmin are;

- Powdered Activated carbon (PAC); for this site the expected dose would average about 15mg/l and at time get to 30mg/L
- Granulated Activated Carbon (GAC) ; for this site the detention time in the GAC filter , or the Empty Bed Contact Time (EBCT) should be 15 minutes

A comparison of costs for the above design basis (refer Appendix I) indicates the GAC approach is preferred as the estimated NPCs, within the accuracy of the estimates, are about the same. However, the PAC has the significant disadvantage of being a difficult material to handle and batch up for dosing and equipment has a relatively high maintenance cost.

Consequently GAC is recommended for this site.

5.1.4 Organics and THM removal

A key challenge for this surface water supply for Bombala is the relatively high level of Dissolved Organic Carbon (DOC) that can arise in the raw water. The 2019/20 water quality testing program (Appendix C) shows the DOC can be up to 24 to 34mg/L and most of the time is around 6 to 15 mg/L. The 2018/20 operating history of relatively high chlorine dose at this plant, up around 8 to 10 mg/L, needed to achieve a treated water chlorine level of 1 to 2mg/L confirms that this high DOC level is present most of the time.

When the plant is operating well the existing coagulation/clarification/filtration process achieves about 45 to 50% removal of the DOC, which is in line with what is expected based on GHD experience elsewhere.

Results from Bombala WTP and experience at other plants with high DOC and THM levels, e.g. Rosslynne WTP and Aires Inlet WTP in Victoria and Morgan WTP in SA, indicate that if DOC is <5 to 6mg/L prior to chlorination then THM levels in the downstream treated water network do not exceed the ADWG health limit of 0.25mg/L. A correlation between THMs and DOC is included in Appendix L.

It is also well known that dosing of ammonia and chlorine to create mono-chloramine for chloramination based disinfection will stop the THM formation reaction. However, chloramine is a weak disinfectant, especially for virus. Consequently, for this unprotected source waters with a HBT category 4 classification, it is recommended that if chloramination is adopted, then chlorine should be added first prior to the existing CWS and then after the CWS add ammonia to create the chloramine residual in the water going to the customers in Bombala.

Finally, THMs can be stripped out of water using surface mounted aeration systems, such as the PAX system (refer Appendix K). GHD have recently commissioned this type of system at Rosslynne WTP in its 10ML treated water tank. The technology has been rigorously tested to confirm that the >30 to 35% THM removal found in jar test work at this site, occurred in the full scale system.

Based on the above a number of process design options for DOC removal and THM control were developed and are summarised below (Figure 7) in terms of concept and expected performance.




Figure 7 DOC removal and THM control future WTP options

5.1.5 Chlorination and chloramination

Primary disinfection for bacteria and virus would be by chlorination with the required detention time to achieve CT >15mg/l-min occurring in the existing Clear water Storage (CWS). In addition for Options 1 to 3, where organics removal is limited it is proposed to also then add ammonia to create a mon-chloramine residual for achieving long-term disinfection residual in the reticulation system and also to quench additional THM formation in the treated water. For options 4 and 5 there will be extra organics removal and it is considered that the chloramination step is not needed.

Council have requested chlorine dosing be from duty/standby 920kg drums and this would be accommodated in a separate purpose built building.

Aqueous ammonia would be used for dosing of ammonia.

5.1.6 Summary of Future Treatment Process Options

Based on the above assessments it was determined that suitable alternative treatment process trains for treatment of this raw water are;

- **Option 1:** Raw water aeration/mixing/oxidation + modify clarifier + retain and upgrade existing filters + GAC + UV +Chlorination then chloramination
- **Option 2:** Raw water aeration/mixing/oxidation + Lamella Plate Clarifier + MF +GAC + UV+ chlorination then Chloramination + THM stripping
- **Option 3:** Raw water aeration/mixing/oxidation + DAF + MF + GAC + UV+ chlorination then Chloramination + THM stripping
- **Option 4:** Raw water aeration/mixing/oxidation + DAF + MF + Ozone/GAC + UV+ Chlorination + THM stripping
- **Option 5:** Raw water aeration/mixing/oxidation + DAF + MF + NF + Chlorination

5.1.7 Fluoridation

Fluoridation is not a raw water treatment issue. It is recommended for this small size plant, that a sodium fluoride system be adopted using 2.5kg jar feed arrangement to a saturator in a suitable package system. The service water for this system would have to be softened. The fluoridation system would be located in a separate purpose built building in all options.

5.2 Option 1: Upgrade and Retain exiting treatment plant buildings/structures

As noted previously the existing Reactivator clarifier is not considered the best option for this high colour/DOC and relatively soft water supply, especially during wet weather events. However, conversion to a flocc-blanket type process and addition of tube settler pack should provide adequate performance.

The dual media filters are a reasonable process as they are dual media but it is not certain whether they have sufficient dual filter media to achieve an L/d ratio >1000. However, the filtration rate is good at <10m/hr at the design flow set at 25 L/s.

As noted in the condition assessment there also needs to be considerable work on improving automation, replacing some chemical systems and electrical systems and generally improving operability and OHS features.

There is also a need to improve the raw water quality by minimising manganese and iron leaching from the bottom of the stratified Coolumbooka Dam (refer to water quality memo in Appendix C).

The other main issue is to achieve good chlorine based disinfection without creating treated water that exceeds ADWG health based limit for THMs.

With these observations in mind the following new works are proposed for this option;

Coolumbooka Dam

- Install bottom mounted mixing/aeration system in Coolumbooka Dam next to the dam wall. A 15 kW air compressor would be installed in the existing emergency Bombala river relift pump station at the site (refer Appendix E for details of this concept). This system would operate on a 24hr/7day time clock to keep the dam destratified in terms of water temperature and Dissolved Oxygen (DO). The reference paper in Appendix E shows this treatment process is quite effective in minimising level of soluble iron and manganese in the raw water. Also, this process should reduce observed MIB/Geosmin as the water quality measurements over 2019/2020 show it is present in stagnant bottom water (refer Water Quality memo in Appendix C).

Raw Water Pump Station

This pump station is well past its asset life and does not have ability to automatically vary flowrate. The following works are proposed;

- new raw water pumps and VSD
- Telemetry from RW pumps back to WTP
- New Raw Water pump station building, including removable roof and/or monorail beam and hoist.
- New switchboard and electrical cabling
- New sump pump to achieve duty/standby for this dry well

Oxidation of manganese and iron

It is expected there will still be a need to oxidise residual soluble manganese (PP) at the plant and it is proposed to dose potassium permanganate to achieve this objective. It may require at times a low dose of prechlorine as well, but high dose rate of prechlorine would be avoided to maintain low THM production. A new mixed 5 minute detention time oxidation tank is required with pre soda ash dosing (when needed) to achieve pH >7.5 in this tank. New pH and ORP analysers would monitor and trim doses of pre-soda ash and PP/prechlorine when required.

Clarifier/filter area:

- new roof at clarifier to provide OHS standard headroom
- new clarifier internals and scraper to achieve floc-blanket arrangement and repainting plus install tube settler pack at top of clarifier

Filters:

- Complete structural assessment and stabilisation of filter block concrete structure
- controls to allow each filter to be automatically sequenced through drain down/air scour/water backwash/refilling/filter to waste at correct rates
- New filter backwash flow meter and better flow control valve (Duty +standby)

- New filter to waste pipework, actuated valve and turbidimeter.
- Constant level control to replace existing rising head operation

Disinfection:

- Install UV to achieve 4 log removal for protozoans
- Separate building for new duty/standby automatic chlorinators, eductors, service water pumps and gas cylinders on load cells and with chlorguard units and compliant mechanical/natural ventilation system booster pumps

GAC

- Install GAC filters supplied with filtered water from the existing filters prior to entry to the existing Clear Water Storage (CWS). Design would be for EBCT=15 minutes and filtration rate <15m/hr plus downstream filtered water tank and duty/standby relift pumps and pipework back into the existing CWS. The relift pumps would also enable backwashing of the GAC filters.

THMs Stripping

- Install PAX type THMs stripping in Res 1 (Appendix K). GHD has recently completed commissioning of this type of system in a 10ML tank and the PAX system achieved 35% THM removal. It is a relatively low cost and low power consumption approach to remove THMs. It involves installing a surface aeration and bottom mixer system within the tank and a blower on the top of the tank to force ventilate the tank to blow away stripped THM compounds.

Chemical systems:

- new automated soda ash and polymer batching and dosing systems and reorganisation of the existing chemical /control building (refer Appendix G)
- conversion to alum coagulant dosing as it is more effective for DOC removal and produces a better settling floc and also construction of a delivery bund and road upgrade for coagulant deliveries
- new pre-soda ash dosing with controls to achieve flow pace plus trim to coagulant pH set point
- add ammonia dosing and controls and a total chlorine residual analyse for control of chloramination type secondary disinfection after primary chlorination to CT>15mg/L-min target
- chlorine dosing from a new separate fit for purpose building
- sodium fluoride dosing from a new separate fit for purpose building
- new more accessible dosing lines in trays at plant

Washwater and sludge

The existing sludge pond needs to have reduced flows of dilute wash water to them to enable sludge to be dried out for disposal to landfill. Also at present about 15% of inflow to the plant is lost in backwash/sludge water requiring excessive raw water pumping from a yield constrained source. In response the following is proposed;

- wash water tank with mixer and pumps on VSD and pipe with mag-flow meter to transfer filter wash water and clarifier sludge to a thickener

- Coagulant and/or Polymer dosing system and thickener and pipework to a supernatant tank and sludge pipe to existing sludge ponds
- supernatant tank and pumps on VSD and pipeline to return supernatant at controlled rate, nominally 5% of plant inflow rate back into the raw water main feeding the plant prior to where coagulant is added

Other works

- removal of old house at site to allow construction of GAC filters and balance tank and relift pumps
- repairs to concrete work in existing chemical areas and bunds
- Removal of old soda ash and polymer batching and dosing systems from chemical dosing / Office building
- New lined separate buildings for Chlorine and Fluoride and sequential reorganisation of existing Chemical dosing / Office building (refer Appendix G) to achieve construction of new chemical systems, analyser racks and electrical and control equipment (in old fluoride room) while existing plant operates. The objective is to minimise expensive plant shutdown for construction and commissioning new works.
- new Air scour blowers on VSD in enlarged blower room
- upgrade SCADA to achieve full automatic control, collection and use of historical performance data from online analysers and provide suitable Operator interface screens for remote monitoring and operation
- additional online analysers for raw water turbidity and pH , settled water turbidity, filter to waste turbidity, coagulation pH, treated water pH, final water total chlorine and pH
- Additional safety showers at chemical areas.

Temporary water supply during upgrade

In order to complete these upgrades, tankering water is assumed to be required to allow for the time that the existing plant is offline (e.g. to complete the upgrade work at the existing).

Cost of water cartage for the Brogo WTP upgrade amounted to \$33,000/ML and similar pricing was advised by a supplier in Cooma for water cartage between Cooma to Bombala (approx. 90km). A 10% margin for uncertainty was also applied.

The total cost for trucking of water (based on 30 days) was estimated at about \$15,600/day, for a total of just under \$0.5 million (based on the need to provide 0.5 ML/day in 39 no. tanker trips @ 13 kL/ tanker).

It is noted that the time offline may be longer as it is uncertain as to the time taken to complete the work in the clarifier, at the filter inlets/filter to waste and to replace old electrics and commission a final PLC control system

PFD – Option 1




Figure 8 Process flow diagram for Option 1

UPGRADE EXISTING WTP – Option 1



- A) New WQ testing area & office
- B) New Soda Ash Bulki-Bag dosing
- C) New Polymer batching & dosing
- D) Blowers
- E) Existing Coag
- F) New building for Fluoride
- G) GAC filtered water balance Tank
- H) GAC filtered water pump station
- I) GAC
- J) UV
- K) Delivery Bund
- L) Thickener
- M) Mixed wash water tank - 6 m diameter (50 m3) and pump station
- N) Thickener
- O) Supernatant Return Tank and PS
- P) Mixed Oxidation Tank 2 m diameter (13 m3)
- Q) New Switchboard & MCC
- R) Chlorine building



Existing pipe New pipe

Figure 9 Concept design layout for Option 1

5.3 New WTP Options

5.3.1 New WTP Building

The new WTP options all would have a large lined ColourBond building, containing main WTP process units, chemical storage, control room and electrics. The figure below shows the concept. Design would need to consider requirements to overcome the specific site bushfire risk.



Figure 10 2.5 ML/d Lancefield DAFF water treatment plant main building

5.3.2 New WTP location

In options 2, 3, 4 and 5 it is proposed that the new WTP be constructed on the site of the existing used house. (Refer Figure 11).




Figure 11 Preferred location of new WTP for Options 2 and 3

For comparison of options it is assumed the existing plant building for chemicals, electrics or controls will not be re-used.

The existing old house offers the following advantages:

- The relatively flat area with sufficient space for any of the plant layouts of options
- Construction without interruption to the current process.

- The existing raw water pipeline, treated water pipeline and pipeline to the sludge lagoons run near the block and hence connecting would require only short pipe lengths.
- Located next to the existing 'ring road'.
- Relatively low bushfire risk

An alternative siting locations was considered, where the new WTP would be located to the east at end of the 'ring' road, behind existing buildings. This option was rejected as it has steep slope, requiring significant earthworks to level the ground and extend a 2:1 batter around edge of building and higher bushfire risk. Also, trucks would have to back into a delivery bund before continuing around the ring road. Raw water and treated water pipelines into and out of the new WTP, and pipeline to the sludge lagoon would be longer. For these reasons this alternative site location was not preferred.

A schematic showing the alternative site location is contained in Appendix F.

5.3.3 Common works for all options

The following works outlined for option 1 in the previous section (refer section 5.2) are also required for the new WTP options 2 to 5. All options require:

- Mixing/aeration of the dam
- All works at the existing raw water pump station
- Oxidation tank and potassium permanganate and pre-chlorine (if required at very low dose) dosing for manganese oxidation
- New soda ash and polymer batching and dosing systems
- New ammonia dosing (options 1,2 and 3 only)
- Mixed Washwater/sludge holding tank and pumps and pipeline to thickener
- Thickener
- Supernatant return pump station and pipeline
- Coagulant and/or Polymer dosing to the thickener feed
- Connection to the existing Clear water Storage
- Reuse of the sludge ponds
- Purpose built new fluoridation and chlorination buildings and dosing systems

The extra works that are common between options 1, 2, 3 and 4 only;

- GAC filters and UV disinfection
- THM Stripping system located in 0.45 ML Res1 tank

Also in Option 4 and 5 do not require mono-chloramine based final disinfection as they have greater organics removal. Finally Option 5 does not require the THM stripping system due to greater DOC removal or UV due to multiple membrane barriers.

5.3.4 Option 2: New WTP (Lamella Plate Clarifier + MF + GAC+ Chloramination)

In Option 2, a new WTP would be constructed where the existing abandoned house is located (as shown in Figure 11). The proposed process train is characterised by the following main steps:

- Lamella Plate Clarifier

- Microfiltration (MF) or Ultrafiltration (UF)
- Granulated Activated Carbon Filter (GAC Filter)
- UV
- Chlorination then mono-chloramine based Chloramination + THM stripping

The Process Flow Diagram for Option 2 is shown in Figure 12 and the proposed site layout is shown in Figure 13.

5.3.5 Option 3: New WTP (DAF + MF +GAC+ Chloramination)

In Option 3, a new WTP would be constructed where the existing abandoned house is located (as shown in Figure 11). The proposed process train is characterised by the following main steps

- Dissolved Air Filtration (DAF)
- Microfiltration (MF) or Ultrafiltration (UF)
- Granulated Activated Carbon Filter (GAC Filter)
- UV
- Chlorination then mono-chloramine based Chloramination + THM stripping

The Process Flow Diagram for Option 3 is shown in Figure 14 and the proposed site layout is shown in Figure 13.

5.3.6 Option 4: New WTP: (DAF + MF + Ozone/GAC + Chlorination)

In Option 4, a new WTP would be constructed where the existing abandoned house is located (as shown in Figure 11). The proposed process train is characterised by the following main steps:

- Dissolved Air Filtration (DAF)
- Microfiltration (MF) or Ultrafiltration (UF)
- Ozone
- Granulated Activated Carbon Filter (GAC Filter)
- UV
- Chlorination + THM stripping

The Process Flow Diagram for Option 4 is shown in Figure 15 and the proposed site layout is shown in Figure 16.

5.3.7 Option 5: New WTP: (DAF + MF + NF + Chlorination)

In Option 5, a new WTP would be constructed where the existing abandoned house is located (as shown in Figure 11). The proposed process train would be:

- Dissolved Air Filtration (DAF)
- Microfiltration (MF) or Ultrafiltration (UF)
- Nano Filtration (NF)
- Chlorination

The Process Flow Diagram for Option 5 is shown in Figure 17 and the proposed site layout is shown in Figure 16.

PFD – Option 2





Figure 12 Process flow diagram for Option 2: New WTP



- 1) New wash water pipe to thickener
- 2) Wash water and sludge pipe from new plant to wash water tank
- 3) New sludge line to lagoons
- 4) Supernatant return to plant inlet
- 5) Wash water flowmeter
- 6) Supernatant flowmeter

- A) Mixed wash water tank - 6 m diameter (50 m³) and pump station
- B) Thickener
- C) Supernatant Return Tank and PS
- D) CIP waste tank
- E) Chlorine Building
- F) Fluoride Building
- G) Mixed Oxidation Tank
- H) UV

Option 2 & 3 – New WTP location

Figure 13 Concept design layout for Option 2 & 3: New WTP

PFD – Option 3




Figure 14 Process flow diagram for Option 3: New WTP

PFD – Option 4





Figure 15 Process flow diagram for Option 4: New WTP



- 1) New wash water pipe to thickener
- 2) Wash water and sludge pipe from new plant to wash water tank
- 3) New sludge line to lagoons
- 4) Supernatant return to plant inlet
- 5) Wash water flowmeter
- 6) Supernatant flowmeter

- A) NF waste tank
- B) CIP waste tank
- C) Mixed wash water tank - 6 m diameter (50 m³) and pump station
- D) Thickener
- E) Supernatant Return Tank and PS
- F) Chlorine building
- G) Fluoride building
- H) Mixed Oxidation Tank
- I) UV (Only for Option 4)

Figure 16 Concept design layout for Option 4 & 5: New WTP

PFD - Option 5




Figure 17 Process flow diagram for Option 5: New WTP

6. Comparison of Options

6.1 Introduction

The relative CAPEX, OPEX, Net Present Cost (NPC) and non-cost related advantages and disadvantages, for each option are discussed in this section of the report.

Refer to Figure 9 (Option 1 site layout) and Figure 13 & 16 (WTP site layout for Options 2 & 3 and 4 & 5 respectively) for site layouts for each option.

Refer to Appendix 0 for the breakdown of costing of CAPEX, OPEX and NPC.

This comparison of options does not include the “Do Nothing” Option as the existing WTP is considered not an acceptable option for the future primarily based on;

- Documented extended failures of the existing treatment process, particularly during higher risk poor raw water quality events associated with wet weather inflows to the dam
- The existing reactivator type clarifier is not a suitable process for a raw water that is variable water temperature/softness, low water temp in winter and generally has high organic/colour and low turbidity
- Measurements that show it is unable to achieve ADWG health limit for THMs in the treated water sent to the town
- insufficient treatment barriers to achieve Health Based Target
- insufficient treatment barriers to achieve normal drinking water limits for odour producing chemicals (eg MIB and geosmin) and stain/taste producing manganese
- Bombala resident complaints of poor odour./taste water (refer previous Business case appendices) , most likely due to MIB/Geosmin and manganese
- Bombala resident complaints and media reports of dirty some water (refer previous Business case appendices) plus treated water quality data (showing aluminium levels >1mg/l) plus detection of substantial sludge build-up in the CWS which indicates significant volumes of dirty water (probably mainly due to non-optimal coagulation process) are getting through the WTP process to CWS and to customer taps
- Significant OHS and lack of duty/standby risks associated with existing chlorine, soda ash , fluoride and polymer systems plus these systems are well beyond normal 25 yr asset life
- Significant other mechanical/electrical systems that are not operable (eg clarifier internals, spare filter air blower and fluoride) and/or are in beyond normal asset life (eg duty air scour blower)

6.2 Comparison of New WTP site layout to upgrade of Existing

6.2.1 Cost comparison

The comparison of options is summarized in Table 10 below. It is noted that the accuracy of relative cost estimates for this options comparison stage is about 30%.

Based on this accuracy assumption options 1, 2, 3 and 4 are of comparable CAPEX and NPC.

The important outcomes from the comparison of non-cost advantages and disadvantages/risks are;

- Option 1 CAPEX could be higher if there was longer offline period for construction requiring drinking water to be carted in.
- Option 1 has a risk of not achieving adequate performance as the existing Reactivator type clarifier, even when modified to a sludge blanket + tube-settlers has performance risk for treating soft high DOC content water.
- Option 5 has the least risk of not achieving the THM target but a high waste production
- Options 2 has a lamella plate clarifier which may not be as efficient in treatment as Dissolved Air Floatation in Option 3 or 4
- Option 4 has expensive and high power ozone and requires a bigger building than options 2 or 3
- Chloramination (in options 1, 2 and 3), as the final disinfection process, has a small risk of nitrification in the extreme parts of the downstream reticulation system. Nitrification is a process whereby residual ammonia becomes a food source for non-health related biofilm in the pipe network. When it gets going, usually after the mono-chloramine residual decays away to <0.5 to 1mg/L, the residual disinfectant residual then disappears in these areas of the network and water becomes stagnant and a mild poor taste/odour arises. To avoid it a booster chlorine and ammonia dose at a tank in the retic is sometimes needed or a routine water flushing program is implemented to reduce long detention times

Table 10 Comparative costs, advantages, disadvantages and MCA Scoring for each option

| | | Option 1: Retain & upgrade existing treatment process (add Oxn+ UV +GAC + chloramination) | Option 2: NEW Lamella Plate Clarifier + MF + GAC + Chloramination | Option 3: NEW DAF + MF/UF + GAC + Chloramination | Option 4: NEW DAF + MF/UF + Ozone/GAC + Chlorination | Option 5: NEW DAF + MF/UF+ NF + Chlorination |
|---|---|--|--|--|---|---|
| CAPEX* | | \$8.6m | \$9.3m | \$9.1m | \$9.8m | \$9.6m |
| OPEX | | \$265k /year | \$329k /year | \$331k /year | \$340k /year | \$576k /year |
| NPC | 6%pa for 25yrs | \$12.0m | \$13.5m | \$13.3m | \$14.2m | \$17.0m |
| Relative Advantages | | <ul style="list-style-type: none"> •Max reuse of existing assets •Retains process well known to WTP operators | <ul style="list-style-type: none"> •Good for high colour/ v good for high turbidity events •Allows option of PAC instead of GAC •MF/UF very robust in operation and easy to run | <ul style="list-style-type: none"> •Best for high algae and high colour and low/moderate turbidity •MF/UF very robust in operation and easy to run •GAC is best option for long-term MIB/Geosmin removal | <ul style="list-style-type: none"> •Best for MIB/Geosmin removal •MF/UF very robust in operation and easy to run •Disinfection by chlorination only and hence no complexity of ammonia dosing and nitrification risk of chloramination | <ul style="list-style-type: none"> •Best treatment for DOC and THMs •Can bypass NF when DOC is low concentration •Disinfection by chlorination only and hence no complexity of ammonia dosing and nitrification risk of chloramination |
| Relative Disadvantages | | <ul style="list-style-type: none"> •Many existing WTP assets are 39 yrs old, which is excessive for Mech/Elect systems •Clarifier may not be reliable treatment process for the high colour/low turbidity/variable alkalinity & water temp conditions •Risk of plant offline for longer than expected in construction/commissioning requiring more carting in of water supply to the CWS at estimated \$14,000/d •Nitrification T&O risk and process complexity of chlorination then chloramination •Uncertain asset condition/residual life of filters and clarifier as only visual inspections and there are signs of movement of the filters •Continued confined space at filter valves (OHS) | <ul style="list-style-type: none"> •MF/UF is new technology for Council •CIP cleaning waste for MF/UF for offsite disposal •Nitrification T&O risk and process complexity of chlorination then chloramination | <ul style="list-style-type: none"> •MF/UF is new technology for Council •CIP cleaning waste for MF/UF for offsite disposal •Nitrification T&O risk and process complexity of chlorination then chloramination | <ul style="list-style-type: none"> •High Power for Ozone/GAC and MF/UF •MF/UF is new technology for Council •CIP cleaning waste for MF/UF for offsite disposal •Nitrification T&O risk and process complexity of chlorination then chloramination | <ul style="list-style-type: none"> •Uncertain on % MIB/Geosmin removal in NF •NF has 20% of inflow going to waste as high DOC water and it is uncertain as to treatment allowing some to return as supernatant, Consequently, need to design for overall losses from plant at about 20 %, so plant is bigger than all other options •CIP cleaning waste for MF/UF and NF offsite disposal •Highest process complexity |
| Relative score against MCA (Best=5, Worst=1) | Performance Operability Enviro&WHS Construction complexity Easy procurement | ✓✓ (performance of modified clarifier uncertain) ✓✓ (too compact at clarifier/filters) ✓✓ (ongoing poor access to filter valves) ✓ (existing structure and uncertain time offline risks) ✓✓✓✓ | ✓✓✓ (nitrification risk) ✓✓✓ ✓✓✓ ✓✓✓✓ (small building easily fits) ✓✓✓✓ | ✓✓✓ (nitrification risk) ✓✓✓ ✓✓✓ ✓✓✓✓ (small building easily fits) ✓✓✓✓ | ✓✓✓✓ ✓✓✓ ✓✓✓ ✓✓✓ (bigger building) ✓✓✓ | ✓✓✓✓✓ ✓✓✓ ✓(high volume of salty NF waste) ✓✓✓ (bigger building) ✓✓ (NF equipment) |
| Order of preferred option | (best=1) | 4 | 2/3 | 1 | 2/3 | 5 |

* The above costs do not include Fluoridation. Based on a separate contract for a new building and sodium fluoride dosing system compliant with the NSW code the extra cost is up to \$0.65m. This cost is based on recent tenders and independent cost estimates.

7. Conclusions & Recommendations

7.1 Conclusions

The main conclusions from condition assessment of the existing plant were;

- The existing raw water pump station requires a new building and E, I and C works due to very old asset in poor condition and not fit for purpose.
- The existing WTP is now 39 years old and the process (especially alkali, polymer and chlorine) and most electrical systems are older than normal asset life.
- Existing sludge ponds are too small to achieve the requirements of (1) containment of filter wash water and clarifier sludge plus (2) sludge drying

The main conclusions from the assessment of demand, groundwater alternative, existing surface water quality and treatment were;

- The required future (in 25 years) peak day demand for the new WTP is 1.5 ML/d
- The alternative of a future water supply from groundwater was found to be not viable
- The construction of a weir on the Bombala river does not provide a suitable raw water supply to the WTP
- The existing raw water pump station structures are well beyond asset life and the pumps have no variable flow control and minimal telemetry back to the Water Treatment Plant (WTP). A reliable pump station with ability to modulate flowrate and monitor performance is essential, particularly given the relatively old AC water main connecting it to the WTP
- The raw water catchment for this system is unprotected with substantial areas of grazing land for cattle/sheep/deer and septic tanks at rural properties. Based on the Health based Targets (HBT) concept, understood to be soon added to (ADWG), the Source Water Category Classification would be 4. This requires multiple treatment barriers to achieve the required high level of removal of bacteria/virus /protozoan (e.g. Cryptosporidium)
- Raw water quality conditions are challenging for treatment. This is mainly because this water supply from Coolumbooka Dam is from an unprotected catchment with high microbiological risk plus after chlorine is added, it produces levels of disinfection byproducts (eg THMs) that exceed ADWG health limit in the treated water. Also, raw water is soft with ongoing odour due to MIB/Geosmin and has very low water temperatures in winter. These characteristics require special features to be added for effective treatment. Events of very high manganese and iron occur. The existing treatment processes are not suitable or sufficient for treatment of this combination of risk and raw water quality conditions.
- The existing WTP is now 39 years old and the process (especially alkali, polymer and chlorine) and most electrical systems are older than normal asset life. Some minor improvements have recently occurred (e.g. motorised filter valves, new coagulant dosing system and limited SCADA upgrade) but performance of this plant is generally below standard (e.g. THMs are too high). Treatment essentially failed for several days soon after the recent wet weather event in February 2020. The existing process is not suitable for these rapidly deteriorating conditions.
- The recent special water quality sampling program was very useful in providing better understanding of the water quality challenges for this surface water supply from Coolumbooka Dam. However, it was of limited duration and did not cover the recent large storm event for several water quality characteristics (results are summarised in Appendix C).

New WTP options that are considered suitable for the raw water quality conditions are:

- OPTION 1: Modify/add to existing plant; Pre-oxidation + tube settlers into modified clarifier + upgraded gravity filtration+ GAC + UV + chloramination. Work would include a new 920kg drum based chlorination system in a separate building plus a separate building for a new future sodium fluoride dosing system plus reorganise the existing main WTP chemicals/office/building
- OPTION 2: Pre-oxidation + Lamella Plate clarifier + Membrane filtration+ GAC + UV + chloramination then chloramination + THM stripping
- OPTION 3: Pre-oxidation + Dissolved Air Floatation (DAF) + Membrane filtration + GAC + UV + chloramination then chlorination+ THM stripping
- OPTION 4: Pre-oxidation + Dissolved Air Floatation (DAF) + Membrane filtration + Ozone/GAC + UV + chlorination+ THM stripping
- OPTION 5: Pre-oxidation + Dissolved Air Floatation (DAF) + Membrane filtration + nano filtration + chlorination

A summary of the options and comparison of options is set out below. All the Options 2 to 5 would be located at the site of the old house on the existing WTP site.

Option 3 is preferred overall on cost and non-cost advantages basis.

| Item | OPTION1 | OPTION 2 | OPTION 3 | OPTION 4 | OPTION 5 |
|-------------------------|--|-----------------------------------|-----------------------------------|-----------------------|-----------------------------------|
| CAPEX | \$8.6m | \$9.3m | \$9.1m | \$9.8m | \$9.6m |
| NPC | \$12m | \$13.5m | \$13.3m | \$14.2m | \$17m |
| Performance | ✓✓ (clarifier uncertain) | ✓✓✓ (small nitrification risk) | ✓✓✓ (small nitrification risk) | ✓✓✓✓ | ✓✓✓✓✓ |
| Operability | ✓✓ (too compact) | ✓✓✓✓ | ✓✓✓✓ | ✓✓✓✓ | ✓✓✓ (|
| Env&WHS | ✓✓ (ongoing poor access to filter valves) | ✓✓✓ | ✓✓✓ | ✓✓✓ | ✓(high volume of salty NF waste) |
| Construction complexity | ✓ (existing structure and uncertain time offline needing carting in water risks) | ✓✓✓✓ (small building easily fits) | ✓✓✓✓ (small building easily fits) | ✓✓✓ (bigger building) | ✓✓✓ (bigger building) |
| Easy procurement | ✓✓✓✓ | ✓✓✓✓ | ✓✓✓✓ | ✓✓✓ | ✓✓ (NF equipment) |

Note that the above costs do not include Fluoridation. Based on a separate contract for a new building and sodium fluoride dosing system compliant with the NSW code the extra cost is up to \$0.65m. This cost is based on recent tenders and independent cost estimate for a similar size plant in NSW.

7.2 Recommendations

The following is recommended based on this assessment of requirements and the options to achieve them;

- Based on projected demand in 25 years' time, the required new WTP capacity is 1.5ML/d with a peak instantaneous flowrate of 25 L/s
- The key features of the preferred Option 3 to go to the next stage of this project are;
 - treatment process; Pre-oxidation + Dissolved Air Floatation (DAF) + Membrane filtration + GAC + UV+ chlorination then chloramination + THM stripping
 - buildings: designed to suit bushfire rating of the area
 - Location; at existing old house site and decommission existing WTP but possibly reuse existing building for some of the chemical systems and for administration/spares storage
 - New wash water/sludge system; wash water/sludge holding tank and pumps to thicken and then concentrated sludge to existing sludge ponds and supernatant tank and supernatant return pumps to WTP inlet
- Construct a separate purpose built new chlorination building to house a duty + standby 920kg drums of chlorine plus duty/standby gas chlorinators and separate service water system
- Because Fluoridation is best located in a separate purpose built building as it requires specialist contractor and often is completed under a separate funding process.
- Continue, at lower frequency of sampling, the special water sampling program over autumn /winter focusing on the main issues of
 - Raw water at dam; E,coli, pH, alkalinity, colour, turbidity, MIB/Geosmin and DOC
 - Filtered water; turbidity prior to addition of soda ash and chlorine
 - Treated water; DOC, pH, alkalinity and THMs (CWS, Res1 and retic sites)

It is also not recommended to pursue any further the options of groundwater or a weir on the Bombala River as a new source of water supply to the WTP.

)

Appendices

Appendix A – Existing plant asset register

Refer to following page



Table 11: Asset register (visual assessment as per site visit 16/4/19)

| Asset | Category | Sub-Asset | Size | Details | Year constructed | Effective Life | Residual Life | Comment / Strategy |
|--------------------------|--------------------------|--|--|--|-------------------------|---------------------------|--------------------------|---|
| Raw Water Source | Civil | Coolumbooka Dam | 250 - 300 ML | | ~1939 | 100 | 19 | In use |
| | | Coolumbooka Weir | | Handrails replaced ~1980 | ~1980 | 50 | 20 | In use |
| Raw Water pumps and Main | Pipework | Pipeline from Dam to RW Pumps | DN 200 CICL | | ~1939 | 100 | 19 | In use |
| | | Pipeline from Bombala river, downstream of dam | ? AC | | Pre 1980 | 50 | < 11 | Only used then water level in dam is low. |
| | | Secondary pipeline from dam... | DN 150 AC | | Pre 1980 | 50 | < 11 | Only used when extra flow is obtained from Bombala River, downstream of dam. |
| | Mechanical | Raw Water pump station | 2 x 50 kW | D/S pumps, observed 67 amp @240V/phase | ~1981? | 40 | 1? | In use. Age and kW uncertain |
| | | RW Pump stn monorail and hoist | | manual | 1981 | 30 | -9 | Hoist old manual chain type and monorail too low |
| | Electrical | Raw Water pump station | steel | D/S pumps | 1981? | 35 | -4? | In use. Age uncertain |
| WTP | Civil | Main plant and TW pump Building | Main 15.5m x 11.6 m pumps 7 x 4.5m | Brick structure | 1981 | 50 | 11 | In use. |
| | | Walkways above clarifier and filters | | Galv steel | 1981 | 35 | -4 | in use |
| | | Roof over clarifier and filter area | | Galv steel | 1981 | 35 | -4 | In use |
| | | Jet Mixing tank | 6 m height | Concrete | 1981 | 80 | 41 | In use. |
| | | Reactor Clarifier | 10.25 m diameter with inner shroud at 4.88m diam | Concrete | 1981 | 80 | 41 | Upflow rate = 1.92m/hr @30L/s, is too high for high organics/colour/low turbidity water. Need 1 to 1.2m/hr in floc-blanket type clarifier, reactivator type more suited to high turbidity or softening Significant vertical cracks in brick wall connecting the filter block to the clarifier. Filtration rate =9.8m/hr at plant flow=30L/s |
| | | Filters | 2.3 m by 3.4 m for each filter | 2 no. concrete filter block. Boby Rapid Gravity type filters | 1981 | < 80? Cracks/moving | < 41? | |
| | | Mixing Tanks – Soda Ash | 1.37 m diameter at 1.5 m deep = 2.2 m ³ | 2 no. tanks –FRP, 20kg bags batch to 5%w/v | 1981 | 25 | -14 | Manual batching to 5%w/v |
| | | Storage – Polymer | 0.76 m diameter | FRP | 1981 | 25 | -14 | Manual batching to 0.2%w/v |
| | | Storage bund– ACH or alum | | Concrete | 1981 | 50? | 11? | Concrete has leak according to ops |
| | | Storage Tank ACH or Alum | 10kL (approx.) | PE | 2018? | 25 | -14 | Tanks shown in original drawings no longer used |
| | Fluoride batching system | | GRP | 1981? | 25 | -14 | Basic manual system | |
| | Sludge Lagoons | 560 m ³ each 24 m x 18 m (surface) 1:2 slope wall | 2 no. sludge lagoons with baffles | 1981 | 40 | 1 | Lagoons need clay lining | |
| | Mechanical | Backwash flowmeter and control valve | | | 1981 | 25 flow meter 40 valve | -14 1 | |
| | | Treated water pumps and motors | 22kw @38L/s | 2No | 1981 and 2007? | 40 | 1 22 | 1 pump motor label 2007 other one looks older |
| | | Dosing Fluoride | Sodium Fluoride | 1No and float activated service water | 1981 | 25 | -14 | Old and poor condition, no softener for service water |
| | | Blowers – Air scour | VSD controls | 2 no. | 1981 blowers 2017 VSDs? | 30 15 | -9 | One blower taken offline for repair at time of visit |
| | | Dosing – Polymer | 12l/hr? | LT20 | 1981 | 25 | -14 | |
| Dosing – ACH/alum | | 12 to 14.4L/hr carrier water 300L/hr | digital | 2018 | 25 | 23 | | |
| | Dosing soda ash | 400L/hr | Metering, | 1981 | 25 | -14 | | |

| Asset | Category | Sub-Asset | Size | Details | Year constructed | Effective Life | Residual Life | Comment / Strategy |
|--------------|------------|--|--|--|--|----------------|---------------|--|
| | | Chlorinators | 1 pre +1 post Chlorinator/ ejector sets 1kg/hr each | Manual adjustment of rotameter valves | 1981 Chlorinators | 25 | -14 | Very basic control OHS risk (ie no chloguards) Gas leak detectors unknown age |
| | | Chlorine cylinders | 2no x 70kg bottles with vac regulators | | Vac regs 2018? | 15 | 13? | No standby and no weight sensor under cylinders |
| | | motorised filter inlet, outlet and wash water valves | | | 2017 actuators 1981 valves? | 25 40 | 22 1? | When were valves installed? |
| | | Motorised Sludge Valve (clarifier outlet) | | | 2017 actuators 1981 valve? | 25 40 | 22 1? | When were valves installed? |
| | | Chemical Mixers | Soda ash, polymer | | 1981 | 25 | -14 | In use |
| | | Reactivator clarifier draught tube mixer and sludge scrapper | | | 1981 | 25 | -14 | Not in use |
| | | Service Water System | | Pumps look recent | 1981? | 25? | -14? | Undersized for systems and no flow meter or VSD control for pressure |
| | Pipework | From filter sump to sludge lagoons | DN250 or 300? | AC | 1981 | 50 | 11 | |
| | | Backwash from Res 1 to filters | DN250 | DICL? | 1981 | 80 | 41? | |
| | | Rising main to Res 1 | DN250 | DICL? | Pre 1980 | 80 | <41? | |
| | | Gravity Main from Res 1 | DN250 | DICL? | Pre 1980 | 80 | <41? | |
| | Other | Filter Media | Filter floor has laterals | Sand/coal media, PVC laterals with PVC nozzles | 2018 | 20 | 18 | Replaced the sand in July 2018. Prior to replacement, there was only 400 mm of sand and no anthracite found. |
| | Electrical | TW pumps and main WTP Switchboards | | 1981 | 35 | | | Comment from Elec engineer? |
| | | SCADA | | | 15 | | | |
| Distribution | Civil | Clear Water Storage <i>(originally named Res 1, pre 1980)</i> | 455 kL 12.8 m diameter 3.58 m high | RC Tank with galv steel roof | Tank - 1938 Roof installed in 2000* (anecdotal, from site visit) | 80 40 | -2 20 | Tank last cleaned 2018. Visual inspection of inside tank during site visit did not show corrosion on galv steel beams access ladder or roof |
| | | Reservoir 1 <i>(originally named Res 2, pre 1980)</i> | 455 kL 8.5m diameter 8.35 m high | | 1981? | 80 | 41? | Beyond scope but looks < 30yr old |
| | | Reservoir 2 <i>(originally named Res 3, pre 1980)</i> | 1,917 kL | | | 80 | | Beyond scope |

Appendix B – OHS issues as noted during site visit 16/04/19

Table 12 OHS issues, as noted during site visit 16/4/19

| Area | Comment | Photo |
|-------------------|---|--|
| Safety Shower | Safety Shower are not standard supplied showers |  |
| | Service water flow – it is not clear whether this is sufficient to supply both the Safety Showers and the chlorinators at the same time | N/A |
| Trip hazard | Trip hazards under Chlorinator/Filter Block | |
| Chemical Handling | Soda Ash dosing is manual. 25kg bags are unloaded into mixing tank. |  |
| | | |
| Chemical Handling | No delivery bund to contain spilled chemicals from delivery tanker | |
| Chlorinator | Exhaust fan in chlorinator room did not turn on when tested at site visit | |
| | ChlorGuards not installed | |
| WTP boundary | Asbestos at house adjoined to WTP boundary. | |

Appendix C – Water Quality Testing: Memorandum

Refer to the following page for the Water Quality Memo & location of sampling points



Memorandum

30th April 2020

| | | | |
|---------|--|---------|--------------|
| To | Snowy Monaro Regional Council | | |
| Copy to | Catherine Sherry, GHD | | |
| From | Laura De Rango, GHD | Tel | 03 8651 9245 |
| | Mike Chapman, GHD (review/approval) | | |
| Subject | Update on Water Quality Monitoring at Bombala WTP Site | Job no. | 3137056 |

Bombala Water Quality Monitoring Update

1 Introduction

- ALS monitoring started on 6 May 2019 and this looks at data until 23rd January 2020.
- This memo compares ALS results against Bombala WTP operational monitoring.
- This is an update of the memo sent to SMRC in December 2019, and incorporates new data from ALS which was taken in January 2020.
- It is noted that sampling did not continue through the storm event which occurred in late January/early February and so it is unknown how the raw water quality changed during this event. Some indication is given by the on-site operational testing of Iron and Manganese which shows very high concentrations during the storm event, however no ALS sampling was taken during this time
- The water quality sampling locations (location 1 through to 7) are shown on a Proces Flow Diagram of the existing Bombala WTP at the end of this memo.



2 Results

2.1 Dissolved Organic Carbon (DOC)




Figure 1 DOC results of raw water (includes dam surface, dam at 1m depth, at raw water pump station, and inlet to WTP) and treated water

ALS results in Figure 1 show;

- Reduction in DOC by this WTP ranged from zero to 60%.
- DOC of treated water ranges from 5 mg/L to 16 mg/L, which is high. (Refer section on THMs).

Recommend continue to collect DOC results over summer/autumn higher colour periods.



Memorandum

2.2 E. Coli




Figure 2 E. Coli results for raw water

Results indicate;

- High levels of E. Coli can be experienced in summer.
- Early results (Jan to April 2019) are from Health NSW record sheets and show high values.
- When combined with catchment vulnerability, the Health Based Targets (HBT) guideline in draft Australian Drinking Water Guidelines (ADWG) document would, on the basis of these E.coli results, define this raw water as at least category 3 based on earlier results.

Recommend continue to collect results.



Memorandum

2.3 Total Trihalomethanes (THMs)




Figure 3 THMs results at sites 5A & 5B, 6A & 6B, and 7A & 7B

Results show;

- THMs rise in reticulation system and have exceeded the ADWG limit of 250 ug/L at sites 6A & 6B and sites 7A & 7B.
- High values are consistent with treated water containing relatively high levels of DOC plus the prechlorination process at this plant to minimise manganese and iron.

Recommend continued measurement over summer/autumn period when it is expected that THM values will increase.



2.4 Turbidity




Figure 4 ALS and operational turbidity results of raw and filtered water

Results show;

- Operational data for raw water is almost an order of magnitude less than ALS data. This is probably due to incorrect sample point at inlet to WTP, which is affected by prechloriation and ACH dosing.
- Operational results for filtered water turbidity are often lower than ALS result which is significant as Log Removal Value (LRV) under Health Based Targets is set from filtered water turbidity results.

Table 1 Comparison of ALS and operational data for filtered water turbidity

| | ALS data | Operational data |
|-------------|----------|------------------|
| % ≤ 0.5 NTU | 78.6 | 96 |

Table 1 shows that filtered water turbidity from ALS would mean the filters fail the HBT requirements for LRV, which require 95% <0.3 NTU and max of <1 NTU.

Recommend relocate raw water operational sampling point to dam taking sample from the surface or discharge side of pumps and only take sample after pump has been running for say 15 minutes. In addition, ongoing measurement of turbidity by ALS and careful matching of filtered water turbidity measurements by Operations (lab test and online analyser) with samples going to ALS.



2.5 True Colour




Figure 5 True colour results of raw and treated water

Results show;

- ALS results for raw water are 3 to 4 times higher than the operational results for raw water.
- This is likely to be due to the operational sample point being at the WTP where raw water is decolourised by prechlorine.

Recommend relocate raw water operational sampling point to dam taking sample from the surface or discharge side of pumps and only take sample after pump has been running for say 15 minutes. Continue to do ALS and operational sampling to verify if there is a high colour period in summer/autumn (based on historical WTP operational data).



Memorandum

2.6 pH




Figure 6 ALS (showing depth profile in dam) and operational pH results of raw water




Figure 7 ALS and operational pH results of treated water

Results indicate;

- Operational pH data for raw water is generally slightly lower than the ALS pH data, probably due to differences in pH analyser calibration.
- Operational pH data for treated water is reasonable match to ALS data.

Recommend continue to do ALS measurements and match to Operational data over summer/autumn period.



Memorandum

2.7 MIB & Geosmin




Figure 8 MIB results of raw water (showing depth profile in dam) and treated water




Figure 9 Geosmin results of raw water (showing depth profile in dam) and treated water



Memorandum

Table 2 Range of MIB + Geosmin results for raw and treated water

| | Raw water | Treated water |
|--|-----------|---------------|
| MIB (ng/L) | 1 - 27 | 1 - 12 |
| Geosmin (ng/L) | 1 - 44 | 6 - 66 |
| MIB + Geosmin (ng/L) (on a given day) | 4 - 71 | 7 - 78 |

Results show;

- That taste and odour is significant compared to targets for “good water quality” of:
 - MIB < 5 ng/L
 - Geosmin < 5 ng/L
 - MIB + Geosmin < 10 ng/L
- Main T&O problem is Geosmin, which is easier to treat using GAC filtration or Powdered Activated Carbon dosing, compared to MIB.

Recommend ongoing monitoring of all current sites for both MIB and Geosmin over the summer/autumn period. It should show the sources of Geosmin.



2.8 Total Manganese




Figure 10 Total manganese results of raw and treated water




Figure 11 Depth profile of manganese and dissolved oxygen in the raw water supply dam



Memorandum

Table 3 Total Manganese depth profile at Coolumbooka Dam (ug/L)

| | Surface | 1m depth | 3m depth | Bottom |
|------------|---------|----------|----------|--------|
| 6/05/2019 | 85.3 | 79.2 | 78.8 | 82.1 |
| 3/06/2019 | 16.3 | 16 | 16.4 | 18.1 |
| 27/06/2019 | | 26.3 | | |
| 24/07/2019 | | 28.3 | | |
| 3/10/2019 | 87.7 | 80.2 | 106 | 94.3 |
| 8/10/2019 | 67.9 | 127 | 137 | |
| 10/10/2019 | 77.2 | 82.7 | 85.9 | 87.4 |
| 14/10/2019 | 59 | 68.4 | 74.7 | 77.2 |
| 17/10/2019 | 43.2 | 45.3 | 107 | 181 |
| 21/10/2019 | | 36.5 | | 29.9 |
| 21/10/2019 | | 67.9 | | 29.9 |
| 24/10/2019 | 58.7 | 58.5 | 76.7 | 75.9 |
| 31/10/2019 | 61.8 | 61 | 96 | 175 |
| 4/11/2019 | 77.8 | 100 | 141 | 142 |
| 11/11/2019 | 89 | 92.9 | 103 | 152 |
| 25/11/2019 | 92.4 | 136 | 150 | 174 |
| 16/12/2019 | 150 | 148 | 206 | 490 |
| 23/12/2019 | 107 | 146 | 1000 | 1460 |
| 30/12/2019 | 145 | 159 | 186 | 2430 |
| 9/01/2020 | 98.5 | 98 | 890 | 1490 |
| 16/01/2020 | 73.6 | 113 | 1290 | |
| 23/01/2020 | 94.6 | 166 | 1650 | |



Memorandum

Results show;

- Relatively low levels of manganese in the treated water compared to the raw water and that it is removed by the WTP. The main treatment step is likely to be the high prechlorine dose. However, this prechlorine dose is increasing the treated water THM levels and may not be sustainable in the future.
- The depth profile in Figure 11 shows when dissolved oxygen (DO) level is low in deeper water in the reservoir, then the manganese level starts to increase and the manganese is mainly in soluble form, which is harder to treat at this WTP.
- Where both operational data and ALS data for Manganese concentration is available (Oct-Nov 2019), the operational results are significantly lower than ALS testing. Therefore, in the storm even when these operational concentrations jumped to 50-800 ug/L, it can be inferred that the true concentration (if tested by ALS) would have been significantly higher again.
- Table 3 shows how Manganese concentrations vary with depth in Coolumbooka Dam. Manganese concentrations increase with depth and therefore there is a potential to get very high Manganese concentrations when water from the bottom of the dam is entrained in the raw water supply pipe.
Aeration

Recommend ongoing monitoring of all current sites for Manganese over the summer/autumn period. Aeration of the Dam would encourage mixing, prevent stratification and hence prevent the very high manganese concentrations being entrained in the raw water pipe.



2.9 Iron




Figure 12 Total iron results of raw and treated water




Figure 13 Depth profile of total iron and dissolved oxygen in the raw water supply dam



Memorandum

Results show;

- Relatively high levels of iron in the raw water that are removed by the WTP. The main treatment step is likely to be the ACH plus prechlorine dose. However, this prechlorine dose is increasing the treated water THM levels and may not be sustainable in the future.
- The depth profile in Figure 13 shows when dissolved oxygen (DO) level is low in deeper water in the reservoir, the iron level does not appear to increase due to leaching from sediments
- The operational data for Iron concentration is similar to results given by ALS testing.

Recommend continue iron measurements by ALS over summer/autumn to confirm if leaching from sediments occurs later in the stratification cycle in the dam and to confirm the effectiveness of the current WTP process for its removal.

2.10 UVT

Results show;

- Treated water has relatively low values of UVT and are consistent with high values for DOC.
- As shown in Figure 14 there is a correlation between DOC and UVT for treated water that is similar for treated water from other systems.
- Based on the current limited data set a design UVT value for UV disinfection process at Bombala WTP would be about 80%. However, this needs to be confirmed by what is measured by ALS over the high demand period over summer.

Recommend continuation of UVT measurements in the same filtered water samples as where turbidity and DOC are measured, as both these can affect UVT measurements.




Figure 14 Correlation between UVT and DOC of treated water



Memorandum

2.11 Summary of ALS and Operational Data

A summary of results to date is set out in Table 3. Highlighted values indicate where a large difference between ALS results and WTP Operational results occur. The differences need to be reconciled as considerable time goes into collection and analysis and coding up the more frequent (and important) Operational results.

Table 4 Summary of ALS and operational data for raw and treated water

| Parameter | Units | ALS Average | ALS Min | ALS Max | Operational Min | Operational Max |
|---------------------------------------|-------------|-------------|---------|---------|-----------------|-----------------|
| Raw water | | | | | | |
| Turbidity | NTU | 3.4 | 1.1 | 8.4 | 0.7 | 3.7 |
| Colour - true | PCU | 28.7 | 22.0 | 42.0 | 0 | 65 |
| pH | - | 8.0 | 6.1 | 8.7 | 7.3 | 8.3 |
| Total alkalinity as CaCO ₃ | mg/L | 113 | 87 | 316 | <1 | 159 |
| E. Coli | MPN/ 100 mL | 13.1 | 0.5 | 66 | - | - |
| MIB + Geosmin | ng/L | 21 | 7 | 65 | - | - |
| Manganese - total | ug/L | 226 | 16 | 2430 | <20 | 700 |
| Iron - total | mg/L | 0.4 | 0.1 | 1.8 | 0 | 2.7 |
| Treated water | | | | | | |
| Turbidity | NTU | 0.4 | 0.1 | 2.4 | 0.01 | 0.52 |
| Total trihalomethanes | ug/L | 220 | 130 | 310 | - | - |
| Total alkalinity as CaCO ₃ | mg/L | 136 | 76 | 167 | - | - |
| pH | - | 7.89 | 7.28 | 8.6 | 7.3 | 8.3 |
| E. Coli | MPN/ 100 mL | No data | No data | No data | - | - |
| MIB + Geosmin | ng/L | 16.7 | 6.0 | 29.0 | - | - |
| Manganese - total | ug/L | 14.82 | 43 | 81 | - | - |
| Iron - total | mg/L | 0.03 | 0.01 | 0.18 | - | - |
| UVT | % | 82.8 | 76.1 | 87 | - | - |



Memorandum

3 Conclusion and Recommendations

3.1 Conclusion – Raw Water

- Operational data is significantly lower for raw water quality compared to ALS data for:
 - Turbidity
 - True colour
 - pH
- This seems to be due to the operational sample point being at the WTP not at the reservoir. That is, results are affected by prechlorine and perhaps ACH dosing.
- Generally, this raw water has high values for:
 - True colour
 - MIB & Geosmin
- E. Coli levels are consistent with category 3 of the HBT guidelines in that levels greater than 20 MPN/100 mL occur. The recent ALS E. Coli results (Jan 2020) confirm the previous NSW Health E Coli results (Jan 2019), both of which show E. Coli at >20 MPN/100 mL.

3.2 Conclusion – Filtered Water

- Filtered water turbidity results, based on ALS data, would also fail the HBT criteria for Log Removal Value for protozoans, bacteria and virus for the clarification/filtration process. That is, to achieve LRVs requires filtered water turbidity to be <0.3 NTU for 95% of data and all data to be <1 NTU.

3.3 Conclusion – Treated Water

- MIB and Geosmin in the treated water give combined results of 7-78ng/L, which is significantly greater than the recommended 'good water quality' Taste & Odour limit of MIB+Geosmin <5ng/L
- THMs are very high and above the ADWG limit of 250 ug/L.

3.4 Recommendations

- Investigate and rectify why the raw water turbidity, true colour and alkalinity levels are so different between the ALS data and the Operational data.
- Continue all aspects of this sampling program. This is recommended to:
 - Confirm the high THM levels over summer/autumn period.
 - Confirm operational data which shows a significant increase in Manganese and Iron in the stratified dam. Soluble Manganese removal at the WTP may not be as effective.
 - Confirm that MIB and Geosmin increase over summer due to algae and/or stratification of the dam.



Memorandum

Regards

Michael Chapman


Principal Engineer Water Treatment and Desalination

GHD Pty Ltd ABN 39 008 488 373
Level 9 180 Lonsdale Street Melbourne Victoria 3000 Australia
T +61 3 8687 8000 **F** +61 3 8732 7046 **E** melmail@ghd.com **W** www.ghd.com

3137056 – Bombala Sampling Program

This document is in draft form. The contents, including any opinions, conclusions or recommendations contained in, or which may be implied from, this draft document must not be relied upon. GHD reserves the right, at any time, without notice, to modify or retract any part or all of the draft document. To the maximum extent permitted by law, GHD disclaims any responsibility or liability arising from or in connection with this draft document.

EXISTING SYSTEM – Sample Locations



- Sample Locations:**
- 1. Depth profile in Dam
 - 1A. Raw water main at raw water pump station
 - 2. WTP inlet (affected by pre-chlorination)
 - 3A and 3B. Outlet of Clarifier (A and B are different WQ parameters measured on different days)
 - 4. Outlet of filters
 - 5A and 5B. Outlet of Clear water storage (A and B are different WQ parameters measured on different days)
 - 6A and 6B. Res 2 outlet (A and B are different WQ parameters measured on different days)
 - 7A and 7B. Caravan Park Retic (A and B are different WQ parameters measured on different days)

Appendix D – Bombala Operational Monitoring Data for recent 2020 wet weather event

Refer following page

Appendix E - Reservoir Aeration/Mixing Systems

Refer to following page.



AWA conference paper 2007/08

The “Do’s and the Don’ts” Experience from Design, Installation and Operation of 13 Large Water Supply Reservoir Aeration-Mixing Systems

*Mike Chapman, Manager Water Quality and Briony Rogers, Civil Engineer
GHD Pty Ltd*

ABSTRACT

Over the past 20 years the authors have designed, installed and, in some cases, developed operating histories of thirteen reservoir air diffuser-based aeration-mixing systems. During risk assessments they have also come across a number of other existing systems, which in some cases have not been effective. The reservoirs varied in size from 40 ML to 100,000 ML, with most in the range of 5,000 ML to 30,000 ML. This paper summarises practical experience in aeration-mixing systems for prevention of manganese and iron leaching from sediments and, in some cases, minimising blue green algae blooms. Design, installation and operational "do's" and "don'ts" are discussed and the water quality effects during operation that were observed in some cases are presented. The paper includes discussion of design rules that work, as well as innovative lightweight concepts for the air diffuser pipes in the reservoir. It also presents the range in installed costs for several recent installations.

INTRODUCTION

Over the past 20 years the authors have designed, installed and, in some cases, developed operating histories of thirteen reservoir air diffuser-based aeration-mixing systems (see Table 1).



Table 1 Recent GHD Experience with Reservoir Aeration-Mixing Systems

| Reservoir | State | Capacity (ML) | Design | Installation & Commissioning | Long-term Operation Review |
|---------------------------|-------|---------------|------------------|------------------------------|----------------------------|
| Glenfern | VIC | 40 | ✓ | ✓ | x |
| Quiet Lakes | VIC | 200 | ✓ | ✓ | x |
| Kerrie | VIC | 200 | ✓ | ✓ | x |
| Running Ck | VIC | 210 | ✓ | ✓ | ✓ |
| Campaspe | VIC | 240 | ✓ | ✓ | x |
| White Swan | VIC | 5,000 | ✓ | ✓ | x |
| Paluma | QLD | 11,800 | ✓ ⁽¹⁾ | x | x |
| Tarago | VIC | 20,000 | ✓ | ✓ | ✓ |
| Rosslynne | VIC | 25,000 | ✓ | ✓ | x |
| Merrimu | VIC | 30,000 | ✓ | ✓ | x |
| Lal Lal | VIC | 60,000 | ✓ | ✓ | x |
| Sugarloaf | VIC | 90,000 | ✓ | ✓ | ✓ |
| Thomson (stage 1 filling) | VIC | 180,000 | ✓ | ✓ | ✓ |
| Upper Yarra | VIC | 200,000 | ✓ | ✓ | |
| Ross River Dam | Qld | 200,000 | ✓ | ✓ | □ |
| Lancefield | Vic | 200 | ✓ | ✓ | |
| Bundanoon | NSW | 2000 | ✓ | ✓ | |

(1) review performance of existing

During risk assessments they have also come across a number of other existing systems, which in some cases have not been effective.

This paper summarises practical experience in aeration-mixing systems for prevention of manganese and iron leaching from sediments and, in some cases, minimising blue green algae blooms. Design, installation and operational "do's" and "don'ts" are discussed and the water quality effects during operation that were observed in some cases are presented. The paper includes discussion of design rules that work, as well as innovative lightweight concepts for the air diffuser pipes in the reservoir. The range in installed costs for several recent installations is also presented.



BACKGROUND

Mixing-aeration of large reservoirs has been used to destratify reservoirs successfully in a number of locations around Australia and overseas since the 1960s.

The basic concept of the aeration-mixing systems is the use of unconfined air bubble plumes to recreate the natural mixing process that occurs during the colder months in a reservoir. The following are the key features of the system:

- ▶ Air is released from long air diffuser pipes located just above the floor of the reservoir.
- ▶ The rising air bubbles entrain water, generating a net water flow rate approximately 50 to 300 times the airflow rate, depending on depth.
- ▶ Large circulation patterns over the whole of the reservoir are established, which slowly mix the reservoir, breaking down existing stratification of water temperature and increasing the dissolved oxygen (DO) concentration at the bottom of the reservoir.
- ▶ Oxygen is transferred into the reservoir water from the air bubbles and, more importantly, by reaeration of water from the atmosphere as it circulates across the surface of the reservoir.
- ▶ Best success, in terms of water quality management, depends largely on:
 - ▶ Delivering enough air in an efficient manner to generate sufficient water movement to raise the DO concentrations at the floor of the reservoir to > 5 to 6 mg/L all year. If this is not achieved manganese and iron are often leached from the bottom sediments especially over periods from January to May.
 - ▶ Commencing operation of the mixing-aeration system before extensive release of manganese and iron from anaerobic sediments begins, typically in October – December for reservoirs in Victoria. If the aeration system commences operation after this time it may, for a period, “pump” manganese-rich bottom water into the surface well-mixed zone for a while until oxidation occurs. This oxidation process is relatively slow for manganese (months) and relatively rapid for iron (weeks).
- ▶ Delaying aeration start up past about February (for reservoirs in Victoria) risks pumping phosphorous into the surface water zone. However, release of phosphorus from bottom sediments is usually only a risk if DO levels at the bottom fall below 1 mg/L for a month or more.

POTENTIAL BENEFITS

GHD's experience with this technology, when properly operated and of the correct size, shows it is effective for:

- ▶ Minimising manganese and iron problems by preventing their release from the bottom waters.
- ▶ Preventing phosphorus (algae nutrient) and sulphide and ammonia (noxious gas risk in valve houses under a dam) releases from sediments into the water column.
- ▶ Minimising the risk of blue-green algae blooms by maintaining a relatively well-mixed environment that is not conducive to the growth of blue-green algae.
- ▶ Reduced short-circuiting of flows into the reservoir.
- ▶ Allowing the full depth of the reservoir to be withdrawn from for water supply.



- ▶ Allowing lower temperature water to be supplied in summer where near-surface draw is required.
- ▶ Possibly reducing evaporation by lowering surface water temperature. This has yet to be measured but in theory, may be 5-10% reduction in evaporation loss

DESIGN CONSIDERATIONS

The following factors need to be considered when designing a reservoir aeration-mixing system:

Air Flow Rate

To achieve adequate mixing, air is pumped to the reservoir floor and released at about 0.5 – 2 L/s per hole via small holes (around 1 to 2 mm diameter) in long air diffuser pipes. The small holes size allows a high pressure drop across each hole. Consequently, if the long air diffuser pipes are located on undulating surfaces at the reservoir bottom there is no significant variation in air flow rate out of holes that are nearer the reservoir surface.

As a rule of 'thumb' for reservoirs deeper than about 15 m, the ratio of water flow rate/free air flow rate is around 150-300 to 1 and sufficient air is needed to:

- ▶ Overcome the rate of oxygen depletion over say Nov/March in the stratified near bottom water in the reservoir.
- ▶ Mix the reservoir contents within 10 to 30 days.

Air Compressor

Rotary screw air compressors have proven to be the best type of unit for these aeration-mixing applications.

Oil-free air is needed to avoid oil-related contamination of the reservoir water. Air filters with capacity to remove down to 0.01 μm particles (Grade C) provide a satisfactory level of control.

Variable speed drives for air compressors are now available. These allow 'fine tuning' of air flow rates.

Construction

Air diffuser pipes of 15 to 20 m in length are typically used, as these permit uniform distribution of air and are relatively easy to manoeuvre into place when installing and pulling out for inspection. It is difficult to install longer aerators in deep reservoirs.

Small air release holes need to be drilled at regular intervals along the diffuser pipe in the horizontal plane on each side to maximise both stability during air diffuser pipe installation and water entrainment.

A flotation pipe attached to each diffuser pipe enables easy removal for inspection and improves the strength of the structure. When inspection and maintenance is required, say once every 5 to 10 years, the flotation pipe is filled with air to allow the aerators to be floated to the surface.

Air hoses are normally connected at the centre of each air diffuser pipe and flotation pipe. A large hose provides the main supply of air to the diffuser pipe and a small hose is utilised to fill the flotation pipe.




Support legs elevate each pipe system approximately 450 to 600 mm from the bottom of the reservoir to avoid entrainment of the bottom sediments.



Photo 1 ; aeration boom placed at floor of reservoir via boats at lal la

Another design for small reservoirs is to run a floating manifold pipe across the storage with dropper hoses and diffuser heads at the bottom. This approach was used at Glenfern, Lancefield and Campaspe sites.



COMMON MISTAKES

GHD's experience has been that mistakes can easily be made in utilising aeration-mixing systems to destratify reservoirs. These errors generally fall into three categories: design, installation and operation.

Design

Incorrect design of an aeration-mixing system will mean the water quality improvements that are expected are not observed.

Air compressor too small

There are a significant number of aeration systems that have not delivered sufficient air to overcome the dissolved oxygen (DO) depletion and raise the DO to > 5 to 6 mg/L at the bottom. This can occur because:



- ▶ There was an incorrect understanding of the rate (in kg oxygen/day) of depletion going on in the near bottom water (say > 10m below the surface).
- ▶ The aeration started too late in the summer.
- ▶ The air diffusers had holes that are too big and all the air came out one end of the long diffuser pipe rather than uniformly along its length.
- ▶ The total length of the air diffuser pipes was too short. As a 'rule of thumb' the air flow rate per unit length of air diffuser pipe should be < 0.1 L/s/m.

GHD has had extensive experience in installing aerators to destratify reservoirs of a range of volumes. Examples of the size of compressors recently designed include:

Table 2 Recent GHD aeration-mixing compressor sizes

| Reservoir | Design Volume | Compressor Size |
|-----------------------|---------------|-------------------|
| Glenfern Reservoir | 40 ML | 7.5 kW |
| White Swan Reservoir | 10,000 ML | 22 kW |
| Lal Lal Reservoir | 36,000 ML | 55 kW |
| Upper Yarra Reservoir | 200,000 ML | 180 kW (proposed) |

Inadequate construction materials

Recent GHD designs have used ABS pipe for the diffusers and flotation pipes (including legs) because of its long life in aquatic environments and its flexibility and impact resistance (minimising the risk of fractures during installation and maintenance).

It should be noted that low DO, sulphides and chlorides in reservoir water can cause rusting of stainless steel that is less than grade 316. Water temperatures >30°C can also result in corrosion of 316 grade stainless steel.

The highest risk element of the aeration system is the connectors holding the air hose to the air diffuser pipe and the straps holding the air diffuser and flotation pipes together. Photo 1 shows the sort of corrosion that can occur to 304 grade stainless steel clips for an aerator installed for only one year.



Photo 1. Corrosion of 304 grade stainless steel

Inappropriate positioning of the diffuser in the water body

The air released from coarse bubble diffuser rises upwards, entraining the water only above the level of the diffuser. There is no mixing of water below the air diffuser pipe. Oxygen transfer below this level is slow, through molecular diffusion.

A common mistake is to locate the diffusers only a few metres below the water surface, resulting in mixing of only the top layers of water, which are naturally well mixed by wind currents and generally high in DO all year around.

It has also been shown on early work that surface aerators are less energy efficient than bottom air diffuser systems.

Installation

The ABS pipes are flexible, so compressed air should be run through the diffuser to reduce weight during installation.

It is also important to minimise the size of air supply hoses, as these can be quite long.



Finally, the ropes connected to the floats and anchors should be carefully designed to avoid tangling during installation.

Operation

The operating strategy for each reservoir varies with experience and climate. Usage tends to increase in hot and low-wind years and decrease in cold and windy years. The critical control is to generate sufficient water circulation to maintain a DO level at the floor of each reservoir of > 5 to 6 mg/L. Installation of a 24 hr/7 day timer to control aerator operating times is essential.

Where manganese and iron control is required, Reservoir aeration-mixing systems in Victorian normally commence operation in October/November to begin mixing before the reservoir begins to stratify. The trigger for starting up the aeration system is typically when the DO level just above the deepest point in the reservoir drops below 5 to 6 mg/L, as measured by fortnightly DO/temperature profile readings.

Where the aeration-mixing system is used for algae control, intermittent operation of the aerator all year in response to detection of high cell counts of blue green algae (say > 1000 to 2000 cells/mL) is required. Normally algae monitoring on a fortnightly to monthly interval is needed to provide sufficient forewarning.

SYSTEM OPERATION AND COSTS

Capital Costs

The capital costs for recent installations ranged from \$100,000 for a small system to \$500,000 for a large system.

Operating Costs

Annual costs of aeration-mixing systems are directly dependant on the compressor size and the operational hours of the systems.

As an example, a 55 kW compressor was recently installed at Lal Lal Reservoir in Ballarat. The operating strategy presented in Table 3 would result in approximately 2056 hours of usage for the compressor each year.

Table 3 Nominal Operating Strategy for Lal Lal Reservoir (36,000 ML Design Volume)

| Month | Nov | Dec | Jan | Feb | Mar | Apr |
|------------|-----|-----|-----|-----|-----|-----|
| Days/month | 20 | 31 | 31 | 28 | 31 | 31 |
| Hours/day | 6 | 12 | 24 | 16 | 6 | 6 |

Table 4 Estimated Annual Operating Costs for Lal Lal Reservoir

| | | |
|---|---|----------|
| 1 | Power consumption of 113,080 kW hrs (55 kW for 2056 hours) per annum @ \$0.15 per kW hr | \$17,000 |
|---|---|----------|



| | | |
|---|--|----------------------------------|
| 1 | Power consumption of 113,080 kW hrs (55 kW for 2056 hours) per annum @ \$0.15 per kW hr | \$17,000 |
| 2 | Operator visits weekly during operational period @ \$70 per hour for 2 hours per week for approximately 20 weeks | \$2,800 |
| 3 | Maintenance, inspections and consumables | \$3,000 |
| | Subtotal | \$22,800 |
| | TOTAL | Say \$22,000 - \$24,000 per year |

WATER QUALITY

Monitoring for Design

Water quality monitoring before designing a mixing-aeration system is needed to 'fine tune' the design. In particular, the following parameters would ideally be monitored for at least one year:

- ▶ Manganese and iron (at say 1 m above the floor of the reservoir) and DO and water temperature profiles, fortnightly over November/March, monthly over October/November and April/June.
- ▶ Blue green algae concentration at the surface, every month

The exception is large reservoirs, say > 30,000 ML, where a weather station measures continuous wind speed, air temperature, solar radiation input and thermal/DO patterns in the reservoir. This data is useful, as a more detailed idea of aeration system size can then be determined using DYRESM and/or CADEM hydrodynamic/DO models for deep stratified reservoirs.

Installation of thermistor & DO chains to get continuous monitoring of water temperature and DO profiles is, in the opinion of the authors, unnecessary.

Water Quality Improvements

The aeration-mixing system in Lal Lal Reservoir was installed in December 2006 and started operation at the beginning of January, when the reservoir was already stratified. The purpose of the following discussion is to show how quickly the reservoir was mixed.

Depth Profiles

Figure 2 shows the DO profile of Lal Lal Reservoir. The initial readings showed significant stratification within the reservoir, with bottom DO levels of less than 1 mg/L. Over six weeks of aeration, the reservoir became less and less stratified, until almost uniform DO levels within the water column were achieved.




Figure 2. Dissolved oxygen profile

It should be noted that after some time, even the water below the aerator level became oxygenated (i.e. from 1/2/07 to 12/2/07).

Figure 2 shows the changing temperature of the water over time, with representative results at the surface, 5 m depth and 10 m depth.




Figure 2. Water temperature over time



The water temperature first became roughly uniform throughout the water column on 29 January, which indicates the time when the reservoir water completed its first turnover. The uniform DO levels on 6 February indicate that by this date the reservoir mixing was complete.

Manganese

Figure 3 illustrates the value of aeration systems in control of manganese.




Figure 3. Manganese over time

This time series graph shows the manganese and DO profiles for the 90,000 ML capacity Sugarloaf Reservoir before and after a permanent aeration system was installed at the bottom. The aeration system is operated each year between about November and April/May.

Prior to a permanent aeration system being in place manganese levels routinely exceeded 0.1 mg/L near the bottom (at 30 m depth) and coincided with DO near the bottom (at 30 m depth) falling between 6 mg/L. After installation manganese levels remained < 0.03 mg/L all year.

Blue Green Algae

The example of successful control of blue green algae is at Glenfern reservoirs in the Western water system. Figure 4 shows a time series graph of total blue green algae concentration before and after installation of permanent aeration systems in January 2002.




Figure 4. Blue green algae over time

It is, however, important to note that control of blue green algae can be a relatively 'hit and miss' affair. However, the 'rules of thumb' include:

- ▶ A significantly larger air compressor than that needed to control manganese is usually needed because more intense mixing is required to produce environmental conditions that discourage the growth of blue-green algae.
- ▶ Control in larger reservoirs is more uncertain than smaller ones.
- ▶ Control in very shallow reservoirs (say < 3 m deep) is also uncertain.

CONCLUSION

Reservoir stratification over summer often produces water quality problems associated with manganese, iron and blue green algae blooms. In GHD's experience, artificial destratification of such reservoirs through the use of aeration-mixing systems has been an effective way to reduce these water quality risks, provided the systems are sized and located correctly, installed with care and operated with an appropriate strategy.









www.atlascopco.com

100-21A

Appendix F – Alternative siting location considered for new WTP

Refer to following page





Alternative Siting WTP location

Appendix G – Proposed WTP building layouts

Refer following page



Concept design layout – for preferred site location option 2 & 3

Area: 18 x 20 m (excl. bund & footpath)



Concept design layout – for preferred site location option 4 & 5

Area: 20 x 20 m (excl. bund & footpath)






Figure 18 Bombala Control Building Layout for Option 1 (Upgrade existing plant)

Appendix H – Comparison of treatment processes

Refer to following page

Table 13: Comparison of treatment processes based on treatment of contaminants

LEGEND

- preferred process
- optional process

| Contaminant Removed | Iron & Manganese | Turbidity and floc particles | Colour | pH control | Dissolved Organic Carbon | Pesticide chemicals | MIB& Geosmin | Virus | Bacteria | Protozoans | THMs | Algae | Comment |
|---|------------------|------------------------------|--------|------------|--------------------------|---------------------|--------------|-------|----------|--------------------|------|-------|---|
| Treatment Process | | | | | | | | | | | | | |
| Potassium Permanganate | ✓✓✓✓ | | | | | | | | | | | | Best at pH >7.5 – 8.5 in high DOC water as if prevents overdose risk |
| Powder activate carbon | | | | | ✓ | | ✓✓✓ | | | | | | Best if MIB/Geosmin is intermittent |
| Alchlor (ACH) | | ✓✓✓✓ | ✓✓ | ✓ | ✓✓ | | | | | | ✓ | | Not Preferred for high DOC water as does not lower pH and produces poor settling floc |
| Alum | | ✓✓✓✓ | ✓✓✓✓ | | ✓✓✓ | | | | | | ✓✓ | | Preferred for high DOC water as lowers pH and produces good settling floc |
| Dissolved Air Floatation (DAF) | | ✓✓ | ✓✓✓✓ | | | | | | | | | ✓✓✓✓ | Best for high colour/low turbidity water and good for confined site |
| Sedimentation Lamella Plate | | ✓✓✓✓ | ✓✓✓ | | | | | | | | | | Good for confined site |
| Sedimentation Reactivator | | ✓✓✓✓ | ✓✓ | | | | | | | | | | Best for high turbidity water and unconfined site |
| Gravity Dual Media Filtration (greensand) | ✓✓ | ✓✓✓ | | | | | | | | ✓ | | | Requires polymer dosing & air scour + water backwash & filter to waste |
| Microfiltration (MF) | | ✓✓✓✓ | ✓ | | | | | | | ✓✓ | | | Pore size 0.3 – 0.5 µm, lower power |
| Ultrafiltration (UF) | | ✓✓✓✓ | ✓✓ | | | | | | | ✓✓✓ | | | Pore size 0.1 – 0.2 µm, higher power |
| Nano Filtration (NF) | | | | | ✓✓✓✓ | | ✓? | | | ✓✓ ✓(if no bypass) | | | Get about 50% DOC removal and recovery 85-90% |
| Nanofiltration (SW) | | | | | ✓✓✓✓✓ | | ✓? | | | ✓✓ ✓(if no bypass) | | | Get about 90% DOC removal and recovery 80% |
| MIEX | | | | | ✓✓✓✓ | | | | | | | | Proprietary design & high OPEX risk |
| Ozone/GAC | | | | | ✓✓ | ✓✓✓ | ✓✓✓✓ | | | ✓✓ (if CT correct) | ✓✓ | | ozone mainly for MIB/geosmin & when its present most of the time |
| GAC/BAC | | | | | ✓✓ | ✓✓ | ✓✓ | | | | ✓✓ | | DOC removal drops from 50% to 20-30% over 1 year then drops to 15-25% over 10 year |
| Chlorine | ✓✓ | | | | | | | ✓✓✓✓ | ✓✓✓✓ | | | ✓✓✓✓ | Need to have DOC < 4 to 6 mg/L to avoid THMs >250 µg/L |
| Chloramine | | | | | | | | ✓ | ✓✓ | | | | Good for avoiding THMs |
| Caustic Soda | | | | ✓✓✓✓ | | | | | | | | | Lower dose required compared to soda ash |
| Soda Ash | | | | ✓✓✓✓ | | | | | | | | | Not a dangerous good |
| UV Disinfection | | | | | | | | | | ✓✓✓✓ | | | Installed power increases a lot as UVT moves from >90% to < 80% |
| PAX type aeration in Treated water tank | | | | | | | | | | | ✓✓ | | Removes about 35% of THM's when water temp <15 deg c |

Appendix I – Cost comparison of PAC vs GAC

| | PAC | GAC/BAC |
|----------------------------------|--------------------|--------------------|
| CAPEX | | |
| CAPEX | \$430,000 | \$540,000 |
| Site distance | \$43,000 | \$54,000 |
| Subtotal | \$473,000 | \$594,000 |
| +30% | \$142,000 | \$176,000 |
| CAPEX total | \$635,000 | \$770,000 |
| O&M | | |
| Power | \$700/yr | \$1600/yr |
| PAC Dosing | \$7500/yr | - |
| GAC replacement (every 10 years) | - | \$6600/yr |
| Maintenance (2% MEI&C) | \$4000/yr | \$3200/yr |
| Operations | \$10,400/yr | \$2600/yr |
| Subtotal | \$26,600/yr | \$17,200/yr |
| +10% | \$2660/yr | \$1720/yr |
| O&M Total | \$29,260 | \$18,920 |
| NPC | | |
| 25 years @ 6% | \$374,000 | \$242,000 |
| | \$635,000 | \$770,000 |
| NPC | \$1,009,000 | \$1,012,000 |

Appendix J – Comparison of DAF and Settling

The following Figure 10.1, based on International Water Treatment experience, shows the normal operating range for a Dissolved Air Flotation (DAF) process. The TOC is related to colour and in turn alum dosage, which adds to the solids load. This figures show that, for water that has a high TOC (or DOC or true colour) and a low turbidity, the preferred treatment process is DAF then filtration. At Bombala the DOC can be up to about 24mg/L and the turbidity is almost all the time <10NTU in all raw water data.

Settling processes, such as the existing reactivator clarifier or lamella Plate clarifier, are not preferred until the raw water turbidity exceeds about 40 NTU (Degremont-Suez). This is consistent with experience by GHD at several plants such as Hamilton in Victoria, where only the combination of high turbidity with high colour caused de-rating of the DAFF process.




FIGURE 10-1 Process selection diagram based on average raw water quality conditions (Source: reprinted from Valade et al. (2009), *Journal of Water Supply: Research and Technology AQUA*, 58 (6), 424–432, with permission from the copyright holder, IWA Publishing).

Appendix K – THM Stripping System

Refer to following page



CASE STUDY

In-Tank THM Removal System Keeps Water System in Compliance

The Problem

Monterey, California is a seaside town that enjoys cool weather, picturesque beaches and, for the most part, excellent water quality. However, over the last few years, Trihalomethane (THM) levels in the Ryan Ranch part of their system have risen dramatically. Despite aggressively flushing this part of the system and periodically boosting chlorine at the tank to improve residual levels, Monterey was on track to breach their their Total Trihalomethane (TTHM) levels in the summer of 2011.

The Ryan Ranch area is the easternmost part of the Monterey system. While the rest of the Monterey system (closer to the coast) is often shrouded in coastal fog during hot summer days, the Ryan Ranch area is sunny and hot. Furthermore, the 500,000 gallon Ryan Ranch tank receives an average of 100,000 gallons per day of water from three wells in the area. These wells were known to have bromine levels around 70 ppb.

The combination of warmer temperatures and lower turnover had made it difficult to maintain an adequate level of chlorine disinfectant residual. As such, operators had periodically spiked the tank with additional disinfectant and frequently flushed the tank and surrounding system in an attempt to control THMs.

Beginning in 2010, TTHM levels spiked, and the running annual average for the Ryan Ranch system rose dramatically (Figure 1). The dominant THM species was bromoform, “which poses the greatest health risk and is hardest to remove using conventional aeration technologies. Water quality managers calculated that they needed to achieve a TTHM level of less than 50 ppb for the June 2011 measurement for the locational running annual average (LRAA) to remain in compliance. Historical estimates suggested that without a major intervention, TTHM levels were on track to reach 140 ppb by June.




Figure 1. Historic TTHM levels (ppb) per quarter at Ryan Ranch. Locational running annual averages were expected to exceed the Maximum Contaminant Level (MCL) in Q2 2011.



CASE STUDY

In-Tank THM Removal System Keeps Water System in Compliance

The Solution

The precise cause of the dramatic increase in TTHMs in the Ryan Ranch tank were uncertain, but several factors likely contributed to the problem:

1. The combination of high temperatures and low turnover likely led to thermal stratification during some months of the year. Thermal stratification leads to high water age and high rates of residual consumption – both of which can elevate THM levels.
2. The use of source water with high bromine levels likely stimulated the formation of brominated THM species such as bromoform.
3. The tank had been periodically washed out, but it had not been chemically cleaned to remove biofilms. The presence of biofilms and sediment provide additional organic matter that can react with disinfectant to produce DBPs.



Figure 2. The Ryan Ranch tank is a 500,000 gallon steel ground storage tank




Figure 3. Interior conditions of the Ryan Ranch tank prior to TRS.

Operators at Monterey had considered an in-tank aeration system to lower THM levels, but the initial cost estimate they received was not attractive. Complicating the issue was the fact that there was only a limited amount of power available at the Ryan Ranch tank, and a conventional aeration system would have required a substantial electrical service upgrade.

PAX Water Technologies, in partnership with Utility Service Company, proposed a multi-staged approach, using a combination of energy-efficient aeration and mixing, combined with a thorough clean-out of sediment and chemical cleaning of the tank interior. The total system was designed to use less than 30 amps at 120V – and leave power to spare for other systems. The combination of power constraints and the high goal for THM reduction (~60 percent reduction) left no room for error.



CASE STUDY

In-Tank THM Removal System Keeps Water System in Compliance

The Results

Installation and start-up was completed on June 23rd, 2011, just 5 days before the Q2 compliance sample was to be taken. Figure 4 shows the results of the chemical clean and installation of the PAX mixer.



Figure 4. Interior conditions in the Ryan Ranch after cleanout and installation of the PAX mixer.

On July 11, the staff at Monterey received their results: TTHM levels were measured at 49.2 ppb (~65 percent reduction), which brought their LRAA to just below the Maximum Contaminant Level (MCL). “This result was HUGE”, according to Monterey water quality superintendent Leslie Jordan. Subsequent measurements have shown that TTHM levels have remained under control (Figure 4).




Figure 4. TTHM levels at the Ryan Ranch tank in 2010 (without TRS) and 2011 (after installation of the TRS).

Working Together

It is impossible to know with certainty which parts of the TRS made the greatest contribution to the reduction of THMs at the Ryan Ranch tank. Mixing, aeration and chemical cleaning all likely worked together synergistically to produce the successful results. And, by working together, PAX Water Technologies and Utility Service Company were able to provide a comprehensive and multi-pronged approach to THM reduction that could be implemented quickly.

Appendix L – THM vs DOC relationship

Refer to following page

POWDERED ACTIVATED CARBON USE FOR REDUCING THM RISKS

Michael Chapman and Michael Kennedy
GHD, Melbourne, VIC, Australia

INTRODUCTION

For water supply systems that experience periodic high levels of Dissolved Organic Carbon (DOC) associated with previous storm events or return to average rainfall after extended dry periods the problem of noncompliance with Total Trihalomethanes (TTHM) limits can occur. This paper summarises a recent case study where this has been a problem and how management has been achieved. Pilot scale testing then full scale construction and operation of a new Powdered Activated Carbon (PAC) dosing system at an existing 35ML/d DAFF plant was a successful way to keep DOC levels below the concentration above which excessive levels of THMs are formed following chlorination. For a treatment plant that has enhanced coagulation then DAFF or clarifier/filtration process then PAC dosing can be optimised by use of an online S:CAN or similar multispectral UV monitoring system to enable the correct dose of PAC to be added to maintain treated water DOC below a threshold value above which excessive TTHM levels will emerge after chlorination. Depending on the frequency of high DOC events in the raw water this approach can be a cost-effective option compared to other enhanced DOC removal technologies such as MIEX and Ozone/GAC. This approach also has the added benefit of removal of periodic blue green algae and stagnant water generated Taste/odour chemicals such as MIB and Geomsin.

TRIHALOMETHANE LIMITS IN DRINKING WATER

There is ongoing investigation of disinfection by-products from chlorination of drinking water and there are also different THM limits and components of THMs for drinking water

Table 1. International THM standards and guidelines, adapted from Hrudey (2002). *TTHM = sum of chloroform, bromodichloromethane, dibromochloromethane, bromoform. RAA= rolling annual ave

| Country | Guidelines for Disinfection byproduct |
|----------------|---|
| Australia | TTHM* (max): 1987: 200 µg/L then 1996: 250 µg/L |
| USA | TTHM (running annual average) RAA; 1979: 100 µg/L then 1998: 80 µg/L |
| Canada | TTHM(max);1978: 350 µg/L then TTHM (max), 1996: 100 µg/L TTHM (RAA). Other THM (max)2006: 16 µg/L bromodichloromethane but in 2009 this guideline was withdrawn |
| WHO | Chloroform (RAA)1984: 30 µg/L, 1993: 200 µg/L, 2008: 300 µg/L .Other THM (RAA)1993: 100 µg/L bromoform then in 1993: 100 µg/L dibromochloromethane and then in 1993: 60 µg/L bromodichloromethane |
| European Union | TTHM (maximum):1998: 100 µg/L |

From this table it is evident that there is a wide range of views around the world on what THM limits and even what species are important. There is also a downward trend in the USA and Canada but an upward trend in Australia and WHO. To achieve compliance with any of these targets would generally require a TTHM level <100ug/L“as a rolling average. This would also tend to mean the maximum TTHM of perhaps <150ug/L.

ENHANCED COAGULATION PLUS PAC DOSING

As part of this study jar test work was also completed to assess what could be done with enhanced coagulation using alum or ferric based coagulants. Optimised DOC removal occurs when the zeta potential is zero. It was found that ferric coagulant operating at a coagulant pH around 4.8 to 5 would achieve this zeta potential. However, DOC removal was still limited. Figure 1 below summarises the findings. It also shows that addition of PAC with enhanced coagulation could further reduce the DOC. The large red dot at the top right hand corner shows the raw water DOC starting point of 18mg/L.




Figure 1: Jar test results for PAC dosing and alternative coagulants

CASE STUDY FOR RETROFITTING PAC DOSING FOR ENHANCED DOC REMOVAL AND TTHM CONTROL

In this case a 35ML/d capacity Dissolved Air Floatation Filtration (DAFF) in Victoria was, after heavy rain flush events following long dry periods, unable to achieve current Safe Drinking Water Act (2005) requirement for TTHM <250ug/L and there was an objective to achieve <150 to 200ug/l in line with the precautionary principle. The problem was that DOC levels in the raw water would rise to >20 mg/L in this soft reservoir water. (see figure 2). With enhanced coagulation using alum at pH6 it was possible to get the DOC down to about 9 to 10mg/L. However, as indicated by the figure below this was not sufficient to achieve TTHM objectives. (refer figure 3)

Figure 2 ; Variation in DOC levels in Supply Reservoir for Case Study No1






Figure 3 : Relationship between treated water DOC or UVA 254nm on TTHM levels



The next step in this investigation was to determine the relationship between PAC dose and type of PAC product that best suited this water. The raw water DOC was about 18mg/L during the test work. Results of jar tests for this aspect indicated a fine coal based product was best and dose of PAC of about 60 to 80mg/L would be needed to get to TTHM <150µg/L. (refer figure 4).

Figure 4 ; Effect of Alum coagulation only and alum plus various types of PAC on DOC and THMs



The last two issues were (1) what minimum detention time for the PAC prior to alum dose was best and (2) can the DAFF process handle the increased suspended solids load of 80mg/L on top of the suspended solids from the 100 to 150mg/l of alum needed for enhanced coagulation.

Jar test work indicated that a contact time of only about 10minutes was sufficient. Full scale pilot testing by dosing PAC to the inlet main of this DAFF plant showed the DAFF process could handle up to about a PAC around 80 to 100mg/L without excessive reduction in filter run time or derating of the plant capacity and also without elevated filtered water turbidity.

PAC DOSE VERSUS ADDITIONAL DOC REMOVAL

A key determining factor for the cost effectiveness calculation for this simple PAC dosing concept is the relationship between PAC dose and reduction in DOC. As a general rule the R&D work carried out by GHD at a number of sites indicates the following general rules;

| Raw Water DOC level | Treated water DOC with Enhanced Coagulation only | PAC dose to get more DOC removal than get from EH only (mgPAC /mg extra DOC removed) | Comment |
|---------------------|--|--|---|
| 15 to 20mg/L | 7 to 10mg/l | 15 to 20 | Easier to get extra DOC removed as still some big molecular wt species of DOC remaining |
| 10 to 15 mg/L | 5 to 8 mg/L | 20 to 30 | |
| 5 to 10mg/L | 3 to 5mg/L | 30 to 40 | |
| <5mg/L | 2.8 to 3mg/L | >50 | |

COST

Construction of the PAC dosing system and PAC contact tank for this 35ML/d plant was completed in 2014 at a cost of about \$1.8m. The supply cost for PAC has been about \$2000 to 2500/tonne

Full scale testing at up to PAC dose of 80mg/l with alum dose around 65mg/l has shown ;

- Filter run times >16 to 24 hours running at up to 26ML/d
- A need to raise filter aid polymer dose from about 0.05mg/L to about 0.15mg/L to maintain filtered water turbidity
- The sludge from the process has a poorer drying characteristic probably due to the extra polymer added
- A S:CAN multispectral UV analyser is a reliable operational tool for monitoring raw water DOC and for optimising the PAC dose to achieve the desired final treated water DOC level which is known to maintain TTHM at acceptable level (refer figure 6)..

Figure 6 : Raw and treated water DOC levels and PAC Dose Rate effect on treated water DOC level versus time during 2015 trial at DAFF plant



CONCLUSIONS

For water supply systems with variable raw water DOC levels and traditional treatment including the need for chlorination, there can be conditions that trigger TTHM noncompliance. Installing a suitable size PAC dosing system and reaction tank to dose PAC to the untreated water prior to where coagulant is dosed can be a

cost-effective solution. To establish the suitability of a particular water supply system for this solution requires only jar tests, running a temporary PAC dosing system at the full scale plant plus analysis of the long term variation in raw water DOC levels to establish the frequency and duration of high raw water DOC concentration events.

Appendix M — CAPEX and OPEX Estimates

Refer to following page

Operating Cost Estimates - Bombala WTP Options Assessment

| Base Assumptions | | |
|---------------------------------|---------|----------|
| Electricity Price | \$ 0.23 | per kWhr |
| Annual treated water production | 180 | ML/yr |
| Max flowrate | 24 | L/s |

From SW Rocks estimate
Based on treated Water demand - WTP flows in 2019

| Chemicals (as supplied) | | |
|-------------------------------|---------|---------------------|
| Coagulant (Alum) | \$0.45 | per kg as pure Alum |
| Potassium permanganate | \$8.0 | per kg |
| pH adjustment (Soda Ash) | \$0.8 | per kg |
| Pre Chlorine gas as 100% Cl2 | \$4.5 | per kg |
| post Chlorine gas as 100% Cl2 | \$4.5 | per kg |
| Polymer - settled water | \$8.0 | per kg |
| Ozone | | |
| Ammonia | \$10.0 | per kg |
| CIP for MF/UF | \$4,000 | per year |
| CIP for NF | \$2,000 | per year |
| Antiscalant for NF | \$1,170 | per year |

SG
1 Dose as pure alum (which is 16% Al2O3)
1
1
1 Updated to gas with new cost
1
1
1 based on 3mg/L dose, refer to Electricity usage table
1
1 UP CIP every month. Based on Ramsey CIP and Upper Yarra CIP.
Hypo, citric acid, SMBM, Caustic Soda
CIP on NF every 2 months. Caustic Soda, Citric acid
based on 2 mg/L = 2kg/ML * \$6.5/kg * ML/year

| UV replacement items | | |
|----------------------|---------|----------|
| UV lamps | \$8,000 | per year |
| UV Ballast | \$400 | per year |
| UV sleeves | \$400 | per year |
| UV wiper | \$200 | per year |
| UVI sensors | \$2,200 | per year |

4 lamps at \$1000 each, twice a year
\$500 * 4, replaced every 5 years
4 UV sleeves replaced every 5 years
\$750 each, replaced every 5 years
4 at \$5400 each, replaced every 10 years

| Membrane Replacement | | |
|----------------------|---------|-------------|
| UF Membrane cost | \$2,500 | per element |
| NF Membrane cost | \$1,000 | per element |
| UF Membrane elements | 64 | elements |
| NF Membrane elements | 96 | elements |
| UF Membrane life | 5 | years |
| NF Membrane life | 3 | years |

From TasWater plants - Laurie Curran tenders. Replace every 5 years
From TasWater plants - Laurie Curran tenders. Replace every 3 years
64 units at Ringarooma (20.8 L/s), \$2100 per element, 5 year life, quote from 2015
According to tenders

| | | | | | | |
|---------------------------------|-----|-----|-----|-----|-----|---------|
| Annual treated water production | 180 | 180 | 180 | 180 | 180 | ML/year |
| Raw water for dosing | 189 | 189 | 189 | 189 | 216 | ML/yr |

Operating cost estimate

| | Upgrade Existing Plant | Clarifier + MF + GAC + Chloramination | DAF + MF + GAC + Chloramination | DAF + MF + Ozone/GAC + Chlorination | DAF + MF + NF + Chlorination | basis of dose |
|-------------------------------------|------------------------|---------------------------------------|---------------------------------|-------------------------------------|------------------------------|--|
| Chemical Doses (mg/L) | | | | | | |
| Coagulant (Alum) | 120 | 120 | 120 | 120 | 120 | raw water as supplied material (16%w/w Al2O3) |
| Potassium permanganate | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | raw water 1.5mg/L for 3 months, 0.5mg/L for 3 months |
| pre pH adjustment (soda) | 3 | 3 | 3 | 3 | 3 | raw water 5mg/L for half the year |
| Pre Chlorine gas as 100% Cl2 | 1 | 1 | 1 | 1 | 1 | raw water 2mg/L for half the year |
| post Chlorine gas as 100% Cl2 | 4 | 4 | 4 | 3 | 2 | treated |
| Polymer - settled water | 0.1 | 0.1 | 0 | 0 | 0 | raw water polymer only for Clarifier |
| Ozone | 0 | 0 | 0 | 3 | 0 | treated electricity cost only |
| Ammonia | 1.3 | 1.3 | 1.3 | 0.0 | 0.0 | treated a third of post chlorine dose |
| post pH adjustment (soda) - if alum | 45 | 45 | 45 | 45 | 45 | treated |
| Coagulant dose to washwater | 100 | 100 | 100 | 100 | 100 | raw water dose for 5% of raw water (options 1-3) and 20% of raw water for option 4 |

Variable Costs (\$ k/yr)

| Chemicals (\$k/year) | Upgrade Existing Plant | Clarifier + MF + GAC + Chloramination | DAF + MF + GAC + Chloramination | DAF + MF + Ozone/GAC + Chlorination | DAF + MF + NF + Chlorination | |
|-------------------------------------|------------------------|---------------------------------------|---------------------------------|-------------------------------------|------------------------------|---|
| Coagulant (Alum) | \$ 10,206 | \$ 10,206 | \$ 10,206 | \$ 10,206 | \$ 11,664 | raw water |
| Potassium permanganate | \$ 1,210 | \$ 1,210 | \$ 1,210 | \$ 1,210 | \$ 1,382 | raw water |
| pre pH adjustment (soda) | \$ 454 | \$ 454 | \$ 454 | \$ 454 | \$ 518 | raw water |
| Pre Chlorine gas as 100% Cl2 | \$ 851 | \$ 851 | \$ 851 | \$ 851 | \$ 972 | raw water |
| post Chlorine gas as 100% Cl2 | \$ 3,240 | \$ 3,240 | \$ 3,240 | \$ 2,430 | \$ 1,620 | treated |
| Polymer - settled water | \$ 151 | \$ 151 | | | | raw water |
| Ozone | | | | | | treated electricity only - calculated below |
| Ammonia | \$ 2,400 | \$ 2,400 | \$ 2,400 | \$ - | \$ - | treated |
| post pH adjustment (soda) - if alum | \$ 6,480 | \$ 6,480 | \$ 6,480 | \$ 6,480 | \$ 6,480 | treated |
| Coagulant dose to washwater | \$ 1,058 | \$ 1,058 | \$ 1,058 | \$ 1,058 | \$ 1,209 | treated dose for 5% of raw water |
| CIP for MF/UF | | \$ 4,000 | \$ 4,000 | \$ 4,000 | \$ 4,000 | |
| CIP for NF | | | | | \$ 2,000 | |
| Antiscalant for NF | | | | | \$ 1,170 | |
| TOTAL CHEMICALS | \$26,049 | \$30,049 | \$29,898 | \$26,688 | \$31,016 | |

Energy (\$k/year)

| | | | | | | |
|-----------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|---|
| Raw Water pumping | \$ 11,737 | \$ 11,737 | \$ 11,737 | \$ 11,737 | \$ 11,737 | See calculations below |
| Flash mixer | \$ 504 | \$ 504 | \$ 504 | \$ 504 | \$ 504 | See calculations below |
| Flocc mixers | \$ 604 | \$ 604 | \$ 604 | \$ 604 | \$ 604 | See calculations below |
| DAF & sludge roller | | | \$ 2,351 | \$ 2,351 | \$ 2,351 | See calculations below |
| UF | | \$ 4,701 | \$ 4,701 | \$ 4,701 | \$ 4,701 | See calculations below |
| NF | | | | | \$ 6,716 | See calculations below |
| UV | \$ 2,686 | \$ 2,686 | \$ 2,686 | \$ 2,686 | \$ 2,686 | See calculations below |
| Ozone | | | | | \$ 3,105 | Ozone cost is electricity only |
| Air compressors - Clarifier | \$ 504 | \$ 504 | | | | See calculations below |
| Air compressors - DAF | | | \$ 2,519 | \$ 2,519 | \$ 2,519 | See calculations below |
| Supernatant | \$ 504 | \$ 504 | \$ 504 | \$ 504 | \$ 1,007.40 | option 5 has double flowrate hence double supernatant |
| Washwater pumping | \$ 504 | \$ 504 | \$ 504 | \$ 504 | \$ 1,007 | |
| Miscellaneous | \$ 3,022 | \$ 3,022 | \$ 3,022 | \$ 3,022 | \$ 3,022 | |
| TOTAL ENERGY | \$20,065 | \$24,766 | \$29,131 | \$32,236 | \$34,168 | |

| | | | | | |
|--------------------------------|-----------|-----------|-----------|-----------|-----------|
| Total Variable Costs (\$ k/yr) | \$ 46,113 | \$ 54,815 | \$ 59,029 | \$ 58,924 | \$ 65,184 |
| Total Variable Costs (\$ / ML) | \$ 256 | \$ 305 | \$ 328 | \$ 327 | \$ 362 |

Fixed Costs (\$ k/yr)

| | | | | | | |
|------------------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|---|
| Operations labour | \$ 100,000 | \$ 100,000 | \$ 100,000 | \$ 100,000 | \$ 100,000 | based on other plants of similar size and complexity, the operations labour and associated transport and wq testing costs is set at \$100,000/yr 2% of M&E CAPEX cost - linked to CAPEX calculation page \$2000/m3 * 30m3 replaced every 10 years |
| Maintenance (Labour & equipment) | \$ 68,070 | \$ 83,240 | \$ 80,440 | \$ 88,400 | \$ 82,530 | |
| GAC media replacement | \$ 6,000 | \$ 6,000 | \$ 6,000 | \$ 6,000 | \$ 6,000 | Annualised cost Annualised cost 2 removals by truck each year 1 removal by truck each year approx 8% of total produced water over the year = 15ML/year. Trucked to STP @ \$300/20kL Assumption |
| UV total | \$ 11,200 | \$ 11,200 | \$ 11,200 | \$ 11,200 | \$ 11,200 | |
| UF Membrane replacement cost | | \$ 32,000 | \$ 32,000 | \$ 32,000 | \$ 32,000 | |
| NF membrane replacement cost | | | | | \$ 32,000 | |
| CIP waste removal for MF | | \$ 2,000 | \$ 2,000 | \$ 2,000 | \$ 2,000 | |
| CIP waste removal for NF | | | | | \$ 1,000 | |
| NF reject | | | | | \$ 225,000 | |
| Sludge Removal | \$ 10,000 | \$ 10,000 | \$ 10,000 | \$ 10,000 | \$ 10,000 | |
| Total Fixed Costs (\$ k/yr) | \$ 195,270 | \$ 244,440 | \$ 241,640 | \$ 249,600 | \$ 458,530 | |

Totals

| | | | | | |
|-----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Total Operating Costs | \$ 241,000 | \$ 299,000 | \$ 301,000 | \$ 309,000 | \$ 524,000 |
| Contingency (10%) | \$ 24,100 | \$ 29,900 | \$ 30,100 | \$ 30,900 | \$ 52,400 |
| TOTAL OPEX (\$/year) | \$ 265,100 | \$ 328,900 | \$ 331,100 | \$ 339,900 | \$ 576,400 |

10% contingency

Electricity estimates

| Type of operation | Power (kW) | Hours per day | kWh/day | Annual cost | kWhr/ML | |
|-----------------------------|------------|---------------|---------|-------------|---------|---|
| Raw Water pumping | | | | \$ | 11,737 | 270 kWh/ML raw water |
| Flash mixer | 0.75 | | 8 | 6 \$ | 504 | 12.2 kWh/ML treated water |
| Flocc mixers | 0.3 | | 24 | 7 \$ | 604 | 14.6 kWh/ML treated water |
| DAF & sludge roller | 3.5 | | 8 | 28 \$ | 2,351 | 56.8 kWh/ML treated water |
| UF | 7 | | 8 | 56 \$ | 4,701 | 113.6 kWh/ML treated water |
| NF | 10 | | 8 | 80 \$ | 6,716 | 162.2 kWh/ML treated water |
| UV | 4 | | 8 | 32 \$ | 2,686 | 64.9 kWh/ML treated water |
| Ozone | | | | 0 \$ | 3,105 | 75 kWh/ML raw water based on 3kg/ML * 25 kWh/kg |
| Air compressors - Clarifier | 3 | | 2 | 6 \$ | 504 | 12.2 kWh/ML treated water |
| Air compressors - DAF | 3 | | 10 | 30 \$ | 2,519 | 60.8 kWh/ML treated water |
| Supernatant | 0.75 | | 8 | 6 \$ | 504 | 12.2 kWh/ML treated water |
| Washwater pumping | 0.75 | | 8 | 6 \$ | 504 | 12.2 kWh/ML treated water |
| Miscellaneous | 3 | | 12 | 36 \$ | 3,022 | 73.0 kWh/ML treated water |

| Growth rate | | Discount rate | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|----------------------------------|--|---------------|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--|
| 0% | | 6% | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | Year | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | 2041 | 2042 | 2043 | 2044 | | |
| Annual treated water demand (ML) | | | | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | |
| | | | | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | |
| UPGRADE EXISTING | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CAPEX | | | | \$ 8,580,000 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OPEX | | | | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | | |
| Cash flow | | | | \$ 8,580,000 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | \$ 265,100 | |
| Cash flow NPV | | | | \$ 250,094 | \$ 235,938 | \$ 222,583 | \$ 209,984 | \$ 198,098 | \$ 186,885 | \$ 176,307 | \$ 166,327 | \$ 156,912 | \$ 148,030 | \$ 139,651 | \$ 131,747 | \$ 124,289 | \$ 117,254 | \$ 110,617 | \$ 104,356 | \$ 98,449 | \$ 92,876 | \$ 87,619 | \$ 82,659 | \$ 77,981 | \$ 73,567 | \$ 69,402 | \$ 65,474 | \$ 61,768 | | |
| Cumulative Cash flow NPV | | | | \$ 8,580,000 | \$ 8,830,094 | \$ 9,066,032 | \$ 9,288,615 | \$ 9,498,599 | \$ 9,696,698 | \$ 9,883,583 | \$ 10,059,889 | \$ 10,226,216 | \$ 10,383,129 | \$ 10,531,159 | \$ 10,670,810 | \$ 10,802,557 | \$ 10,926,846 | \$ 11,044,100 | \$ 11,154,717 | \$ 11,259,073 | \$ 11,357,522 | \$ 11,450,398 | \$ 11,538,017 | \$ 11,620,676 | \$ 11,698,657 | \$ 11,772,223 | \$ 11,841,626 | \$ 11,907,100 | \$ 11,968,868 | |

CAPEX \$ 8,580,000
OPEX \$ 265,100 per year
NPC (25 years) \$ 11,970,000

| Clarifier + MF + Chloramination | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|--|--------------|--------------|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--|
| CAPEX | | | | \$ 9,280,000 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OPEX | | | | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | | |
| Cash flow | | | | \$ 9,280,000 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | \$ 328,900 | |
| Cash flow NPV | | | | \$ 328,900 | \$ 292,720 | \$ 276,151 | \$ 260,520 | \$ 245,773 | \$ 231,862 | \$ 218,737 | \$ 206,356 | \$ 194,675 | \$ 183,656 | \$ 173,260 | \$ 163,453 | \$ 154,201 | \$ 145,473 | \$ 137,238 | \$ 129,470 | \$ 122,142 | \$ 115,228 | \$ 108,706 | \$ 102,553 | \$ 96,748 | \$ 91,271 | \$ 86,105 | \$ 81,231 | \$ 76,633 | | |
| Cumulative Cash flow NPV | | | | \$ 9,280,000 | \$ 9,608,900 | \$ 9,901,620 | \$ 10,177,771 | \$ 10,438,290 | \$ 10,684,063 | \$ 10,915,925 | \$ 11,134,662 | \$ 11,341,018 | \$ 11,535,694 | \$ 11,719,350 | \$ 11,892,610 | \$ 12,056,063 | \$ 12,210,264 | \$ 12,355,737 | \$ 12,492,976 | \$ 12,622,446 | \$ 12,744,588 | \$ 12,859,816 | \$ 12,968,521 | \$ 13,071,074 | \$ 13,167,822 | \$ 13,259,093 | \$ 13,345,198 | \$ 13,426,430 | \$ 13,503,063 | |

CAPEX \$ 9,280,000
OPEX - fixed \$ 328,900 per year
NPC (25 years) \$ 13,505,000

| DAF + MF + Chloramination | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|----------------------------------|--|--|--|--------------|--------------|--------------|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--|
| CAPEX | | | | \$ 9,060,000 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OPEX | | | | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | | |
| Cash flow | | | | \$ 9,060,000 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | \$ 331,100 | |
| Cash flow NPV | | | | \$ 312,358 | \$ 294,678 | \$ 277,998 | \$ 262,262 | \$ 247,417 | \$ 233,412 | \$ 220,200 | \$ 207,736 | \$ 195,978 | \$ 184,885 | \$ 174,419 | \$ 164,547 | \$ 155,233 | \$ 146,446 | \$ 138,156 | \$ 130,336 | \$ 122,959 | \$ 115,999 | \$ 109,433 | \$ 103,239 | \$ 97,395 | \$ 91,882 | \$ 86,681 | \$ 81,775 | \$ 77,146 | | |
| Cumulative Cash flow NPV | | | | \$ 9,060,000 | \$ 9,372,358 | \$ 9,667,036 | \$ 9,945,034 | \$ 10,207,296 | \$ 10,454,714 | \$ 10,688,126 | \$ 10,908,326 | \$ 11,116,063 | \$ 11,312,040 | \$ 11,496,925 | \$ 11,671,344 | \$ 11,835,891 | \$ 11,991,123 | \$ 12,137,569 | \$ 12,275,726 | \$ 12,406,062 | \$ 12,529,021 | \$ 12,645,020 | \$ 12,754,452 | \$ 12,857,691 | \$ 12,955,086 | \$ 13,049,968 | \$ 13,133,649 | \$ 13,215,423 | \$ 13,295,569 | |

CAPEX \$ 9,060,000
OPEX - fixed \$ 331,100 per year
OPEX - variable per ML
NPC (25 years) \$ 13,295,000

| DAF + MF + Ozone/GAC + Chlorination | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|--|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--|
| CAPEX | | | | \$ 9,820,000 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OPEX | | | | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | | |
| Cash flow | | | | \$ 9,820,000 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | \$ 339,900 | |
| Cash flow NPV | | | | \$ 320,660 | \$ 302,510 | \$ 285,387 | \$ 269,233 | \$ 253,993 | \$ 239,616 | \$ 226,053 | \$ 213,257 | \$ 201,186 | \$ 189,798 | \$ 179,055 | \$ 168,920 | \$ 159,358 | \$ 150,338 | \$ 141,828 | \$ 133,800 | \$ 126,227 | \$ 119,082 | \$ 112,341 | \$ 105,982 | \$ 99,983 | \$ 94,324 | \$ 88,985 | \$ 83,948 | \$ 79,196 | | |
| Cumulative Cash flow NPV | | | | \$ 9,820,000 | \$ 10,140,660 | \$ 10,443,170 | \$ 10,728,557 | \$ 10,997,789 | \$ 11,251,782 | \$ 11,491,399 | \$ 11,717,451 | \$ 11,930,709 | \$ 12,131,895 | \$ 12,321,694 | \$ 12,500,749 | \$ 12,669,669 | \$ 12,829,027 | \$ 12,979,365 | \$ 13,121,193 | \$ 13,254,994 | \$ 13,381,221 | \$ 13,500,302 | \$ 13,612,644 | \$ 13,718,626 | \$ 13,818,610 | \$ 13,912,934 | \$ 14,001,919 | \$ 14,085,867 | \$ 14,165,063 | |

CAPEX \$ 9,820,000
OPEX - fixed \$ 339,900 per year
NPC (25 years) \$ 14,165,000

| DAF + MF + NF + Chlorination | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-------------------------------------|--|--|--|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--|
| CAPEX | | | | \$ 9,600,000 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OPEX | | | | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | | |
| Cash flow | | | | \$ 9,600,000 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | \$ 576,400 | |
| Cash flow NPV | | | | \$ 543,774 | \$ 512,994 | \$ 483,957 | \$ 456,563 | \$ 430,720 | \$ 406,339 | \$ 383,339 | \$ 361,640 | \$ 341,170 | \$ 321,859 | \$ 303,640 | \$ 286,453 | \$ 270,239 | \$ 254,942 | \$ 240,512 | \$ 226,898 | \$ 214,054 | \$ 201,938 | \$ 190,508 | \$ 179,724 | \$ 169,551 | \$ 159,954 | \$ 150,900 | \$ 142,358 | \$ 134,300 | | |
| Cumulative Cash flow NPV | | | | \$ 9,600,000 | \$ 10,143,774 | \$ 10,656,768 | \$ 11,140,724 | \$ 11,597,287 | \$ 12,028,006 | \$ 12,434,346 | \$ 12,817,685 | \$ 13,179,325 | \$ 13,520,495 | \$ 13,842,354 | \$ 14,145,995 | \$ 14,432,448 | \$ 14,702,686 | \$ 14,957,629 | \$ 15,198,140 | \$ 15,425,038 | \$ 15,639,092 | \$ 15,841,031 | \$ 16,031,538 | \$ 16,211,263 | \$ 16,380,814 | \$ 16,540,768 | \$ 16,691,668 | \$ 16,834,026 | \$ 16,968,326 | |

CAPEX \$ 9,600,000
OPEX - fixed \$ 576,400 per year
NPC (25 years) \$ 16,970,000

Appendix N — Weir proposal correspondence

Refer to following page.



OUT17/21143

The General Manager
Snowy Monaro Regional Council
PO Box 714
COOMA NSW 2630
Council@snowymonaro.nsw.gov.au

Dear Sir/Madam,

Planning Proposal: PP 2017 SMONA 001 00. Amend Bombala Local Environmental Plan 2012

Thank you for your referral of 18 April 2017, received on 27 April 2017, seeking comment on the proposal from DPI Fisheries, a division of NSW Department of Primary Industries.

DPI Fisheries is responsible for ensuring that fish stocks are conserved and that there is no net loss of key fish habitats upon which they depend. To achieve this, DPI Fisheries ensures that developments comply with the requirements of the *Fisheries Management Act 1994* (FM Act) (namely the aquatic habitat protection and threatened species conservation provisions in Parts 7 and 7A of the Act, respectively), and the associated *Policy and Guidelines for Fish Habitat Conservation and Management (2013)*. In addition, DPI Fisheries is responsible for ensuring the sustainable management of commercial, recreational and Aboriginal cultural fishing, aquaculture and marine protected areas within NSW.

The Department understands that the 'Planning Proposal' is to enable the construction of a new weir (approximately 2m high) on the Bombala River between Caveat and Young Streets Bombala. The resulting weir pool/lake is expected to inundate the beds of the Bombala River and the Coolumbooka River to beyond the confluence of the two rivers and up to the existing Coolumbooka Weir.

Please note that the Department's assessment does not concur with the way the project has been characterised as "an extension of the existing weir pool". The proposal involves the construction of a new weir which will create a new weir pool and inundate a previously un-impacted section of river channel. The Department considers that the footprint of the proposal, as shown in the Planning Proposal (Zenith) and Biodiversity Assessment (Envirokey), is likely to be incorrect. The diagrams show the weir pool/lake extending up the Coolumbooka River from the Bombala/Coolumbooka confluence but do not show the weir pool/lake extending up the Bombala River from the Bombala/Coolumbooka confluence. The weir pool is likely to extend further up the Bombala River than shown and is therefore likely to affect additional properties.

Both the Bombala and Coolumbooka Rivers are considered by the Department to be Type 1 (highly sensitive), Class 1 (major) key fish habitats under the *Policy and*

Guidelines for Fish Habitat Conservation and Management (2013). Both are also highly valued as recreational fishing areas.

As identified by both the Planning Proposal (prepared by Zenith) and Biodiversity Assessment (prepared by Envirokey), the Bombala and Coolumbooka Rivers are included as part of the Endangered Ecological Community (EEC) of the Snowy River Catchment in NSW under Schedule 4 of the FM Act. The proposal for amending the Bombala LEP 2017 to permit the construction of a new weir and creation of a water storage facility on the Bombala River and to rezone land associated with the existing Coolumbooka weir pool/lake is therefore of significant interest to the Department. It should also be noted that the provisions of section 34A of the *Environmental Planning and Assessment Act 1979* are applicable to this proposal.

A new weir across the Bombala River would obstruct fish passage to in excess of 50km of the upper reaches of the river. The Department would require a high quality fishway to be included in the design of the weir in accordance with section 218 of the FM Act. Significant offsets to compensate for the loss of flowing river habitat, likely impacts on the EEC and recreational fishing would also be required. Additionally, the “installation and operation of instream structures and other mechanisms that alter natural flow regimes of rivers and streams” is listed as a key threatening process under the FM Act. Construction and operation of the proposed weir would fall within this classification. It should be noted that approval to construct a weir (i.e. undertake a Key Threatening Process) within a core area of a listed EEC will require a Species Impact Statement to be prepared under the FM Act.

While the Department acknowledges the need to rezone the land to enable a weir to be constructed, we note that “the planning proposal has not resulted from a strategic study or report”. The Department’s view is that Council needs to consider completing an Integrated Water Cycle Management Study to:

1. demonstrate that additional Town Water Supply is required to meet future demand,
2. canvass the full range of options for supplying additional demand and
3. settle on a preferred option which balances economic, social and environmental considerations.

In light of the fact that the main purpose of the proposal is to allow for the construction of a new weir for town water supply, the Department recommends the issues raised above should be adequately addressed by the planning proposal.

If you require any further information, please contact Senior Fisheries Manager, Allan Lugg, on (02) 4428 3401.

Yours sincerely



Dr Geoff Allan
Deputy Director General DPI Fisheries

Date: 30 May 2017



Contact: Bob Britten
Phone: 02 6491 7809
Email: bob.britten@dpi.nsw.gov.au

Our ref: V15/3876#69,
File No:
Your Ref:

General Manager
Snowy Monaro Regional Council
PO Box 714
COOMA NSW 2630

16 May 2017

Attention: Grantley Ingram

Dear Grantley,

Re: DPI Water Consultation – Planning Proposal (PP_2017_SMONA_001_00) to amend Bombala LEP

Thank you for seeking comments on the proposed amendment to Bombala Local Environmental Plan 2012 – to permit the expansion of a water storage facility on a section of the Bombala River to facilitate town water supply.

DPI Water has reviewed the information and reports provided. The proposed rezoning of the Bombala River (Lot 7018 DP 94005) component is not supported, on the basis of significant reservation with regard to the suitability of the intended purpose of the rezoning, which is to enable the construction of a storage weir on the Bombala River. The proposed development of the Bombala River channel within the town precinct as a town water supply storage is not adequately justified or supported. The submitted information does not adequately demonstrate that the proposed use of the site and intended works are likely to be within the objectives and principles of the Water Management Act 2000 (WMA).

The Department recognises issues which have arisen with regard to meeting Bombala's town water supply requirements during serious drought periods. Advice has been provided in line with future water supply development should be based on both a justified water requirement and development within a framework of water use efficiency and best management practice for TWS. It is to be noted that the [NSW Government's Best-Practice Management of Water Supply and Sewerage Framework \(PDF, 23.9 KB\)](#) requires local water utilities to prepare and implement a sound 30-year Integrated Water Cycle Management (IWCM) Strategy.

Key elements which should be addressed include:

- The proposed rezoning should sit within a broader strategy for the sustainable water use in Bombala, consistent with the principles of the Water Management Act 2000 and DWE guidelines including NSW Best- Practice Management (BPM) of Water Supply and Sewerage Framework incorporating:
 - Integrated Water Cycle Management Planning (IWCM) recommended as an appropriate planning mechanism to manage the urban water services in an integrated manner. Council's overall water requirements and the best integrated solutions will not be fully realised until the IWCM is

www.water.nsw.gov.au

3rd Floor, Sapphire Market Place, Upper Street, PO Box 48 Bega NSW 2550 Australia t 1800 353 104 | e
water.enquiries@dpi.nsw.gov.au

underway or completed. At this stage the overall economics / benefits / costs of proposals remains unclear.

- Environmental Assessment is considered preliminary with a number of issues identified, but not effectively addressed at this stage. Identified issues include "Loss of vegetation and Habitat", impacts to Threatened Ecological Communities (*Tablelands Snow Gum Grassy Woodland* and the *Aquatic Ecological Community in the Catchment of the Snowy River in NSW*), Connectivity of habitat within the Bombala River and dispersal potential of immature platypus. Mitigation measures discussed are brief and considered non-specific with regard to environmental outcomes. Viable outcomes should align with the objectives of the WMA.
- The NSW Weirs Policy is a key document for consideration in the future development of the site. The goal of the State Weirs Policy is to halt and, where possible, reduce and remediate the environmental impact of weirs. The Principles of this policy should be addressed and incorporated at this early stage of development planning. A copy of this policy is attached.

For further information please contact Bob Britten, Water Regulation Officer at DPI Water (Bega office) on t: (02) 6491 7809; e: bob.britten@dpi.nsw.gov.au

Yours sincerely



for :

Vickie Chatfield
Regional Manager
Water Regulation



NSW Weirs Policy



NSW Weirs Policy

CONTEXT

In 1994 the Council of Australian Governments recognised that widespread natural resource degradation has occurred in Australia that has impacted on the quality and/or quantity of the nation's water resources. It adopted a framework for the efficient and sustainable reform of the water industry that included making formal allocations to the environment, based on the best scientific information available.

In September 1995, the Minister for Land and Water Conservation announced that a State-wide review of weirs would take place as part of the water industry reforms. The State Weirs Policy provides the framework for that review and establishes the goals and principles for the ongoing approval and management of weirs.

The State Weirs Policy is a further component of the *State Rivers and Estuaries Policy*, which was approved by the NSW Government in 1991. The *State Rivers and Estuaries Policy* establishes the framework for the management of rivers and estuaries of NSW and related ecosystems, such as wetlands. It is based on the Total Catchment Management philosophy, defined in the Catchment Management Act 1989 as "the coordinated and sustainable use and management of land, water, vegetation and other natural resources on a catchment basis so as to balance resource utilisation and conservation". Other policies under this framework include the State Wetlands Policy, Estuaries Policy and the Sand and Gravel Extraction Policy.

BACKGROUND

WHAT IS A WEIR ?

A weir is a structure (including a dam, lock, regulator, barrage or causeway) across a defined watercourse that will pond water, restrict flow or hinder the movement of fish along natural flow paths, in normal flow conditions.

THE ROLE OF WEIRS

There are estimated to be over 3,000 weirs on rivers in New South Wales. In some rivers significant lengths of stream are impounded behind weirs. For example 40% of the Barwon-Darling River is in weir pools.

Most weirs were originally built to provide a reserve of water for towns or properties to carry them through dry periods. Others were built to facilitate diversion of water into effluent streams or onto floodplains to spread the productive benefits of water over a wider area. In more recent years, weirs have been built to help river operators manage releases from dams or to increase water depth for pumps and diversion channels in major irrigation developments. In a few cases weirs have been built for purely recreational or aesthetic purposes. Some weirs in the Murray River were built to improve navigation.

WHY ARE WEIRS A PROBLEM ?

Weirs have served an important role in the amenity of the towns and properties they serve, but in recent years it has become apparent that this has been at a significant environmental cost. For example:

- the still waters in weir pools are less biologically productive than natural river channels, as native species adapted to diverse and free-flowing stream conditions are disadvantaged;
- riparian vegetation is drowned in the weir pool or killed by water-logging in low-lying areas of adjoining floodplains;
- weirs act as a trap for sediments, nutrients and pollutants;

- invertebrate and detrital drift is reduced, reducing biological productivity and diversity below weirs;
- weir conditions favour water stratification in summer and the growth of algae and development of algal blooms;
- weirs obstruct native fish migration and reduce native fish populations;
- the relatively stable conditions in weir pools give alien species, such as carp, an advantage over native species;
- weir pools may affect groundwater systems by maintaining artificially high water levels, resulting in groundwater mounding;
- inundation of surrounding areas destroys flora and fauna habitat, including that of threatened species;
- weirs accumulate sediments and prevent their downstream flow, resulting in erosion and scouring downstream of the weir;
- a constant level of discharge from weirs can result in geomorphological changes to rivers, tending to make them wider and shallower; and
- weirs can alter temperature regimes downstream, resulting in an adverse impact on native flora and fauna.

Another issue is that circumstances and community needs may have changed over the years since a weir was constructed. For example, an alternative water supply may now be available and an old weir may no longer serve its original purpose. Some of these, particularly those near towns, may have developed secondary uses as recreational and visual amenities for local communities, but others are now redundant and could be removed.

A number of older weirs need major maintenance or refurbishment. Before significant expenditure is incurred, the owners and the community should consider if the cost would be better spent on an alternative supply, or significant design changes, which will reduce the environmental impact of the weir.

Because of changing circumstances and the growing awareness of the adverse impacts most weirs have on the environment, it is time to evaluate the need for existing weirs, to remove redundant weirs, to devise ways to minimise the impact of weirs retained and to critically consider any proposals for new construction.

GOAL AND PRINCIPLES

GOAL

The goal of the State Weirs Policy is to halt and, where possible, reduce and remediate the environmental impact of weirs.

PRINCIPLES

The goal is to be supported by the adoption of the following management principles:

1. *The construction of new weirs, or enlargement of existing weirs, shall be discouraged.*
 2. *Weirs that are no longer providing significant benefits to the owner or user shall be removed, taking into consideration the environmental impact of removal.*
 3. *Where retained, owners shall be encouraged to undertake structural changes to weirs to reduce their environmental impact on the environment.*
- For example:

- reducing the crest level and pool storage volume to the minimum necessary to satisfy the purposes for which the weir is required;
- modification of the weir to reduce its impact. For example, installing a larger outlet to permit the release of environmental flows or water level variation, or installing a dropboard or gated opening to allow free flow when the weir is not needed; and
- constructing a fishway or modifying an existing fishway to reduce the weir's impact on fish passage.

4. *Where retained, owners of weirs with regulatory works shall prepare and adhere to operational plans to reduce the environmental impact of those weirs.*

For example:

- achieving water level variations;
- setting minimum rates of change for discharge and storage draw-down to mimic natural changes of water level within and downstream of the weir;
- raising gates fully during any portion of the year when a weir is not needed, such as in the non-irrigation season or during significant unregulated flows; and
- raising gates at times critical to maintenance of river health, wetlands, fish etc.

5. *Where retained, gates, offtake structures and fishways on all weirs shall be maintained in good working order.*

6. *Wetlands and riparian vegetation adjacent to weirs should be protected from permanent inundation.*

7. *Areas of environmental degradation caused by the impacts of weirs upstream and downstream of weir pools, should where possible be rehabilitated.*

8. *A respect for the environmental impact of weirs should be encouraged in all agencies and individuals who own, manage or derive benefits from weirs.*

The State Weirs Policy will have three components. The first relates to the approval to build a new, or expand an existing weir. The second is a review of all existing weirs (Weir Review Program). The third addresses the provision of fishways.

APPROVALS FOR NEW OR EXPANDED WEIRS

For the purposes of this part of the policy, weir means a licensable “work” as described under the Water Act 1912, and could include any dam, lock, weir, regulator, barrage or causeway which effects the quantity or flow of water in a river or lake. This part of the policy applies to privately owned and publicly owned weirs. This does not, however, include off-river storages or farm dams on small, ephemeral streams.

Note that the State Weirs Policy does not act to the exclusion of any applicable EIA or heritage protection legislation, notably the *Environmental Planning and Assessment Act 1979*.

A proposal to build a new weir or enlarge an existing weir should not be approved unless it can be demonstrated that the primary component of the proposal is necessary to maintaining the essential social and economic needs of the affected community.

In determining the need for a new or expanded weir, the following general principles apply:

- Provision for fish passage cannot be used as a sole justification to approve a proposal to enlarge an existing weir.
- An increase in town water supply for the purposes of meeting projected population demand cannot be used as a justification to approve a proposal to build a new, or expand an existing weir, if environmentally friendlier alternatives to meeting that demand exist, which are also economically feasible.
- Provision for future industrial expansion (such as, but not limited to, tourism) cannot be used as a justification to build a new, or expand an existing weir.
- Subject to the usual EIA process, a proposal for the construction of new, or expansion of an existing weir, that will result in a net environmental benefit may be approved

(eg. this may include options to offset the impact of new or enlarged structures by the removal of existing ones).

WEIR REVIEW PROGRAM


The aim of the Weir Review program is to examine the impacts of existing works and to develop a strategy which would lead to an enhanced environmental outcome. It will be achieved through undertaking an environmental audit of all weirs throughout the State, and assessing the appropriateness of the existence and/or operation of each weir, against a set of established criteria.

The review process will also cover all publicly and privately owned licensed weirs, and unlicensed weirs, including riparian rights weirs

(ie those weirs not requiring to be licensed under the *Water Act 1912*) and other in-stream structures such as road crossings, which have the hydraulic effect of a weir. Information about some of these weirs and structures, especially riparian rights weirs and road crossings, will be acquired through local knowledge.

The program will be implemented in two stages - an inventory and a review stage. The inventory will provide a comprehensive database on the weirs in each region. The review stage will evaluate the environmental impact of each weir against its socio-economic value.

From the results of the review, options for modifications to a weir will be explored. These might include structural changes, changes in weir operation rules or even removal of the weir. However, weirs will not be removed or changes made without consideration of the needs of the communities they serve and the socio-economic impact of removal. Following is the process of weir review. See Figure 1 below.



WEIR IDENTIFICATION

The first step in the weir review process will be to identify the number, location, purpose and size of the weirs in each region. A Weir Inventory Database has been adapted by the Department of Land and Water Conservation (DLWC) from a database developed by the Murray-Darling Basin Commission.

The database will record information on weir ownership, mode of operation, purpose, licensing and weir type, location, structural characteristics, some hydrological characteristics and environmental data.

TRIGGERS FOR REVIEW

A review of a weir may be triggered by any of the following:

- license renewal;
- consideration of a weir for modification under the Algal Management Program;
- consideration of a weir for inclusion of a fishway;
- weirs identified as having a serious environmental impact eg. groundwater, wetlands, water quality, etc.;
- weirs whose purpose is now redundant; and
- DLWC operational structures.

LICENCE RENEWAL

Licences for weirs are renewed every five years, or ten years for town water supplies. This gives the DLWC an opportunity to ask the owner to show cause why the licence for the structure should be renewed and for additional conditions to be imposed. The process would be:

- When the renewal notice is issued, the licensee will be forwarded background information on the environmental impact of weirs and the review process, and a pro-forma requesting updated information on the weir's structure, its current use, operating rules and justification for its retention. It will be the owner's responsibility to provide this information to the satisfaction of the DLWC.

- The information will be used to update the database on weirs, and for a review of the weir by DLWC regional staff, who may also draw on expertise from other government agencies.
- If a clear need for the weir can be established and no significant adverse impacts are identified, the licence will be renewed, subject to normal licensing procedures.
- If a significant impact is apparent or no clear and strong need for the weir is identified, follow up field inspection and discussion with the owners and other interested parties will occur. This will aim to determine if:
 - the weir can be removed,
 - the weir should be modified, or
 - additional conditions should be imposed on its use.

Where there is significant public use or interest in a weir, wider community consultation should be included in the investigation.

- On the basis of this investigation the DLWC may either refuse to renew the licence, or issue the renewal with conditions prescribing modifications or changed operating rules, or renew with existing conditions.

Weirs which are subject to licensing under the Water Act but not licensed, should be the subject of ongoing action to bring them into line with the Act's requirements. Before any licence is issued to authorise a structure, it should be subject to the same review process outlined above for renewal of existing licences.

ALGAL MANAGEMENT PROGRAM

Weirs being identified as structures of concern under the Algal Management Program shall be subject to a full review before a decision is made about an appropriate algal management strategy.

FISHWAYS

Once a weir is being seriously considered for inclusion of a fishway, a comprehensive review shall be included in the initial evaluation of the site before any significant expenditure on design or construction of a fishway is incurred.

WEIR ASSESSMENT

Each weir should be evaluated to determine the options for modification. Options may include doing nothing, weir removal, operational modifications or structural modifications such as lowering the crest height, constructing a larger diameter flow through pipe or installation of siphons, or fitting a fishway.

Consideration must be given to whether or not there is a realistic chance of effecting some change, either operational or structural on the weir. The likelihood of any action being taken must be assessed within the context of the current dependence and importance of the weir.

If it is likely that an operational or structural change, or removal may occur, a more detailed feasibility study should be undertaken and should include:

- socio-economic impact assessment of options;
- negotiation with owners/users;
- considerations regarding cumulative impacts of weirs in a locality; and
- environmental impact assessment of options including:
 - continuous impact of “do nothing” option
 - environmental benefits of options
 - environmental risks of options.

PROVISION OF FISHWAYS

Where necessary, weirs considered to have a significant impact on the movement of fish shall be formally considered for inclusion of a fishway.

The Fisheries Management Act 1994 requires that NSW Fisheries must be notified whenever a weir or any barrier to fish movement is constructed, altered or modified. If the Minister for Fisheries requests it, a fishway must be included in the design. Where the DLWC or NSW Fisheries identifies a weir as having a significant impact on the movement of fish, licensees should be advised and the weir review

process commenced without waiting for the normal renewal process.

A State Government program has been established, coordinated by the DLWC and NSW Fisheries to provide adequate fish passage in rivers to ensure the maintenance of native fish stocks for species conservation, ecosystem maintenance, and economic and cultural uses. The Fishways program seeks to identify weirs which are a significant barrier to fish passage. It will also design and trial a range of structural and operational solutions for fish passage.

The fishways program is strongly linked to the Weir Review program through the Weir Inventory, which is currently being developed by DLWC. Weirs targeted by either program will automatically trigger a broader review of options, as well as specific consideration of fishway requirements.

STATE WEIR REVIEW COMMITTEE

Progress on the weir review will be reported through the existing *State of the Rivers and Estuaries* Reports, and the proposed State of the Catchment Reports. A State Weir Review Committee will be established to further develop the weir review program and to give feedback on the approval process for new or expanded weirs. This committee will be comprised of representatives of:

- DLWC Resource Management;
- DLWC Water Business;
- EPA;
- NSW Fisheries;
- NSW Agriculture;
- Local Government Association;
- Catchment Management Committees;
- NSW Farmers Association;

- NSW Irrigators Council; and
- NSW Conservation interests (eg, Australian Conservation Foundation, Nature Conservation Council).

The role of the Committee will be, amongst other things:

- to review and refine criteria for weir review;
- to review and refine criteria for approval to construct new or expanded weirs;
- to provide advice on State priorities for weir management;
- to recommend on funding priorities;
- to promote the goal and principles of the State Weirs Policy; and
- to conduct an annual audit over the implementation and performance of the State Weirs Policy.

WHOLE OF GOVERNMENT APPROACH

DEPARTMENT OF LAND AND WATER CONSERVATION

The Department of Land and Water Conservation is the agency responsible for coordinating the implementation of the water reforms. The department will work closely with the community and other government agencies to define the mix of environmental, economic and social outcomes it wants, then manage the development, use and protection of our natural resources to achieve these outcomes.

ENVIRONMENT PROTECTION AUTHORITY

The Environment Protection Authority (EPA) is leading the process for recommending to the Government interim environmental (river flow and water quality) objectives for New South Wales intrastate rivers.

The EPA will audit the achievement of environmental objectives.

NSW AGRICULTURE

NSW Agriculture is committed to helping NSW food and fibre industries and our rural communities to be economically viable and environmentally sustainable.

NATIONAL PARKS AND WILDLIFE SERVICE

The National Parks and Wildlife Service is concerned with ensuring healthy and sustainable water resources in the future, including an equitable share of water for the environment.

NSW FISHERIES

NSW Fisheries will use the findings of its NSW Rivers Survey to pinpoint areas where there are problems - especially with carp - and seek remedial action to improve conditions for native fish and fish habitat, e.g. better water quality, increased water flows and removal of impediments to flow.

HEALTHY RIVERS COMMISSION

The Healthy Rivers Commission is holding independent public inquiries into individual rivers. The Commission will recommend longer term environmental objectives for each river and strategies to achieve them.



Office of
Environment
& Heritage

PP_2017_SMONA_001_00
DOC17/250451

Grantley Ingram
Deputy Director Service Planning
Snowy Monaro Regional Council
PO Box 714
COOMA NSW 2630
via email: council@snowymonaro.nsw.gov.au

Dear Mr Ingram

RE: Planning Proposal to Permit Water Storage Facility at Bombala

Thank you for referring the above planning proposal to permit a water storage facility at Bombala to the Office of Environment and Heritage (OEH) for our review and advice. We have reviewed the biodiversity, Aboriginal cultural heritage and flooding potential impacts of the proposed plan amendment.

The proposal is for Snowy Monaro Regional Council to construct a water storage weir on the Bombala River to augment the existing town water supply storage capacity. The weir is to be located on top of a natural sandbar at central point in town and would most likely incorporate a gabion rock basket and fish ladder. The structure would raise the level of the existing pool by about 1.5 metres, which would extend upriver to the existing weir on Coolumbooka River, where the elevation of the water level is not expected to exceed about 10 centimetres.

It is recognised that proposal has only currently a concept design at the LEP amendment stage to enable it to be made a permissible use in the zone. That final design will be confirmed and detailed assessment carried out as part of the Review of Environmental Factors for the project.

Biodiversity

OEH has reviewed the *Terrestrial and Aquatic Biodiversity Assessment Bombala Weir and Low-level Bridge* February 2016 by Envirokey and supports its recommendations and conclusions.

EnviroKey report concludes that the proposal is unlikely to have a 'significant effect' on any listed threatened species, communities, populations and their habitats and the current rezoning proposal should proceed. Also that the mitigation measures detailed within Chapter 5 should be adopted and implemented.

Of particular importance is the recommendations in regard to the area as platypus habitat. Two individuals were observed utilising the area during the site survey. This is going to require carefully planning and design in the detailed assessment at the REF stage.

OEH support the recommendation that a qualified ecologist would inspect the banks of the river where proposed bridge and weir construction would be undertaken prior to works beginning to ensure no platypus burrows are present. That a contingency plan would be formulated if so. Also that a Platypus management plan would be created following the management guides set out by the Australian Platypus Conservancy (<http://www.platypus.asn.au>) and Platypus Spot (www.platypusspot.org). This should be resolved before

the detailed design is finalised as it would provide an opportunity to incorporate platypus friendly measures into the project.

In this regard *Queanbeyan Platypus Awareness and Conservation Strategy 2012* prepared by Australian Platypus Conservancy has many relevant design considerations for urban friendly riparian environment for the species. This document and other sources of information can be found at www.qcc.nsw.gov.au/Environment/Sustainability/Platypus-Awareness-and-Conservation/Platypus-Awareness-and-Conservation

Aboriginal cultural heritage

In relation to Aboriginal cultural heritage matters; OEH advises that several Aboriginal sites are known to occur around the Bombala township and within the general locality of both the existing and proposed impoundments of the Coolumbooka Weir. These sites were recorded during previous archaeological assessments which concluded that there is potential for further evidence of Aboriginal heritage values to occur across the current subject area. As the planning proposal itself indicates, while no Aboriginal objects are recorded on AHIMS in the immediate area this may be because no Aboriginal cultural heritage survey has been conducted rather than reflecting an actual absence of Aboriginal objects. The Bombala River itself is a significant landscape feature that is often associated with Aboriginal people's traditional use of an area.

As such, OEH advises that while the current planning proposal may not specifically impact any Aboriginal objects at this time, any future development in this area will require a comprehensive Aboriginal cultural heritage assessment to be undertaken. Details regarding specific requirements for the preparation of Aboriginal cultural heritage assessments and AHIP applications can be found within the guidance material listed below;

OEH Guidelines

- Guide to investigating, assessing and reporting on Aboriginal cultural heritage in NSW. OEH 2011. Available online at:
<http://www.environment.nsw.gov.au/resources/cultureheritage/20110263ACHguide.pdf>
- Code of practice for archaeological investigation of Aboriginal objects in New South Wales, DECCW 2010. Available online at:
<http://www.environment.nsw.gov.au/resources/cultureheritage/10783FinalArchCoP.pdf>
- Aboriginal cultural heritage consultation requirements for proponents 2010. DECCW 2010. Available online at:
<http://www.environment.nsw.gov.au/resources/cultureheritage/commconsultation/09781ACHconsultreq.pdf>
- Applying for an Aboriginal Heritage Impact Permit guide for applicants, OEH (2011). Available online at:
<http://www.environment.nsw.gov.au/resources/cultureheritage/20110280AHIPguideforapplicants.pdf>

Flooding

The planning proposal makes reference to hydraulic assessment of the weir being in the FRMS. OEH has reviewed both the flood study and floodplain risk management study for Bombala and can't find any explicit reference to any proposed water supply weir in the Bombala River or potential impacts.

Could Council please forward a copy of the report in this regard.

Please contact Miles Boak on (02) 62297095 or by email miles.boak@environment.nsw.gov.au if you have any further questions regarding this development application.

Yours sincerely



24/5/17.

ALLISON TREWEEK
Senior Team Leader - South East Planning
Regional Operation Division

Our Ref: STH12/00088/02
Contact: Andrew Lissenden 4221 2769
Your Ref: PP_2017_SMONA_001_00



Transport
Roads & Maritime
Services

6 June 2017

Grantley Ingham
Snowy Monaro Regional Council
BY EMAIL: council@snowymonaro.nsw.gov.au

**PLANNING PROPOSAL – TO AMEND BOMBALA LOCAL ENVIRONMENTAL PLAN 2012
TO PERMIT A WATER STORAGE FACILITY ALONG SECTIONS OF THE BOMBALA RIVER
(PP_2017_SMONA_001_00)**

Dear Grantley

Roads and Maritime Services (RMS) refers to your email to Transport for NSW dated 18 April 2017 regarding the above planning proposal (PP) and subsequent email from Transport for NSW dated 15 May 2017 seeking RMS comment.

RMS has reviewed the information provided and wishes to seek clarification of the following in order to provide an informed comment:

- *SP2 Infrastructure Zoning*: The proposal seeks to rezone land inclusive of the lot that contains the Classified Road and associated bridge that crosses the Bombala River to SP2 Infrastructure (refer to Attachment 1). This bridge as well as a separate bridge over the Coolumbooka River at Bombala/Crankkies Plains, which adjoins the PP area (refer to Attachment 2) are controlled, inspected and maintained by the RMS.

RMS acknowledges the intent of the proposed rezoning so as to allow water supply systems and permit the expansion of a water storage facility on the affected land which, based on the submitted PP, includes the above lot on which the bridge that crosses the Bombala River is located. It is also acknowledged that the rezoning will allow a range of works in the proposed SP2 zone as 'development permitted without consent' or as 'exempt development'.

Concern is therefore raised that works could occur within close proximity to the existing bridges without any consultation with RMS. A review of the submitted PP and the provisions of *State Environmental Planning Policy (Infrastructure) 2007* has failed to locate any requirement for consultation to occur with RMS. Noting this concern, RMS seeks advice on what measures will be put in place to ensure that consultation with RMS is undertaken prior to the commencement of any works that may impact on the Classified Road and associated bridge structures that cross the Bombala River and Coolumbooka River (i.e. no works shall be carried out within either bridges footprint

Roads & Maritime Services

unless it is authorised by RMS – refer to comments below under the heading 'Existing Bridges' for details on each bridges footprint).

- *Flooding Impacts/assessment:* Noting the above comments and the general comments provided below in relation to each of the bridge structures that may be impacted upon, RMS at this time is unclear as to what impacts the PP will have on each structure. The main concern relates to the existing bridge over Bombala River at Bombala (RMS Bridge No. 7585). The RMS drawings for this bridge do not contain Australia Height Datum (AHD) details. As such, the levels provided can't be correlated with the proposed weir structure and resultant maximum water level. As this bridge has not been designed to be submerged, additional flood information is required to satisfy RMS that the bridge will not be impacted upon.

In addition to the above, RMS provides the following general comments for Council's consideration:


- *Existing Bridges:* There are currently two bridges that are controlled, inspected and maintained by RMS that may be affected by the PP (refer to Attachment 2). Additional details on each is provided below:
 - Bridge over Bombala River at Bombala (RMS Bridge No. 7585):
 - This is a plank concrete bridge with eight spans with a total bridge length of 121m and overall width of 13m. The bridge was built in 1986;
 - The bridge is suitable for Higher Mass Limit (HML) loading;
 - No works should be carried out within the bridge footprint unless is authorised by RMS. The total bridge footprint is defined by its length and width that is 121 m and 15m;
 - The bridge drawings that RMS have do not have Australia Height Datum (AHD). As such, the levels can't be correlated with the proposed weir structure. A survey will be required.
 - The latest inspection conducted on the bridge in March 2107 noted a flood level on Pier 1 which was one metre down from the soffit of the headstock. The river level was 6.5m during the inspection; and
 - The bridge hasn't been designed to submerged, so a flood study/assessment required for the proposed area so as to clearly identify any impacts of the proposal on the bridge.
 - Timber Truss Bridge over Coolumbooka River at Bombala (RMS Bridge No. 6129):
 - It has a two timber-truss span and four timber girder span. The total length and width of the bridge are 87m and 6m. The bridge was built in 1893 and under the timber truss strategic the bridge has been identified for replacement within 10 years.
 - The bridge is suitable only for General Access (ST42.5 and TDT50T);
 - No works shall be carried out within the bridge footprint unless is authorised by RMS. The total bridge footprint is defined by its length and width that is 87m and 10m;
 - The bridge drawings doesn't have Australia Height Datum (AHD) so the levels can't be correlated with the proposed weir structure; and
 - Flood in 2011 reported water level 300mm over the top of the bridge deck.

Roads & Maritime Services

RMS will reconsider the PP once the above issues/clarification is provided. Please ensure all future correspondence relating to this matter is sent to development.southern@rms.nsw.gov.au and quote RMS reference STH12/00088/02.

If you have any questions please contact Andrew Lissenden on 4221 2769.

Yours faithfully

A handwritten signature in blue ink, appearing to read 'Andrew Lissenden', with a stylized flourish at the end.

Andrew Lissenden
A/Manager Land Use
Southern Region

Roads & Maritime Services


Level 4, Southern Regional Office, 90 Crown Street, Wollongong NSW 2500 | PO Box 477 Wollongong East NSW 2520
T 02 4221 2460 | F 02 4221 2777 | www.rmsservices.nsw.gov.au |



RMS bridge/asset that it is proposed to rezone SP2
– Water Storage Facility – Bridge No. 7585



Roads & Maritime Services



BN 6129 - Timber Truss Bridge Over Coolumbooka River at Bombala/Crankkies Plains

BN 7585 - Bridge over Bombala River at Bombala



RECEIVED
23 MAY 2017

BY:

Our reference: DOC17/280501-01
Contact: Carlie Armstrong (02) 6229 7002

The General Manager
Snowy Monaro Regional Council
PO Box 714
Cooma NSW 2630
Attention: Mr Grantley Ingram

Dear Mr Ingram,

Planning Proposal (PP_2017_SMONA_001_00) to Amend Bombala Local Environmental Plan 2012

Thank you for your referral to the NSW Environment Protection Authority (EPA) of the above planning proposal on 01 May 2017. The EPA understands that the proposed amendment will permit the expansion of a water storage facility on a section of the Bombala River and rezoning of land associated with the existing Coolumbooka River storage for the purposes of securing town water supply.

The EPA is not an approval body in the assessment of the proposed amendment of the LEP. Accordingly the EPA does not have any comments on the proposed amendment of the LEP. However, the EPA is the Appropriate Regulatory Authority (ARA) pursuant to Section 6 of the *Protection of the Environment Operations Act 1997* (POEO Act) for activities carried on by a State of Public Authority. Accordingly, EPA is the ARA for activities carried on by Snowy Monaro Regional Council (Council), including works to expand water storage on Bombala River. In this regard, pending approval of the amendment to the LEP and prior to any works to construct the proposed weir, the EPA provides the following comments for consideration:

Water (Sediment and Erosion Control – Construction Phase)

Activities at the site must be carried out to ensure that any discharge from the premises complies with Section 120 of the POEO Act. Stormwater management and sediment and erosion control should be managed in a manner consistent with the guidelines "Managing Urban Stormwater: Soils and Construction" (*Landcom, 2004*). Sediment and erosion control measures

must consider clean water diversion around the construction site in order to reduce the volume of "clean" water to be controlled.

During construction of the weir, particular care must be taken to avoid pollution of waters and to ensure that stormwater discharge criteria and work plans are developed in consideration of the general framework outlined in the NSW Water Quality Objectives and Australian and New Zealand Guidelines for Fresh and Marine Water Quality (ANZECC and ARMCANZ, 2000).

Noise

Noise generated during the construction phase of the project must be managed in a manner consistent with the principles stated in the "Industrial Noise Policy" (NSW EPA, 2000). The amenity of any residents adjacent to the proposal must be considered.

Air

Council must ensure that dust is managed on site to reduce the potential for pollution of waters or impact on amenity of adjacent residents.


General

The EPA emphasise that all activities must be carried out with due diligence, duty of care, and in accordance with best management practices. All staff associated with operations at the site of the proposed works must be aware of the strict liability provisions of the POEO Act, particularly section 120 of the Act which prohibits the pollution of waters. In this regard, all personnel involved in the works for the proposal should be aware of the details of the works plans, legislation and associated pollution controls, and the environmental sensitivity of the receiving waters before any works commence.

The EPA would appreciate the opportunity to provide further comments once the environmental assessment for construction of the weir has been developed.

Thank you for discussing this matter with the EPA. If you have any queries or wish to discuss this matter further, please contact Carlie Armstrong or myself on (02) 6229 7002.

Yours sincerely



Mr Matthew Rizzuto
Unit Head - South East Region
Environment Protection Authority



Transport
for NSW

RECEIVED
19 JUN 2017

BY:

The General Manager
Snowy Monaro Regional Council
PO Box 714
COOMA NSW 2630

Attention: Grantley Ingram

**Exhibition of Planning Proposal (PP_2017_SMONA_001_00) to Amend Bombala
Local Environmental Plan 2012**

Dear Mr Sir/Madam

Thank you for your letter 18 April 2017 requesting Transport for NSW (TfNSW) review and comment on the amendments to the Bombala Local Environmental Plan 2012.

TfNSW have reviewed the documentation supplied in support of the above proposal and have no comment at this stage of the planning process. Please note that Roads and Maritime Services (RMS) will be providing a separate submission.

Thank you again for requesting TfNSW comment on this proposal. If you have any further questions, Mr Lee Farrell, Transport Planner at TfNSW, would be pleased to take your call on (02) 8202 2944. I hope this has been of assistance.

Yours sincerely

6/6/17

Mark Ozinga
**Principle Manager, Land Use Planning and Development
Freight, Strategy and Planning Division**

CD17/04706

GHD

Level 18 180 Lonsdale Street
Melbourne VIC 3000

T: 61 3 8687 8000 F: 61 3 8687 8111 E: melmail@ghd.com

© GHD 2020

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

3137056-33237-61/C:\Users\bjackson\Desktop\3137056-REP-
Rev1_Options_Assessment_Bombala_Water_Supply.docx

Document Status

| Revision | Author | Reviewer | | Approved for Issue | | |
|----------|--|------------|------------------|--------------------|--------------------|-----------|
| | | Name | Signature | Name | Signature | Date |
| A | L. De Rango M. Chapman B.Jackson | M. Chapman | <i>M.Chapman</i> | | | 7/5/2020 |
| 0 | L. De Rango M. Chapman B.Jackson | M. Chapman | <i>M.Chapman</i> | John Wearne | <i>John Wearne</i> | 21/5/2020 |
| 1 | J Wearne | M Chapman | <i>M.Chapman</i> | John Wearne | <i>John Wearne</i> | 12/6/2020 |

www.ghd.com

