

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
 Adaminaby STP - EPA Licence: 450
 EPA Point 2 - Final Discharge Effluent Sampling

[illegible]

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
Adaminaby STP - EPA Licence: 450
EPA Point 5 Upstream

DATE	pH	BOD (mg/l)	Oil & Grease (mg/l)	TSS (mg/l)	Ammonia (mg/l) N	Total P (mg/l) P	Total N TKN+NOX	Faecal Coliforms (CFU/100ml)	Entered by
04-Oct-23	7.90	1.00	0.50	12.00	0.05	0.05	0.44		CK
01-Nov-23	7.76	1.00	0.50	13.00	0.05	0.07	0.50	10	CK
29-Nov-23	7.55	4.00	0.50	23.00	0.05	0.17	1.37	8500	CK
27-Dec-23	7.12	6.00	0.50	31.00	0.05	0.17	2.03	640	CK
24-Jan-24	7.87	12.00	1.00	76.00	0.05	0.10	1.97	68	CK
21-Feb-24	7.66	2.00	0.50	21.00	0.05	0.04	2.13	90	CK
20-Mar-24	7.91	5.00	0.50	19.00	0.05	0.10	0.89	28	CK
Lowest	7.12	1.00	0.50	12.00	0.05	0.04	0.44	10.00	
Mean	7.68	4.43	0.57	27.86	0.05	0.10	1.33	1556.00	
Highest	7.91	12.00	1.00	76.00	0.05	0.17	2.13	8500.00	

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
Adaminaby STP - EPA Licence: 450
EPA Point 4 (Downstream)

DATE	pH	BOD (mg/l)	Oil & Grease (mg/l)	TSS (mg/l)	Ammonia (mg/l) N	Total P (mg/l) P	Total N TKN+NOX	Faecal Coliforms (CFU/100ml)	Entered by
04-Oct-23	8.09	2.00	0.50	48.00	0.30	0.24	2.04		CK
01-Nov-23	7.99	3.00	0.50	134.00	1.30	0.41	15.50	1440	CK
29-Nov-23	7.71	4.00	0.50	48.00	0.05	0.18	1.39	500	CK
27-Dec-23	7.12	4.00	0.50	15.00	0.05	0.10	1.87	660	CK
24-Jan-24	7.94	1.00	0.50	4.00	0.05	0.14	1.18	10	CK
21-Feb-24	8.10	1.00	0.50	67.00	0.05	0.06	0.62	9	CK
20-Mar-24	7.45	4.00	0.50	13.00	0.20	0.30	1.24	302	CK
Lowest	7.12	1.00	0.50	4.00	0.05	0.06	0.62	9.00	
Mean	7.77	2.71	0.50	47.00	0.29	0.20	3.41	486.83	
Highest	8.10	4.00	0.50	134.00	1.30	0.41	15.50	1440.00	