

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
 Adaminaby STP - EPA Licence: 450
 EPA Point 2 - Final Discharge Effluent Sampling

DATE	pH	TSS (mg/l)	Oil & Grease (mg/l)	BOD (mg/l)	Ammonia (mg/l)	Total N (mg/l) N	Total P (mg/l) P	Aluminium dissolved (mg/L)	Aluminium total (mg/L)	Faecal Coliforms (CFU/100ml)	Entered by
30-Oct-24	7.29	5.00	0.50	2.00	0.20	2.82	0.23	0.05	0.72	0.50	EA
17-Dec-24	7.38	7.00	0.50	1.00	0.05	2.15	0.10	0.05	0.86	0.50	EA
22-Jan-25	7.53	9.00	0.50	1.00	0.05	2.38	0.14	0.10	1.50	1.00	EA
19-Feb-25	7.75	7.00	0.50	1.00	0.05	1.66	0.06	0.04	0.92	1.00	EA
19-Mar-25	7.51	11.00	0.50	1.00	0.05	2.45	0.22	0.04	1.47	0.50	EA
16-Apr-25	7.07	6.00	0.50	1.00	0.05	2.30	0.11	0.04	1.02	1.00	EA
Lowest	7.07	5.00	0.50	1.00	0.05	1.66	0.06	0.04	0.72	0.50	
Mean	7.42	7.50	0.50	1.17	0.08	2.29	0.14	0.05	1.08	0.75	
Highest	7.75	11.00	0.50	2.00	0.20	2.82	0.23	0.10	1.50	1.00	
90%ile		10.00	0.50	1.50	0.13	2.64	0.23	0.08	1.49	1.00	
100%ile											
Licence Target											
90%	6.5-8.5	15	2	10	2	10	0.5	N/A	N/A	200	
100%		20	10	15	5	15	1	N/A	N/A		
Summary of Non-Compliance											
Date	Summary										