

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
Bombala STP - EPA Licence: 1752
EPA Point 3 (Upstream)

<i>DATE</i>	<i>pH</i> (pH Unit)	<i>TSS</i> (mg/l)	<i>Oil & Grease</i> (mg/l)	<i>BOD</i> (mg/l)	<i>Ammonia</i> (mg/l) N	<i>Total N</i> Total N(mg/l)	<i>Total P</i> (mg/l) P	<i>f coliform</i> (CFU/100ml)	<i>Entered by</i>
15-May-24	7.44	8	0.5	1	0.05	0.77	0.06	220	CK
12-Jun-24	7.17	7	0.5	1	0.05	0.68	0.05	142	CK
11-Jul-24	7.71	8	0.5	1	0.05	0.28	0.03	8	CK
7-Aug-24	7.55	5	0.5	1	0.05	0.24	0.02	2	CK
4-Sep-24	7.94	4	0.5	1	0.05	0.28	0.02	0.5	EA
2-Oct-24	7.76	5	0.5	1	0.05	0.28	0.02	12	EA
30-Oct-24	8.04	4	0.5	1	0.05	0.43	0.02	0.5	EA
27-Nov-24	7.81	4	0.5	1	0.05	0.46	0.02	8	EA
17-Dec-24	7.63	5	0.5	1	0.05	0.55	0.04	2	EA
22-Jan-25	7.39	6	0.5	1	0.05	0.62	0.06	38	EA
19-Feb-25	7.5	4	0.5	1	0.05	0.62	0.05	24	EA
05-Mar-25	6.9	6	0.5	1	0.05	0.69	0.04	36	EA
12-Mar-25	7.82	5	0.5	1	0.05	0.8	0.03	76	EA
19-Mar-25	7.67	4	0.5	1	0.05	0.83	0.04	60	EA
27-Mar-25	7.55	4	0.5	1	0.05	0.58	0.09	40	EA
02-Apr-25	7.45	66	0.5	1	0.05	0.95	0.07	294	EA
16-Apr-25	7.38	4	0.5	1	0.05	0.63	0.04	80	EA
Lowest	6.90	4.00	0.50	1.00	0.05	0.24	0.02	0.50	
Mean	7.57	8.76	0.50	1.00	0.05	0.57	0.04	61.35	
Highest	8.04	66.00	0.50	1.00	0.05	0.95	0.09	294.00	