

Snowy Monaro Regional Council
Quarterly Effluent Discharge Test Results
Bombala WTP - EPA Licence: 1640
EPA Point 1 (Discharge)

<i>DATE</i>	<i>TSS (mg/l)</i>	<i>Reviewed by</i>	<i>Entered by</i>
19-Apr-23	4		CK
15-Jun-23	3		CK
6-Sep-23	1		CK
21-Feb-24	27		CK
Lowest	1.00	0.00	0.00
Mean	8.75	0	0
Highest	27.00	0.00	0.00
Licence Target			
90%			
100%	50		

Summary of Exceedances	
Date	Summary